



# Annex to the CONFORMITY CERTIFICATE

No. 25TSU0152

Page 1/2

Specification – NIK 2104...P...

|   |   |   |   |   |   |   |   |   |   |   |
|---|---|---|---|---|---|---|---|---|---|---|
| NIK 2104                                  | X   | X | T | 2 | 6 | 0 | X | X | X | X |
| <b>Nominal voltage</b>                    |   |   |   |   |   |   |   |   |   |   |
| 1   | 220 V   |   |   |   |   |   |   |   |   |   |
| 2   | 230 V   |   |   |   |   |   |   |   |   |   |
| 3   | 240 V   |   |   |   |   |   |   |   |   |   |
| <b>Ability of energy measurement</b>      |   |   |   |   |   |   |   |   |   |   |
| 1   | In the forward direction  |   |   |   |   |   |   |   |   |   |
| 2   | In the forward and reverse direction                                  |   |   |   |   |   |   |   |   |   |
| <b>Sensors</b>                            |   |   |   |   |   |   |   |   |   |   |
| 0   | Without sensors   |   |   |   |   |   |   |   |   |   |
| M   | The magnetic field sensor is installed                                |   |   |   |   |   |   |   |   |   |
| C   | The electromagnetic field sensor is installed                         |   |   |   |   |   |   |   |   |   |
| MC  | Magnetic field and electromagnetic field sensors are installed        |   |   |   |   |   |   |   |   |   |
| <b>Relay availability</b>                 |   |   |   |   |   |   |   |   |   |   |
| 0   | Without Supply Control Switch   |   |   |   |   |   |   |   |   |   |
| 2   | The Supply Control Switch is installed                                |   |   |   |   |   |   |   |   |   |
| <b>The third interface is unavailable</b> |   |   |   |   |   |   |   |   |   |   |
| <b>Second interface availability</b>      |   |   |   |   |   |   |   |   |   |   |
| 6   | LTE interface is installed  |   |   |   |   |   |   |   |   |   |
| <b>Design</b>                             |   |   |   |   |   |   |   |   |   |   |
| 2   | The meter with optical port and additional sealed function button     |   |   |   |   |   |   |   |   |   |
| <b>Indication of multi-rate meters</b>    |   |   |   |   |   |   |   |   |   |   |
| <b>Type of connection</b>                 |   |   |   |   |   |   |   |   |   |   |
| P1  | Direct connected with reference (basic) and maximal current 5 (100) A |   |   |   |   |   |   |   |   |   |
| P6  | Direct connected with reference (basic) and maximal current 5 (80) A  |   |   |   |   |   |   |   |   |   |
| <b>Type of the measured energy</b>        |   |   |   |   |   |   |   |   |   |   |
| A   | Measurement of the active energy                                      |   |   |   |   |   |   |   |   |   |
| AR  | Measurement of the active and reactive energy                         |   |   |   |   |   |   |   |   |   |



*[Handwritten signature]*