



S.C TehnoWorld SRL

| CERTIFICAT DE CALITATE | |
|------------------------|-----------------|
| Nr. | Data |
| Beneficiar | |
| Adresa | |
| Aviz nr. | |
| Produs | |
| Executat dupa | SR EN 12201-2 - |
| Lot | |
| Cant. Livrata | M |
| Marcaj | |

Loc. Baia, nr. 1616, DN2E km 2
Jud. Suceava, RO-727020
0230 546 696 tel
0230 206 090 fax
0743 069 587 mob
office@tehnworld.ro
www.tehnworld.ro
RC: J33/145/2003
CUI: RO15231305
RO87BACX0000003023781012
UNICREDIT BANK

REZULTATE INCERCARI LOT PRODUS FINIT

| Nr. Crt. | Tip de incercare | Metoda | UM | Valori prevazute SR EN 12201-2 | Valori determinate | |
|----------|------------------------------------|---------------------------------|-------------|--|--------------------|---------|
| 1 | Aspect | Vizual | | Suprafete interioare si exterioare: curate, netede, fara crestaturi, adancituri sau alte defecte | Conform | |
| 2 | Culoare | Vizual | | Negru | Conform | |
| 3 | Caracteristici dimensionale | Diametru extern mediu/toleranta | SR ISO 3126 | mm | Conform | |
| | | | | Grosime perete/toleranta | mm | Conform |
| | | | | Ovalizare | mm | Conform |
| 4 | Indice de fluiditate la cald (MFR) | SR ISO 1133 | g/10min | 0.2 - 1.4 si $\pm 20\%$ fata de MFR granula | Conform | |
| 5 | Timp inducere oxidare la 200°C | ISO 11357-6 | minute | ≥ 20 | Conform | |
| 6 | Caracteristici tractiune | ISO 6259 | % | ≥ 350 | Conform | |
| 7 | Rezistența hidrostatică | SR ISO 1167 | ore | ≥ 165 | Conform | |

Produsul este conform cu prevederile normei europene de referinta SR EN 12201-2



SC TEHNO WORLD SRL

Carmen Maria Benea

Sef Laborator