



BULGARKONTROLA

BULGARKONTROLA SA -Sofia

Conformity Assessment Body for Construction Products

With identification number 14 and Permit № ПОССП-14 on 15.09.2016

Issued by Ministry of Regional Development and Public Works

CERTIFICATE OF CONFORMITY

14 – НУРВСПСРБ – 3875

Issued pursuant to Art. 14, par.1 and par.2 of the Regulation № ПД-02-20-1 on 05.02.2015 on the terms and conditions for use of construction products in the construction of the Republic of Bulgaria on Ministry of Regional Development and Public Works for the **construction product**

FITTINGS

with trademark wato/europevalves

made of ductile cast iron and epoxy coating are designed **for connection with pipes of PE/PVC** for construction of potable water supply systems outside buildings, with product range, operating pressure, and evaluated characteristics in accordance with national requirements as per Annex № 1 to this certificate.

placed on the market by

“WATO BG” LTD

6100 Kazanlak, South Industrial Zone

Id No 201549826

manufactured by

“WATO BG” LTD

6100 Kazanlak, South Industrial Zone

This certificate certifies that the product has been evaluated and meets national requirements set out in

BDS EN 12842:2012

*and item 7.2. of Annex 3 to item 2 of Order № 02-14-1329 from 12.03.2015,
the Minister of Regional Development and Public Works*

The Certificate was issued on **04/08/2023**, cancel the Certificate № **14-НУРВСПСРБ-3449** from **31/07/2020** and remains valid for three years until **03/08/2026** provided that the manufacturer ensures consistency of product characteristics and the conditions of production or production control have not been changed significantly.

Place: Sofia

Date: 04/08/2023

Director of "Conformity Assessment" Dept.

[Signature]
/T. Lyubenova/





1. Product range, operating pressure and dimensions

№	Product range	DN mm	PN bar
1.	Tapping saddles for PE/PVC Pipes-threaded end	32÷600	16
2.	Tapping saddles for PE/PVC Pipes-flanged end	100÷600	16
3.	Combine coupling	50÷300	10/16
4.	Restrained couplings for PE/PVC pipes	50÷400	10/16
5.	Restrained flange adaptors for PE/PVC pipes	50÷400	10/16
6.	Combi-flanges for PE/PVC pipes	50÷600	10/16

2. Evaluated characteristics in accordance with national requirements

Characteristics	Requirement to declare / border level
Dimensions , mm	BDS EN 12842, item.4.2; tabl. 1, 2, 3; т. 8, tabl. 7÷21
Leak tightness at internal hydrostatic pressure of the pipes and joints	No damage or leaks BDS EN 12842, item.4.6, tabl. 5, item. 7,tabl. 22
Mechanical properties of materials	
▪ Tensile strength	≥ 420 MPa BDS EN 12842, item.4.3.1.1
▪ Elongation after break	≥ 5 % BDS EN 12842, item. 4.3.1.1
▪ Brinell Hardness	≤ 250 HBW BDS EN 12842, item.4.3.1.2

Place: Sofia
Date: 04/08/2023

Director of "Conformity Assessment" Dept. 
/T. Lyubanova

