

**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME****CB TEST CERTIFICATE**

## Product

Residual current operated circuit-breakers with integral overcurrent protection for household and similar uses (RCBOs)

## Name and address of the applicant

HIMEL HONG KONG LIMITED  
11/F Kerry Ctr 683 King's Rd Quarry Bay  
Hong Kong

## Name and address of the manufacturer

DELIXI ELECTRIC LTD  
Delixi High Tech Industrial Park, Liushi Town, Yueqing City  
Zhejiang Province, China 325604

## Name and address of the factory

Note: When more than one factory, please report on page 2

See page 2

## Ratings and principal characteristics

See page 2

## Trademark (if any)



## Customer's Testing Facility (CTF) Stage used

-

## Model / Type Ref.

HDB3LE, HDB3LEG

## Additional information (if necessary may also be reported on page 2)

-

## A sample of the product was tested and found to be in conformity with

IEC 61009-1:2010+A1+A2  
IEC 61009-2-2:1991

## As shown in the Test Report Ref. No. which forms part of this Certificate

211201643SHA-001, 211201643SHA-002

This CB Test Certificate is issued by the National Certification Body

**Intertek Semko AB**  
Torshamnsgatan 43  
Box 1103  
SE-164 22 Kista, Sweden**intertek**

Signature:



Henrik Wikström

Date: 11 January, 2022

**Factories**

DELIXI ELECTRIC LTD  
Delixi High Tech Industrial Park  
Liushi Town, Yueqing City,  
Zhejiang Province, China 325604

DELIXI ELECTRIC (WUHU) LTD.  
Wuhu Machinery Industrial Park  
Wuhu City, Anhui Province, China 241100

**Ratings and principal characteristics**

$U_n = 230V\sim$  or  $240V\sim$  for 2P(1P+N),  $400V\sim$  or  $415V\sim$  for 3P, 4P(3P+N)  
 $I_n = 6, 10, 16, 20, 25, 32, 40, 50, 63A, B- \& C- \& D-$  type; 50/60Hz;  
 $I_{\Delta n} = 10mA$ (only for 2P), 30mA, 50mA, 75mA, 100mA, 300mA; Type-A & -AC  
 $I_{cs} = I_{cn} = 6000A, I_{\Delta m} = 2000A$

Date: 11 January, 2022

Signature:

