KRA D D DEKRA

D DEKR

## ATTESTATION OF CONFORMITY

Issued to: Schréder S.A.

Rue de Lusambo 67,B-1190 Brussels, Belgium

For the product: LED flood light (INDU FLOOD GEN2)

Trade name: Schréder

Type/Model: INFLD2a-b-c-d-2-e series

a=1 or 2 or 3, means the different size; b=1 to 7, means the different lumen:

c=730, 740, 750, 830 or 840, means the different CCT and CRI;

d=C1 to C3 or A1 to A4, means the different optics shape; e=N, D, A, S, means the different function, N means normal; D

means DALI dimming; A means 1- 10 V dimming; S means sensor

Ratings: 220-240 V~; 50/60 Hz; 375 W max; 1P66; ta; 50 °C; Class

Manufactured by: Schréder S.A.

Rue de Lusambo 67,B-1190 Brussels, Belgium

Requirements: EN 60598-1:2015+A1:2018

EN 60598-2-5:2015 EN 62493:2015

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in a confidential file no. 6075808.50.

This Attestation implies that the examined types are in accordance with the standards designated under the Low Voltage Directive (LVD) 2014/35/EU.

The examination has been carried out on one single specimen or several specimens of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

The CE marking may be affixed on the product if all relevant and effective EC directives are complied with

Arnhem, 2 September 2020 Number: 6075808.01AOC

DEKRA Testing and Certification (Shanghai) Ltd.

Kate Xu

Certification Manager

© Integral publication of this attestation and adjoining reports is allowed

CE