

CERTIFICATE

Certificate holder	Pestan d.o.o Put 1300 kaplara 188 34301 Bukovik SERBIA
Production facility	Bukovik, Serbia
Product	Pressure pipes made from Polyethylene (PE) for alternative installation techniques - PE 100-RC
Classification	EG 926.2, Outer diameter 75 mm up to 225 mm, type 2 2L
Type, Model	PE100RC pipe
Remarks to the type	PAS 1075 Type 2 2L - TW / Basis EN 12201-2
Testing basis	PAS 1075:2009-04 Certification Scheme Plastic Piping Systems (Pressure Pipes and Fittings) (2017-05)

Mark of conformity



Registration No. P1R0637

Valid until 2028-04-30

Right of use This certificate entitles the holder to use the mark of conformity shown above in conjunction with the specified registration number.
See annex for further information.

2023-05-11

K. Vehring
Dipl.-Biol. Katharina Vehring, M. Eng.
Certification Body



ANNEX

Page 1 of 1

Certificate

P1R0637 dated 2023-05-11

Technical Data

PAS 1075 Type 2 2L - TW
Basis EN 12201-2

Outer diameter 75 mm up to 225 mm
Minimum wall thickness 10,0 mm

Material: PE 100-RC

Type: see production facility related material list

colour outer layer: blue
colour inner layer: black

DW-8136CM0391

Operating over pressure burstlining: see Certification Scheme Plastic piping systems
(Pressure pipes and fittings)(2017-05) Annex O 14

**Testing laboratory/
Inspection body**

Hessel Ingenieurtechnik GmbH
Am Münsterwald 3
52159 Roetgen
GERMANY

Test report(s)

R22 06 4238-B_2NCT+ dated 2022-07-26
R23 06 4361-C_2NCT+ dated 2023-02-15
R23 06 4361-C4_PLT+ dated 2023-02-15
R23 06 4361-D_ACT dated 2023-02-15
R23 06 4451-B_2NCT+ dated 2023-02-22
R23 06 4451-B4_PLT+ dated 2023-02-22

