

Laboratory Service PHYSICAL TEST REPORT



R-Tech
Rue de Mons 3 – B-4000 Liège – Belgium
Tel.: +32 4 224 71 40 – Fax: +32 4 224 25 90
Member of Schröder Group

Subject: SKIDO 6 led's

Sample n°: P-E15365

Test purpose: Thermal test evaluation @ 1.05A and 700mA following IEC/EN 60598-1 Std

Remarks:

Test request n°: P-D15544

Folder n°: P-F14083

TEST CONDITIONS:

Operator: CLOSSET Frédéric

Load: 6 led's

Driver: Test 1A: Mean Well PLD-25-1050

Test 700mA: Mean Well PLD-16-700

Tc 70 °C

Measurement device:

Yokogawa TX10: thermal measurement

Yokogawa WT 210: primary EM

Fluke 87: secondary and led's EM

Junction Temperature measurement method

Junction temperature measurement by base temperature measurement and electrical measurement.

$$T^{\circ}_j = T^{\circ}_b + R_{jb} \times P_{led}$$

CONCLUSIONS:

@ 1,05A: Ta (IEC): 35 °C
Tq (IEC): 25 °C

@ 700 mA: Ta (CEI): 50 °C
Tq (CEI): 40 °C

Tq given for driver full load

T° given without wind effect to comply with IEC 62722-2-1

Duplicate to: Mr M. Thijs

LAB 01/07/2015

L. Maghe

//P-15CR544

A handwritten signature in blue ink, appearing to read "L. Maghe", is written over a faint yellow rectangular stamp.