

Reg.no.: ME000161392(01)

List of clarifications and deviations

For transformer 25 / 25 / 25 MVA, 115 / 38,5 / 11 kV

1. TECHNICAL REQUIREMENTS for 110/35/10 kV 25 MVA POWER TRANSFORMER
CHANGE (technical requirements. power transformer.pdf)

- Text part of document (page 1 - 52) vs TECHNICAL DATA SHEET (page 53 - 60). These two parts of this document have different values for same parameters, there are not united.

ETD offer:

For the contract purposes will be ETD guaranteed only parameters applied in the point 8. TECHNICAL DATA SHEET, of this document and set of standards IEC

30.11. 2023

Elaborated by: Ing. Vild