

STEELMET ROMANIA S.A.
 42nd DRUMUL INTRE TARLALE STR.
 032982 BUCHAREST 3rd SECTOR

INSPECTION CERTIFICATE
Type 3.1 acc. EN 10204
Certificate No : 1000460351
DATE: 18.12.2020
Delivery No : 0085220739

Customer	STEELMET ROMANIA S.A.			
Cust's Ref No	OR166		Cust's Part No	
Our Order No	1200112596 / 50	Quantity	620,00 MTR	Inspection Lot 020000661519

Designation	CuT m 022,000x1,00x5000 AJ HSH D M
-------------	---

according to	EN 12735-1 R290, P.E.D 97/23/EC, EN 13348.
--------------	---

Material	Cu-DHP
Chem. Anal.:	CU>99,90-P:0,015-0,040 OK

Characteristic	Unit of meas.	Specifications	Values	Sample No
ODmin	mm	$\geq 21,940$	21,990	1
ODmax	mm	$\leq 22,060$	22,020	1
ODav	mm	21,950 - 22,050	22,005	1
Smin	mm	$\geq 0,850$	0,870	1
Smax	mm	$\leq 1,150$	0,890 - 0,900	1
Sav	mm	$\leq 0,895$	0,880 - 0,885	1
LENGTH	mm	≥ 5000	5008	1
WGHT/m	kg/m	$\leq 0,5293$	0,5224 - 0,5237	1
Rm	N/mm ²	$\geq 290,0$	458,5	1
A50	%	$\geq 3,0$	6,0	1
EXPANSION	%	$\geq 30,0$	OK	1
C TOT. RES. IN.	mg/dm ²	$\leq 0,20$	0,07	1
ECT EN 1971	%	100	OK	-

DECLARATION OF COMFORMITY

The products detailed above, conform to the conditions and requirements of the purchaser and to the description, quantities and spec. stated. The Quality Assurance System applied to monitor their production, complies with the requirements of ISO 9001:2015, independently certified by TÜV HELLAS, with certification No 041070119.

Athens

19.12.2020

Q.C. INSPECTOR

Q.A. MANAGER



D. SKARMOUTSOS

ISSUE: C

REV: 2

DATE: DEC. 2017

FORM N3

e-mail: info@halcor.com
 website: www.halcor.com
 VAT number: EL094061318

Offices & Copper Tube Plant (Mailing Address)
 62nd km Athens-Lamia National Road,
 GR-32011 Inofita-Viotia, GREECE
 Tel.: +30 22620 48111, Fax: +30 22620 48911

Foundry
 60th km Athens-Lamia National Road,
 GR-32011 Inofita-Viotia, GREECE
 Tel.: +30 22620 53479, Fax: +30 22620 53925

Domestic Sales Dept
 252 Pireos str.
 GR-17778, Tavros, Athens, GREECE
 Tel.: +30 210 4898111, Fax: +30 210 4898397