



QUALITY CERTIFICATE			
No.	25339013	Date	04.02.2025

Customer	VOLTA SRL
Address	Loc: Chisinau Jud: Chişinău
Invoice no.	FX0000026821 / 04.02.2025

Product	Corrugated cable protection PE pipe DE 40 450 N/m ELCOR red C 50 ML
Normative	EN 61386-24
Batch	22402473
Quantity	5500.00 M
Marking	TEHNO WORLD ELCOR DN/OD 40 SR EN 61386-24 TIP 450 N/mp PROTECTIE LOT

FX0000026821
FX0000026821-04.02.2025

THE FINAL PRODUCT BATCH TESTING RESULTS

No. Crt.	Features	Test method	Unit	Requirements	Results
1	Surface visual control	Visual		Inside and outside pipe surfaces are clean, smooth, without any scratches, deformations or foreign inclusions, without pinholes or other defects	Complied
2	Colour	Visual		Outer wall Red Inner wall - black	Complied
3	Outside diameter (d _e)	SR EN 61386-24	mm	40-40,8	Complied
4	Inside diameter (d _i)	SR EN 61386-24	mm	>30	Complied
5	Compression force	SR EN 61386-24	N	=450	Complied
The tested corrugated pipe batch meets the requirements of the reference standard EN 61386-24.					

SC TehnoWorld SRL

Carmen Maria Benea
Laboratory Manager

