

Laboratory Service PHYSICAL TEST REPORT



R-Tech
Rue de Mons 3 – B-4000 Liège – Belgium
Tel.: +32 4 224 71 40 – Fax: +32 4 224 25 90
Member of Schröder Group

Subject: VOLTANA-0 6 led's class II PHILIPS driver 22 W

Sample n°: P-E17148

Test purpose: EMC tests according to EN 55015 & EN 61547 Standards

Remarks:

Test request n°: P-D17186

Folder n°: P-F16041

TEST CONDITIONS:

Operator: EMC - ULg

Test Summary

EN 55015 & EN 61547 Standards

Emission

Standard	Limit / Level	Result	
		PASS	FAIL
EN 55015 Conducted Emission	9kHz- 30 MHz	X	
EN 55015 Annex B	30 MHz – 300 MHz	X	
EN 61000-3-2	Class C a)	X	

Immunity

Standard	Limit / Level	Result	
		PASS	FAIL
EN 61000-4-2	4 kV at contact 2, 4 & 8 kV in the air Criteria B required	X	
EN 61000-4-3	3 V/m 80 MHz – 1 GHz AM 80 % 1 kHz Criteria A required	X	
EN 61000-4-4	1 kV 5 kHz Criteria B required	X	
EN 61000-4-5	0.5 & 1 kV MD Criteria C required	X	
EN 61000-4-5	Complementary levels 2, 4, 8 & 10 in MD Criteria C required	X	
EN 61000-4-6	3 V 150 kHz – 80 MHz AM 80 % 1 kHz Criteria A required	X	
EN 61000-4-11	0% U 0.5 period 70% U 10 periods Criteria B/C required	X	

VOLTANA-0 6 led's class II PHILIPS driver 22 W

Driver: Philips FP 22W 0.3-1A

EMC Auxiliaries: Varistors

CONCLUSIONS:



VOLTANA 0 6 led's driven by PHILIPS FP 22 W driver in class II complies with the CISPR/EN 55015 and EN 61547 Standards.

Remark: Surge protection tested OK up to 10 KV for Differential mode for the equipment with eventual Fuse replacement.

Duplicate to: MM Ph. Verbeeck
LAB 24/04/2017
G. Cheuvart

//P-17CR186