

Laboratory Service PHYSICAL TEST REPORT



R-Tech
Rue de Mons 3 – B-4000 Liège – Belgium
Tel.: +32 4 224 71 40 – Fax: +32 4 224 25 90
Member of Schröder Group

Subject: VOLTANA-2 16 led's @ 1A

Sample n°:

Test purpose: Tightness test IP66 following IEC/EN 60598-1 Standard

Remarks:

Test request n°: P-D14696

Folder n°: P-F14058

TEST CONDITIONS:

Operator: BOMBIL Patrick

Preconditioning: endurance test

Test	Result
IP6X : -Luminaire switched ON until stable T° -Talcum in suspension (blowing ON) -After 1', luminaire OFF -Talcum for 3 hours	OK.
IPX6 : - Luminaire switched ON until stable T° - Luminaire switched OFF and immediately sprayed with water jet - Hose Φ 12,5 mm - Water pressure: 1 kg/cm ² - Spraying distance: 3 m - Duration of test: 3 minutes	OK.

CONCLUSIONS:

VOLTANA-2 16 led's @ 1A satisfies the IP66 test following IEC/EN 60598-1 Standard.

Duplicate to: Mr M. Thijs
LAB 23/09/2014
J.P. Harchies

//P-14E696

A handwritten signature in blue ink, appearing to read "J. P. Harchies", with a horizontal line drawn underneath it.