



Product Approval
TTR 7816523 000 00
05.12.2020

Confirmation

Type test for on-load tap-changer type:

VACUTAP® VRM III 700Y-123/RD-10 19 3W

The type test was performed in accordance with IEC Standard Publication 60214-1:2014, sub-clauses 5.2.2, 5.2.3, 5.2.4, 5.2.5, 5.2.6 and 5.2.8. All tests were passed successfully.

The tests are documented in the following type test reports:

Diverter switch

Temperature rise of contacts.....	VR 1E 001e
Switching tests.....	VR 2E 001e
Short-circuit current test.....	VR 3E 001e
Transition resistor test.....	VR 4E 002e
Mechanical tests.....	VR 5E 001e
Dielectric tests.....	VR 6E 003e

Tap selector

Temperature rise of contacts.....	VR/R/VM/M 1E 001e
Short-circuit current test.....	VR/R/VM/M 3E 001e
Mechanical tests.....	VR/R/VM/M 5E 001e
Dielectric tests.....	VR/R/VM/M 6E 002e

i. V. Dr. Thomas Strof

[valid without signature]

Maschinenfabrik Reinhausen GmbH
- PRODUCT APPROVAL -

Maschinenfabrik Reinhausen GmbH
Falkensteinstraße 8
93059 Regensburg, Germany
Phone +49 941 40 90-0
info@reinhausen.com
www.reinhausen.com

Managing Directors:
Dr. Nicolas Maier-Scheubeck
Wilfried Breuer
Holger Michalka

F01105:20

Chairman of Supervisory
Board: Hans-Jürgen Thaus
Commercial register
Regensburg HRB 3687
VAT reg. no.: DE133705195

Reinhausen Group