

TÜV Rheinland LGA Products GmbH • 51105 Cologne • Germany

Atlas Copco Airpower n.v.
P.O. Box 104
Boomsesteenweg 957
2610 Wilrijk
Belgium

Your correspondence
Dr. Norbert Horlemann

Order-No.: 3047714

Phone +49 (0)221-806-1896
Fax +49 (0)221-806-1461
Mail horlema@de.tuv.com

Customer Service Center
for Products
Phone +49 911 655-5225

Mail service@de.tuv.com

Cologne, 05th March 2012

Type Test certificate
Evaluation of the residual aerosol oil content after an
Atlas Copco PD+ filter
Test report No.: 3047714

The Atlas Copco PD+ filters are measured under the test conditions according to ISO 12500-1:2007, the compressed air samples are analyzed according to the ISO 8573-2:2007 test method.

	Maximum residual aerosol oil content	Average wet pressure drop
PD+-filter	0.008 mg/m ³	< 215 mbar

i. V.



Björn Koch

i. A.



Dr. rer. nat. Norbert Horlemann

TÜV Rheinland
LGA Products GmbH

Am Grauen Stein 29
51105 Cologne
Germany

Headquarter

TÜV Rheinland
LGA Products GmbH

Tillystraße 2
90431 Nuremberg
Germany

Phone +49 911 655 5225
Fax +49 911 655 5226
service@de.tuv.com
www.tuv.com/safety

Board of Management

Dipl.-Ing.
Jörg Mähler, Spokesman

Dipl.-Kfm.
Dr. Jörg Schlösser

Nuremberg HRB 26013
VAT No.: DE811835490