

KEMA REPORT OF PERFORMANCE

1087-16

Object	Heat shrinkable outdoor termination
Type	MZDWK-3-15-C
	8,7/15 (17,5) kV – 3 x 185 mm ² – Cu – XLPE
Client	Jiangsu Jiameng Electrical Equipment Co., Ltd. (MELEC), Qidong, China
Manufacturer	Jiangsu Jiameng Electrical Equipment Co., Ltd. (MELEC), Qidong, China *)
Tested by	KEMA Nederland B.V., Arnhem, The Netherlands
Date of tests	16 November 2015 to 25 May 2016
Test specification	The tests have been carried out in accordance with IEC 60502-4 (2010), subclause Table 6 (test sequence 1.1. and 1.2).
Summary and conclusion	The object has complied with the relevant requirements of the standard.

This report applies only to the object tested. The responsibility for conformity of any object having the same type references as that tested rests with the Manufacturer.

*) as declared by the manufacturer

This report consists of 72 pages in total.

KEMA Nederland B.V.


J.P. Fonteijne
Executive Vice President
KEMA Laboratories



KEMA

Laboratories

Arnhem, 22 June 2016