






Subject:	Investigation of: Repairclamp Series 748	Customer: AVK Rewag	Product: FS20 310-330 L=300	Test: Pressure test	Signature:
Name:	Marco van den Berg	Job Title:	Quality and Development Engineer	Date:	24-01-2018

Test	Clamp	Torque	Leakage
1	Serie 748 (NBR)	120Nm	No leakage at 17bar after 6hours

## Test 1: 748

Repairclamp Series 748/FS20/310-330/(fingers)

			
Test-sample on 326 testpipe		Pressure increased to 17bar	
			
Rubber at 120Nm		No leakage at 17bar after 6 hours	