



S.C TehnoWorld SRL

Loc. Baia, nr. 1616, DN2E km 2
Jud. Suceava, RO-727020
0230 546 696 tel
0230 206 090 fax
0743 069 587 mob
office@tehnworld.ro
www.tehnworld.ro
RC: J33/145/2003
CUI: RO15231305
RO87BACX0000003023781012
UNICREDIT BANK

CERTIFICAT DE CALITATE	
Nr.	Data
Beneficiar	
Adresa	
Aviz nr.	
Produs	
Executat dupa	SR EN 13476-2 SR EN 1401-1
Lot	
Cant. Livrata	buc
Marcaj	

REZULTATE INCERCARI LOT PRODUS FINIT

Nr. Crt.	Tip de incercare	Norma	UM	Valori prevazute	Valori determinate
1	Aspect	SR EN ISO 13476-2		Suprafete interioare si exterioare: curate, netede, fara crestaturi sau alte defecte	Conform
2	Culoare	SR EN 1401-1		RAL 8023	Conform
3	Lungime utila bara	SR ISO 3126	m		Conform
4	Diametrul exterior mediu (d)	SR EN ISO 13476-2	mm		Conform
5	Diametrul interior mediu (d _i)	SR EN ISO 13476-2	mm		Conform
6	Ovalizare	SR EN 1401-1	mm		Conform
7	Grosime medie perete interior (e _s)	SR EN ISO 13476-2	mm		Conform
8	Grosime medie perete total (e _{mi})	SR EN 1401-1	mm		Conform
9	Rigiditate circulara teava	SR EN ISO 9969	kN/m ²		Conform
10	Flexibilitate circulara (deformare 30% d _e)	EN 13968		Fara delaminare, fisuri, rupturi	Conform
11	Rezistenta la impact	EN 3127		≤ 10%	Conform
12	Etanseitate - ansamblu teava, mufa, garnitura (0.5 bar / 1min) Proba de Tip	EN 13254		Fara scurgeri de apa	Conform

CONCLUZII: Lotul testat de teava PVC multistrat corespunde cerintelor standardului de referinta SR EN 13476-2 si de asemenea corespunde cerintelor de geometrie ale standardului SR EN 1401-1.



SC TEHNO WORLD SRL

Carmen Maria Benea

Sef Laborator

CC15 Locul emiterii: loc. Baia, jud. Suceava

Pagina 1 | 1

DRAFT