

Device specification

Quantity	Article No.	Deliv.Cat	Description
1	A02311		SAL A0 0
1	ACTSEQC15	A	- Sequencing cable 15m
1	VCC	B	- Voltage monitoring for 1-ph units - 9.
			<u>Voltaaj monitoring calitatii puterii electrice cu resetarea automata</u>
1	ACTKPDC1010H	A	- external LCD user- and service interface (Keypad) - <u>Interfata utilizator</u>
1	ACTSERC1010	A	- Serial adapter for BMS/Gateway connection - <u>Adapter pentru conectarea la WIB8000 setarea functionarii zonala in regim de secventa cu unitatea existenta</u>
1	CRA	A	- Crankcase heater for Scroll Compressor (for outdoor-temp. < -20°C down to -25°C) - <u>încălzitor carter pentru Compresor Scroll</u>