

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Name and address of the applicant

Name and address of the manufacturer

Name and address of the factory

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Trademark / Brand (if any)

Customer's Testing Facility (CTF) Stage used
Model / Type Ref.

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

As shown in the Test Report Ref. No. which forms part of this Certificate

Split-Type Air-Conditioner

GD Midea Air-conditioning Equipment Co., Ltd.
Lingang Road, Beijiao, Shunde, Foshan, 528311,
Guangdong, China

GD Midea Air-conditioning Equipment Co., Ltd.
Lingang Road, Beijiao, Shunde, Foshan, 528311,
Guangdong, China

See page 2

☒ Additional Information on page 2

Model A:

IU: 220 V – 240 V; 50 Hz; OU: 380 V – 415 V 3 N~;
50 Hz; 6100 W; 13,0 A; Class I

Model B:

IU: 220 V – 240 V; 50 Hz; OU: 380 V – 415 V 3 N~;
50 Hz; 7500 W; 14,0 A; Class I

Midea

-

See page 2

Refrigerant: R32; OU: IP24;
(IU: Indoor unit; OU: Outdoor unit)
Modification of FI-35412/A1 dated 2018-07-05,
additional alternative components.

☒ Additional Information on page 2

IEC 60335-2-40:2013,
IEC 60335-2-40:2013/AMD1:2016
IEC 60335-1:2010, IEC 60335-1:2010/AMD1:2013,
IEC 60335-1:2010/AMD2:2016

National Differences:

-

GZES170901597401
GZES170901597401A1
GZES170901597401A2

This CB Test Certificate is issued by the National Certification Body

SGS Fimko Ltd
Takomotie 8
FI-00380 Helsinki, Finland



Date: 2021-08-04

Signature:



David Guo
Senior Technical Manager

Name and address of the factories:

1. GD Midea Air-conditioning Equipment Co., Ltd.
Lingang Road, Beijiao, Shunde, Foshan, 528311, Guangdong, China
2. Guangzhou Hualing Refrigerating Equipment Co., Ltd.
6 Meide 1st Road, Zhujiang Industrial Park, Zhujiang Street, Nansha, Guangzhou, Guangdong, China

Additional information:**Model / Type Ref.:**

Model A:
IU: MTI-48HWFNX-QRD0, OU: MOE30U-48HFN1-RRD0;
Model B:
IU: MTI-60HWFNX-QRD0, OU: MOE30U-60HFN1-RRD0

SGS Fimko Ltd
Takomotie 8
FI-00380 Helsinki, Finland



Date: 2021-08-04

Signature:



David Guo
Senior Technical Manager