



CERTIFICATE

Certificate registration number: ZSTS/SWZE/6847

The notified body
TÜV AUSTRIA GMBH (identification number 0408)
certifies, that the manufacturer

GasOil Endüstriyel Üretim Sanayi Ticaret A.Ş. Sasalı Merkez 43 Sok. No:29, 35620 Çiğli / İZMİR

operates a quality assurance system for design, manufacture, final inspection and testing according to Annex III of the Pressure Equipment Directive 2014/68/EU which is subject to surveillance by TÜV AUSTRIA GMBH and is therefore authorized to apply the following conformity assessment procedures according Pressure Equipment Directive 2014/68/EU:

Module H

Scope: Insulation Joint Size: 1" to 56", Rating: ANSI 150 up to ANSI 1500, Pressure: 6 bar to 250 bar.

Based on our audit carried out on February 3, 2025 in accordance with Annex III of the Pressure Equipment Directive 2014/68/EU we certify compliance with the requirements.

Results of the audit are recorded in the audit report 24-IS-2064-2025-PED-Modul H-005 dated February 3, 2025.

Pressure equipment and assemblies within the scope of this certificate shall carry the marking as illustrated:

C€ 0408

This certificate is valid from March 20, 2025 to March 19, 2028 provided that the terms and conditions of the agreement with the notified body are met.

Vienna, 20.03.2025

DI Martin Schwarz

Notified Body 0408 TÜV AUSTRIA GMBH





1230 Vlenna / Austria Tel: +43 (0)5 0454 email: info@tuv.at Web: http/www.tuv.at

Deutschstrasse 10





SERTIFIKA

Gasoil Endüstriyel Üretim Sanayi Ticaret Anonim Şirketi

Sasalı Merkez Mahallesi 43 Sokak No:29 Çiğli, İzmir, Türkiye

IFC Global Sertifikasyon, yukarıda adı geçen kuruluşun yönetim sisteminin değerlendirildiğini ve aşağıdaki standardın gerekliliklerine uygun olduğunu teyit eder.

Standard:

ISO 9001:2015

Kapsam:

Endüstriyel tesisler, gaz ve petrol boru hatları için ekipman, makine, basınçlı kap üretimi

 İlk Yayın Tarihi
 : 22.11.2024

 Yayın Tarihi
 : 22.11.2024

Revizyon No : 0

Sertifika Geçerlilik Tarihi: 21.11.2025Sertifika Bitiş Tarihi: 21.11.2027

Sertifika No : IFC-Q-11-24-2413







Onay



CERTIFICATE

Gasoil Endüstriyel Üretim Sanayi Ticaret Anonim Şirketi

Sasalı Merkez Mahallesi 43 Sokak No:29 Çiğli, İzmir, Türkiye

IFC Global Certification confirms that the above-named organization's management system has been assessed and complies with the requirements of the following standard.

Standard:

ISO 9001:2015

Scope:

Production of equipment, machinery, pressure vessels for industrial plants, gas and oil pipelines

Initial Date Issue Date

Revision Number

Date of Validity : 21.11.2025 : 21.11.2027 **Expiry Date Certificate No**

: IFC-Q-11-24-2413












INSULATING JOINT DATA SHEET 4" ANSI #600



QTY:2

ITEM		DESCRIPTION		
TYPE	INSULATING JOINTS, Monolithic			
DESIGN CODE	ASME B 31.1 - ASME B 31.3 - ASME B 31.4 - ASME B 31.8 - ASME VIII Div.I Appx.2			
DESIGN PRESSURE (barg)	100			
TEST PRESSURE (barg)	150			
DESIGN TEMPERATURE (°C)	-20 / +70 °C			
RATING (ASME/ANSI #) Class	CL600			
ENDS	BUTT WELDED - API 5L / B16.25 / B16.5			
DESIGN FACTOR	According to project datas (standard is 0.6)			
CONNECTION PIPE DN "C" (mm/in.)	114,3 / 4"			
CONNECTION PIPE THK "t" (mm)	6,02			
JOINT OVERALL LENGTH "A"(mm)	500			
MATERIAL	"D" PIPES (API 5L or 6	equivalent)	API 5L - Gr. X52	
	"F-O-P" Body Parts		ASTM A694 F52	
	"G" O Ring Double Seal Gasket System		ASTM D 2000 Nbr / Viton	
	"E" Insulating Filling Material		Epoxy Resin	
	"R" Isolating Ring		D 709 G10 / G11	
	EXT External Coating		Solvetless Epoxy Paint 3000 μm	
	INT Internal Coating		Solvetless Epoxy Paint 500 μm	
INSTALLATION	ABOVEGROUND / UNDERGROUND / SUBSEA			
PNEUMATIC TEST	8 bar for 10 min			
HYDROSTATIC TEST	1.5 Times the Design Pressure - 1 hour (Or as per Customer Requirements)			
HYDRO FATIGUE TEST	5 cycles at 80% test pressure			
DIELECTRIC TEST	3 KV @ 1 minute AC 50÷60 Hz (25°C dry air)			
ELECTRIC INSULATION TEST	≥ 5 MΩ @ 1000 Volt DC			
WELDS	W1-W2-W3 are in accordance with ASME Sec.VIII And Sec IX			
NDT TEST	Butt welds W1-W2 are in accordance with ASME Sec V: RT			
	Closure weld W3 is in accordance with ASME Sec.VIII : PT / MT			
MATERIAL CERTIFICATION	EN 10204 - 3.1 (EN 10204 - 3.2 if requested)			
INSPECTION & TEST/ACCEPTANCE	Manufacturer Standard / Customer Applicable Requirements			
CORROSION ALLOWANCE	Standard 1.6 mm / As per Customer Requirements			
SERVICE	Gas, Hydrocarbons, Oil, Chemical Fluids, Water, Toxic, etc.			

- 1) Uncoated pipe length is 50 mm at each end for welding.
- 2) All pressure materials are suitable for resistance to $\mathrm{H}_2\mathrm{S}$ environments.
- 3) This information is approximate. The exact data shall be specified during the PO Stage.
- 4) Material not in contact to the fluid
 5) Cables Lugs will be installed on Isolating Joint only if requested.

400 (D) F (G) EXT 6,02 114,3 156 (INT)

80

INSULATING JOINT DATA SHEET 4" ANSI #150

160

QTY: 1


160

ITEM		DESCRIPTION		
TYPE	INSULATING JOINTS, Monolithic			
DESIGN CODE	ASME B 31.1 - ASME B 31.3 - ASME B 31.4 - ASME B 31.8 - ASME VIII Div.I Appx.2			
DESIGN PRESSURE (barg)	25			
TEST PRESSURE (barg)	37,5			
DESIGN TEMPERATURE (°C)	-20 / +70 °C			
RATING (ASME/ANSI #) Class	CL150			
ENDS	BUTT WELDED - API 5L / B16.25 / B16.5			
DESIGN FACTOR	According to project datas (standard is 0.6)			
CONNECTION PIPE DN "C" (mm/in.)	114,3 / 4"			
CONNECTION PIPE THK "t" (mm)	6,02			
JOINT OVERALL LENGTH "A"(mm)	400			
MATERIAL	"D" PIPES(API 5L or equivalent)		API 5L - Gr. X52	
	"F-O-P" Body Parts		ASTM A694 F52	
	"G" O Ring Double Seal Gasket System		ASTM D 2000 Nbr / Viton	
	"E" Insulating Filling Material		Epoxy Resin	
	"R" Isolating Ring		D 709 G10 / G11	
	EXT External Coating		Solvetless Epoxy Paint 3000 μm	
	INT Internal Coating		Solvetless Epoxy Paint 500 μm	
INSTALLATION	ABOVEGROUND / UNDERGROUND / SUBSEA			
PNEUMATIC TEST	8 bar for 10 min			
HYDROSTATIC TEST	1.5 Times the Design Pressure - 1 hour (Or as per Customer Requirements)			
HYDRO FATIGUE TEST	5 cycles at 80% test pressure			
DIELECTRIC TEST	3 KV @ 1 minute AC 50÷60 Hz (25°C dry air)			
ELECTRIC INSULATION TEST	≥ 5 MΩ @ 1000 Volt DC			
WELDS	W1-W2-W3 are in accordance with ASME Sec.VIII And Sec IX			
NDT TEST	Butt welds W1-W2 are in accordance with ASME Sec V : RT			
	Closure weld W3 is in accordance with ASME Sec.VIII : PT / MT			
MATERIAL CERTIFICATION	EN 10204 - 3.1 (EN 10204 - 3.2 if requested)			
INSPECTION & TEST/ACCEPTANCE	Manufacturer Standard / Customer Applicable Requirements			
CORROSION ALLOWANCE	Standard 1.6 mm / As per Customer Requirements			
SERVICE	Gas, Hydrocarbo	ns, Oil, Chemical Fluids, Wa	ater,Toxic, etc.	

- 1) Uncoated pipe length is 50 mm at each end for welding.
- 2) All pressure materials are suitable for resistance to $\mathrm{H}_2\mathrm{S}$ environments.
- 3) This information is approximate. The exact data shall be specified during the PO Stage.
- 4) Material not in contact to the fluid
 5) Cables Lugs will be installed on Isolating Joint only if requested.

INSULATING JOINT DATA SHEET 6" ANSI #150

QTY:2




ITEM		DESCRIPTION		
TYPE	INSULATING JOINTS, Monolithic			
DESIGN CODE	ASME B 31.1 - ASME B 31.3 - ASME B 31.4 - ASME B 31.8 - ASME VIII Div.I Appx.2			
DESIGN PRESSURE (barg)	25			
TEST PRESSURE (barg)	37,5			
DESIGN TEMPERATURE (°C)	-20 / +70 °C			
RATING (ASME/ANSI #) Class	CL150			
ENDS	BUTT WELDED - API 5L / B16.25 / B16.5			
DESIGN FACTOR	According to project datas (standard is 0.6)			
CONNECTION PIPE DN "C" (mm/in.)	168,3 / 6"			
CONNECTION PIPE THK "t" (mm)	7,11			
JOINT OVERALL LENGTH "A"(mm)	500			
MATERIAL	"D" PIPES(API 5L or equivalent)		API 5L - Gr. X52	
	"F-O-P" Body Parts		ASTM A694 F52	
	"G" O Ring Double Seal Gasket System		ASTM D 2000 Nbr / Viton	
	"E" Insulating Filling Material		Epoxy Resin	
	"R" Isolating Ring		D 709 G10 / G11	
	EXT External Coating		Solvetless Epoxy Paint 3000 μm	
	INT Internal Coating		Solvetless Epoxy Paint 500 μm	
INSTALLATION	ABOVEGROUND / UNDERGROUND / SUBSEA			
PNEUMATIC TEST	8 bar for 10 min			
HYDROSTATIC TEST	1.5 Times the Design Pressure - 1 hour (Or as per Customer Requirements)			
HYDRO FATIGUE TEST	5 cycles at 80% test pressure			
DIELECTRIC TEST	3 KV @ 1 minute AC 50÷60 Hz (25°C dry air)			
ELECTRIC INSULATION TEST	≥ 5 MΩ @ 1000 Volt DC			
WELDS	W1-W2-W3 are in accordance with ASME Sec.VIII And Sec IX			
NDT TEST	Butt welds W1-W2 are in accordance with ASME Sec V : RT			
	Closure weld W3 is in accordance with ASME Sec.VIII : PT / MT			
MATERIAL CERTIFICATION	EN 10204 - 3.1 (EN 10204 - 3.2 if requested)			
INSPECTION & TEST/ACCEPTANCE	Manufacturer Standard / Customer Applicable Requirements			
CORROSION ALLOWANCE	Standard 1.6 mm / As per Customer Requirements			
SERVICE	Gas, Hydrocarbo	ns, Oil, Chemical Fluids, Wa	ater,Toxic, etc.	

- 1) Uncoated pipe length is 50 mm at each end for welding.
- 2) All pressure materials are suitable for resistance to $\mathrm{H}_2\mathrm{S}$ environments.
- 3) This information is approximate. The exact data shall be specified during the PO Stage.
- 4) Material not in contact to the fluid
 5) Cables Lugs will be installed on Isolating Joint only if requested.

INSULATING JOINT DATA SHEET 6" ANSI #600

QTY:2




ITEM DESCRIPTION		DESCRIPTION		
TYPE	INSULATING JOIL	INSULATING JOINTS, Monolithic		
DESIGN CODE	ASME B 31.1 - ASME B 31.3 - ASME B 31.4 - ASME B 31.8 - ASME VIII Div.I Appx.2			
DESIGN PRESSURE (barg)	100			
TEST PRESSURE (barg)	150			
DESIGN TEMPERATURE (°C)	-20 / +70 °C			
RATING (ASME/ANSI#) Class	CL600			
ENDS	BUTT WELDED -	API 5L / B16.25 / B16.5		
DESIGN FACTOR	According to pro	ject datas (standard is 0.6)		
CONNECTION PIPE DN "C" (mm/in.)	168,3 / 6"			
CONNECTION PIPE THK "t" (mm)	7,11			
JOINT OVERALL LENGTH "A"(mm)	600			
MATERIAL	"D" PIPES (API	5L or equivalent)	API 5L - Gr. X52	
	"F-O-P" Body Pa	arts	ASTM A694 F52	
	"G" O Ring Doub	le Seal Gasket System	ASTM D 2000 Nbr / Viton	
	"E" Insulating Fil	ling Material	Epoxy Resin	
	"R" Isolating Rin	g	D 709 G10 / G11	
	EXT External Coa	iting	Solvetless Epoxy Paint 3000 μm	
	INT Internal Coa	ting	Solvetless Epoxy Paint 500 μm	
INSTALLATION	ABOVEGROUND	ABOVEGROUND / UNDERGROUND / SUBSEA		
PNEUMATIC TEST	8 bar for 10 min	8 bar for 10 min		
HYDROSTATIC TEST	1.5 Times the Design Pressure - 1 hour (Or as per Customer Requirements)			
HYDRO FATIGUE TEST	5 cycles at 80% test pressure			
DIELECTRIC TEST	3 KV @ 1 minute AC 50÷60 Hz (25°C dry air)			
ELECTRIC INSULATION TEST	≥5 MΩ @ 1000 Volt DC			
WELDS	W1-W2-W3 are in accordance with ASME Sec.VIII And Sec IX			
NDT TEST	Butt welds W1-W2 are in accordance with ASME Sec V : RT Closure weld W3 is in accordance with ASME Sec.VIII : PT / MT			
MATERIAL CERTIFICATION	EN 10204 - 3.1 (EN 10204 - 3.2 if requested)			
INSPECTION & TEST/ACCEPTANCE	Manufacturer Standard / Customer Applicable Requirements			
CORROSION ALLOWANCE	Standard 1.6 mm / As per Customer Requirements			
SERVICE	Gas, Hydrocarbons, Oil, Chemical Fluids, Water,Toxic, etc.			
General notes :	•			

- 1) Uncoated pipe length is 50 mm at each end for welding.
- 2) All pressure materials are suitable for resistance to $\mathrm{H}_2\mathrm{S}$ environments.
- 3) This information is approximate. The exact data shall be specified during the PO Stage.
- 4) Material not in contact to the fluid
 5) Cables Lugs will be installed on Isolating Joint only if requested.

INSULATING JOINT DATA SHEET 8" ANSI #600

QTY:2



ITEM		DESCRIPTION		
TYPE	INSULATING JOINTS, Monolithic			
DESIGN CODE	ASME B 31.1 - ASME B 31.3 - ASME B 31.4 - ASME B 31.8 - ASME VIII Div.I Appx.2			
DESIGN PRESSURE (barg)	100			
TEST PRESSURE (barg)	150			
DESIGN TEMPERATURE (°C)	-20 / +70 °C			
RATING (ASME/ANSI#) Class	CL600			
ENDS	BUTT WELDED -	API 5L / B16.25 / B16.5		
DESIGN FACTOR	According to project datas (standard is 0.6)			
CONNECTION PIPE DN "C" (mm/in.)	219,1 / 8"			
CONNECTION PIPE THK "t" (mm)	10,31			
JOINT OVERALL LENGTH "A"(mm)	600			
MATERIAL	"D" PIPES (API	5L or equivalent)	API 5L - Gr. X52	
	"F-O-P" Body Parts		ASTM A694 F52	
	"G" O Ring Double Seal Gasket System		ASTM D 2000 Nbr / Viton	
	"E" Insulating Filling Material		Epoxy Resin	
	"R" Isolating Ring		D 709 G10 / G11	
	EXT External Coating		Solvetless Epoxy Paint 3000 μm	
	INT Internal Coat	ting	Solvetless Epoxy Paint 500 μm	
INSTALLATION	ABOVEGROUND / UNDERGROUND / SUBSEA			
PNEUMATIC TEST	8 bar for 10 min			
HYDROSTATIC TEST	1.5 Times the Design Pressure - 1 hour (Or as per Customer Requirements)			
HYDRO FATIGUE TEST	5 cycles at 80% test pressure			
DIELECTRIC TEST	3 KV @ 1 minute AC 50÷60 Hz (25°C dry air)			
ELECTRIC INSULATION TEST	≥5 MΩ @ 1000 Volt DC			
WELDS	W1-W2-W3 are in accordance with ASME Sec.VIII And Sec IX			
NDT TEST	Butt welds W1-W2 are in accordance with ASME Sec V: RT			
	Closure weld W3 is in accordance with ASME Sec.VIII : PT / MT			
MATERIAL CERTIFICATION	EN 10204 - 3.1 (EN 10204 - 3.2 if requested)			
INSPECTION & TEST/ACCEPTANCE	Manufacturer Standard / Customer Applicable Requirements			
CORROSION ALLOWANCE	Standard 1.6 mm / As per Customer Requirements			
SERVICE	Gas, Hydrocarbons, Oil, Chemical Fluids, Water, Toxic, etc.			
General notes :				

- 1) Uncoated pipe length is 50 mm at each end for welding.
- 2) All pressure materials are suitable for resistance to $\mathrm{H}_2\mathrm{S}$ environments.
- 3) This information is approximate. The exact data shall be specified during the PO Stage.
- 4) Material not in contact to the fluid
 5) Cables Lugs will be installed on Isolating Joint only if requested.

700 (D) F (G) EXT 14,27 323,9 395 (INT) 277,5 145 277,5

QTY:4

INSULATING JOINT DATA SHEET 12" ANSI #150

ITEM DESCRIPTION		DESCRIPTION		
ТҮРЕ	INSULATING JOI	INSULATING JOINTS, Monolithic		
DESIGN CODE	ASME B 31.1 - A'	ASME B 31.1 - ASME B 31.3 - ASME B 31.4 - ASME B 31.8 - ASME VIII Div.I Appx.2		
DESIGN PRESSURE (barg)	25			
TEST PRESSURE (barg)	37,5	37,5		
DESIGN TEMPERATURE (°C)	-20 / +70 °C	· ·		
RATING (ASME/ANSI#) Class	CL150	·		
ENDS	BUTT WELDED -	API 5L / B16.25 / B16.5		
DESIGN FACTOR	According to pro	oject datas (standard is 0.6)		
CONNECTION PIPE DN "C" (mm/in.)	323,9 / 12"			
CONNECTION PIPE THK "t" (mm)	14,27			
JOINT OVERALL LENGTH "A"(mm)	700			
MATERIAL		5L or equivalent)	API 5L - Gr. X52	
	"F-O-P" Body Pa	arts	ASTM A694 F52	
	"G" O Ring Doub	ole Seal Gasket System	ASTM D 2000 Nbr / Viton	
	"E" Insulating Fil	lling Material	Epoxy Resin	
.["R" Isolating Ring		D 709 G10 / G11	
.	EXT External Coa	ating	Solvetless Epoxy Paint 3000 μm	
	INT Internal Coat	U	Solvetless Epoxy Paint 500 μm	
INSTALLATION	ABOVEGROUND	ABOVEGROUND / UNDERGROUND / SUBSEA		
PNEUMATIC TEST	8 bar for 10 min	8 bar for 10 min		
HYDROSTATIC TEST	1.5 Times the De	1.5 Times the Design Pressure - 1 hour (Or as per Customer Requirements)		
HYDRO FATIGUE TEST	5 cycles at 80% t	5 cycles at 80% test pressure		
DIELECTRIC TEST	3 KV @ 1 minute	3 KV @ 1 minute AC 50÷60 Hz (25°C dry air)		
ELECTRIC INSULATION TEST	≥ 5 MΩ @ 1000	≥5 MΩ @ 1000 Volt DC		
WELDS	W1-W2-W3 are	W1-W2-W3 are in accordance with ASME Sec.VIII And Sec IX		
NDT TEST	Butt welds W1-\	Butt welds W1-W2 are in accordance with ASME Sec V: RT		
	Closure weld Wa	3 is in accordance with ASM	IE Sec.VIII : PT / MT	
MATERIAL CERTIFICATION	EN 10204 - 3.1 (EN 10204 - 3.2 if requested)			
INSPECTION & TEST/ACCEPTANCE	Manufacturer Standard / Customer Applicable Requirements			
CORROSION ALLOWANCE	Standard 1.6 mr	Standard 1.6 mm / As per Customer Requirements		
SERVICE	Gas, Hydrocarbo	ons, Oil, Chemical Fluids, Wa	ater,Toxic, etc.	
General notes :				

- 1) Uncoated pipe length is 50 mm at each end for welding.
- 2) All pressure materials are suitable for resistance to $\rm H_2 S$ environments.
- 3) This information is approximate. The exact data shall be specified during the PO Stage.
- 4) Material not in contact to the fluid
 5) Cables Lugs will be installed on Isolating Joint only if requested.