



Product Service

Attestation of Conformity

No. D6 001466 0005 Rev. 00

Holder of Attestation: Zhejiang Taifu Pump Co.,Ltd

Southeast Industrial Zone Songmen Town
317511 Wenling City, Zhejiang
PEOPLE'S REPUBLIC OF CHINA

Product: Circular Pumps
Circulation pump

Model(s): STAR65/15F, RGN 65FX

Parameters:

Rated voltage:	230VAC
Rated frequency:	50/60Hz
Rated input power:	1300W
Protection class:	I
Degree of protection:	IP 42
Rated Head:	9.0m
Rated Flow:	30.0m ³ /h
Declared EEI:	Less than 0.23

Implementation Measure EC Regulation
No 641/2009:22.07.2009
amended by (EC) 622/2012:11.07.2012, (EU) 2016/2282:2016-11-30
Stage 2 (01 Aug. 2015)

Tested according to: PPP 11093D:2017
EN 16297-1:2012
EN 16297-2:2012
EN 16297-3:2012

This Attestation of Conformity is issued on a voluntary basis and confirms that the listed product fulfils the generic ecodesign requirements as stated in Annex I in combination with the specific ecodesign requirements defined in the above mentioned Implementation Measure and as stated in Annex II of Council Directive 2009/125/EC for the setting of ecodesign requirements for energy-related products. This attestation refers only to the sample submitted to TÜV SÜD PRODUCT SERVICE GMBH for testing and evaluation and to its technical documentation. See also notes overleaf.

Test report no.: 7040118124401-03

Date, 2019-01-16

(Lucy Lu)