



**LABORATOR DE ANALIZE SI INCERCARI IN ACTIVITATEA DE
CONSTRUCTII - AXA CERT S.R.L.**

Autorizat ISC sub nr. 3782/21

Ferestre, usi, fatade cortina, EVI-uri, geam securizat, geam laminat,
termosistem ETICS, reactie la foc



Anexa 3 la certificatul nr. 3067-CPF -22

FERESTRE SI USI EXTERIOARE PENTRU PIETONI sistem VIVA seria TBO 70 (ferestre si usi de exterior fabricate din profile de Aluminiu cu rupere termica, compuse din unul, doua sau mai multe canate compartimentate prin montanti fiksi si/sau mobili echipate cu geam termoizolant) -vezi DoP 003/2022

Caracteristici de performanță	Clasă performanță	Rapoarte/ Autoritate emitenta/	Standarde de incercare/clasificare
Rezistenta la incarcare din vant	C3	3055/2022-AXA CERT	SR EN 12211:2016 SR EN 12210:2016
Etansietate la apa - neprotejata	3A	3055/2022-AXA CERT	SR EN 1027:2016 SR EN 12208:2001
Permeabilitate la aer	4	3055/2022-AXA CERT	SR EN 1026:2016 SR EN 12207:2016
Performanta acustica* Rw (C ;Ctr)	32 dB (-1 ; -5)	Determinare/ SR EN 14351-1+A2:2016	Determinare/ SR EN 14351-1+A2:2016 SR EN ISO 140-3:1998 SR EN ISO 717-1:2000 SR EN ISO 717-1:2000
Transmitanta termica*	1,4 W/m²K	Determinare/ SR EN 14351-1+A2:2016	Determinare/ SR EN 10077-1:2018 SR EN ISO 12567-1:2011/AC:2011

*Functie de geamul termoizolant folosit

Autoritate emitenta: AXA CERT SRL (Laborator Grad I), Tancabesti, jud. Ilfov,
Autorizatie ISC nr. 3782/21

Data emiterii
19.09.2022

DIRECTOR,

Aud. Mincu Eduard

