



## DICHIARAZIONE DI CONFORMITÀ

La ditta **RBM S.p.A.**,  
produttrice di componenti per impianti idrotermici, con sede a S.Giovanni di Polaveno  
Via Industriale 23 (BS) Italia

### DICHIARA CHE:

Le valvole termostatiche, codice: **31.XX.XX - 32.XX.XX - 48.XX.XX - 49.XX.XX - 2494.XX.XX - 2495.XX.XX - 2496.XX.XX - 2497.XX.XX**,  
abbinata alle Teste termostatiche, serie **305 (TL8) - 590 (TL10) - 590.00.00 (TL20) - 720 (TL30) - 2633 (TL70) - 2634**;

Le valvole termostatiche, serie **1564.XX.XX - 1979.XX.XX**,  
abbinata alle Teste termostatiche, serie: **305 (TL8) - 590 (TL10) - 590.00.00 (TL20) - 720 (TL30) - 2633 (TL70) - 2634 - 3614**;

Le valvole termostatiche, serie **2640.XX.XX - 2641.XX.XX - 2642.XX.XX - 2643.XX.XX**,  
abbinata alle Teste termostatiche, serie: **305 (TL8), 590 (TL10), 590.00.00 (TL20), 720 (TL30), 2633 (TL70) e 2634**;

Le valvole termostatiche, serie **31.XX.XX - 32.XX.XX - 48.XX.XX - 49.XX.XX - 2494.XX.XX - 2495.XX.XX - 2496.XX.XX - 2497.XX.XX - 2640.XX.XX - 2641.XX.XX - 2642.XX.XX - 2643.XX.XX**,  
abbinata alla Testa termostatica, serie: **3087 (TL10W)**;

Le valvole termostatiche, serie **31.XX.XX - 32.XX.XX - 48.XX.XX - 49.XX.XX**  
abbinata alle Testa termostatica, serie: **3614**;

I Kit termostatici (\*), codici: **1342.XX.XX - 1343.XX.XX - 2078.XX.XX - 2079.XX.XX - 2817.XX.XX - 2818.XX.XX - 2819.XX.XX - 2820.XX.XX - 2821.XX.XX - 2822.XX.XX - 2823.XX.XX - 2824.XX.XX**;

I Kit termostatici (\*), codici: **1344.XX.XX - 1345.XX.XX - 2080.XX.XX - 2081.XX.XX**,  
abbinata alle Teste termostatiche, serie **305 (TL8), 590 (TL10), 720 (TL30), 2633 (TL70) e 2634**;

(\* ) *La certificazione è riferita alla sola Valvola termostatica facente parte del Kit, per il relativo certificato fare riferimento al singolo codice prodotto ed alla Testa a cui viene abbinata.*



## DICHIARAZIONE DI CONFORMITÀ

Sono realizzati a regola d'arte secondo le prescrizioni tecniche della norma **UNI EN 215** "Valvole termostatiche per radiatori – Requisiti e metodi di prova".

Hanno ottenuto la certificazione, in accordo al **CEN Keymark scheme rules for thermostatic radiator valves**, ed inteficate dal "licensee identity number" n°43.

Le Teste termostatiche RBM hanno ottenuto la certificazione Thermostatic Efficiency Label (**TELL**).

Le valvole termostatiche RBM sono da ritenersi a bassa inerzia termica in quanto il tempo di risposta (determinato in conformità al punto 6.4.1.13 della norma UNI EN 215) è inferiore a 40 minuti, quindi rispondono a quanto previsto dal Decreto del Ministero dell'Economia e delle Finanze del 19 febbraio 2007 recante: "Disposizioni in materia di detrazioni per le spese di riqualificazione energetica del patrimonio edilizio esistente, ai sensi dell'articolo 1, comma 349, della legge 27 dicembre 2006, n. 296. articolo 9 - 1/b".

Lo stesso decreto è richiamato anche nell'Art.1 del Decreto MISE 06/08/2020 "Requisiti tecnici per l'accesso alle detrazioni fiscali per la riqualificazione energetica degli edifici" e, per tale motivo, la presente dichiarazione di conformità può essere assunta in ottemperanza a quanto riportato all'Art.6 del Decreto MISE 06/08/2020.

RBM S.p.A.

Nave (BS), 01/03/2023

(firma):



## DECLARATION OF COMFORMITY

The company **RBM S.p.A.**,  
manufacturer of components for hydrothermal systems, with head office at S.Giovanni di Polaveno  
Via Industriale 23 (BS) Italy

### HEREBLY DECLARES:

The Thermostatic valves, codes: **31.XX.XX - 32.XX.XX - 48.XX.XX - 49.XX.XX - 2494.XX.XX - 2495.XX.XX - 2496.XX.XX - 2497.XX.XX**,  
coupled with the Thermostatic heads, series **305 (TL8) - 590 (TL10) - 590.00.00 (TL20) - 720 (TL30) - 2633 (TL70) - 2634**;

-  
The Thermostatic valves, codes: **1564.XX.XX - 1979.XX.XX**,  
coupled with the Thermostatic heads, series: **305 (TL8) - 590 (TL10) - 590.00.00 (TL20) - 720 (TL30) - 2633 (TL70) - 2634 - 3614**;

-  
The Thermostatic valves, codes: **2640.XX.XX - 2641.XX.XX - 2642.XX.XX - 2643.XX.XX**,  
coupled with the Thermostatic heads, series: **305 (TL8), 590 (TL10), 590.00.00 (TL20), 720 (TL30), 2633 (TL70) e 2634**;

-  
The Thermostatic valves, codes: **31.XX.XX - 32.XX.XX - 48.XX.XX - 49.XX.XX - 2494.XX.XX - 2495.XX.XX - 2496.XX.XX - 2497.XX.XX - 2640.XX.XX - 2641.XX.XX - 2642.XX.XX - 2643.XX.XX**,  
coupled with the Thermostatic head, series: **3087 (TL10W)**;

-  
The Thermostatic valves, codes: **31.XX.XX - 32.XX.XX - 48.XX.XX - 49.XX.XX**  
coupled with the Thermostatic head, series: **3614**;

-  
The thermostatic KIT (\*), codes: **1342.XX.XX - 1343.XX.XX - 2078.XX.XX - 2079.XX.XX - 2817.XX.XX - 2818.XX.XX - 2819.XX.XX - 2820.XX.XX - 2821.XX.XX - 2822.XX.XX - 2823.XX.XX - 2824.XX.XX**;

-  
I The thermostatic KIT (\*), codes: **1344.XX.XX - 1345.XX.XX - 2080.XX.XX - 2081.XX.XX**,  
abbinata alle Teste termostatiche, serie **305 (TL8), 590 (TL10), 720 (TL30), 2633 (TL70) e 2634**;

(\* ) *The certification is referred to the single thermostatic valve that is part of the KIT, for the relevant certificate refer to the individual product code.*



## DECLARATION OF COMFORMITY

Are manufactured in accordance with the technical requirements of standard **UNI EN 215** "Thermostatic radiator valves. Requirements and test methods".

Are certified according to **CEN Keymark scheme rules for thermostatic radiator valves** and identified by "Licensee identity number" n°**43**.

RBM Thermostatic heads have obtained the Thermostatic Efficiency Label (**TELL**).

RBM Thermostatic valves are to be considered low thermal inertia as the response time (determined in compliance with point 6.4.1.13 of the UNI EN 215 standard) is less than 40 minutes, therefore they comply with the provisions of the Decree of the Ministry of Economy and Finance of 19 February 2007 concerning: "*Provisions on deductions for expenses for energy requalification of the existing building stock, pursuant to article 1, paragraph 349, of law no. 296 of 27 December 2006. article 9 -1/b*".

The same decree is also referred to in Art.1 of the MISE Decree 06/08/2020 "*Technical requirements for access to tax deductions for the energy requalification of buildings*" and, for this reason, this declaration of conformity can be taken in compliance with Art.6 of the MISE Decree 06/08/2020.

RBM S.p.A.

Nave (BS), 01/03/2023

(signature):