



Letter of Attestation

Document: 80162024

Master Contract: 303380

Project: 80162024

Date Issued: 2023-06-28

Issued to: Shenzhen SOFARSOLAR Co., Ltd.
11/F., Gaoxinqi Technology Building,
No.67 Area, Xingdong Community,
Xin'an Sub-district, Bao'an District,
Shenzhen, Guangdong 518100
China

*CSA Group hereby confirms that it has completed an evaluation of:
Grid Support Utility Interactive Inverter with PV input, model SOFAR 25KTLX-G3, SOFAR 30KTLX-G3,
SOFAR 30KTLX-G3-A, SOFAR 33KTLX-G3, SOFAR 36KTLX-G3, SOFAR 40KTLX-G3, SOFAR 45KTLX-G3,
SOFAR 50KTLX-G3, SOFAR 40KTLX-G3-HV and SOFAR 50KTLX-G3-HV.*

*CSA Group hereby attests that the products identified above and described
in test report 80162024 dated June 28, 2023
complies with the following standards/tests, to the extent applicable:*

UL 1699B - Photovoltaic (PV) DC Arc-Fault Circuit Protection (First Edition, Dated August 22, 2018)

Issued by: Henry Huan Henry Huan

CSA Group

The applicable tests performed as following:

Standard	Clause	Requirement	Remark
UL 1699B-2018	28	Environmental Test Sequence	Pass
UL 1699B-2018	29	Arc Fault Detection Tests	Pass

Note:

- 1. The test sequence is selected by the customer and only the conclusion criteria used is Standard UL 1699B-2018.*
- 2. Typical test model selected Model SOFAR 50KTLX-G3-HV and SOFAR 36KTLX-G3, Other models have the same circuit structure, but the power is different.*



Document: 80162024

Master Contract: 303380

Project: 80162024

Date: 2023-06-28

3. For details related to rating, size, configuration, etc., reference to CSA TIS report 80162024.

THIS LETTER OF ATTESTATION DOES NOT AUTHORIZE THE USE OF THE CSA MARK ON THE SUBJECT PRODUCTS.

QUOTATIONS FROM THE TEST REPORT OR THE USE OF THE NAME CSA GROUP OR ITS REGISTERED TRADEMARK, IN ANY WAY, IS NOT PERMITTED WITHOUT PRIOR WRITTEN CONSENT OF CSA GROUP TESTING & CERTIFICATION INC.