

We declare under our sole responsibility that the product

Product: Rotary Gas Meter
Type: FMR G160 DN80 PN 16
Serial No / Year: R000064771 / 2021

is designed and manufactured in conformity with the following EU Directives:

1 2014/32/EU (Measuring Instruments Directive)

Module B with EU type examination certificate: **T10372-MID**
Module D supervised by:
NMI CERTIN B.V. ; notified body number 0122
Thijsseweg 11
2629 JD Delft NL
Harmonised standard : OIML R137-1&2:2012

2 2014/68/EU (Pressure Equipment Directive)

Module B with EU type examination certificate: **CE-PED-B-6410121-01-16-NLD-rev00**
Module D with EU certificate of conformity: **0343/PED/RQA655610**
Module D supervised by:
Lloyd's Register Nederland B.V. ; notified body number 0343
K.P. Van Der Mandelelaan 41 A
3062 MB Rotterdam
Harmonised standard : EN13445:2009

3 2014/34/EU (ATEX Directive)

Marking:  **II 2 G**
Mechanical gasmeter: Annex VIII: Cert No RET0249259 by LRV Notified Body Number 0038
II 2 G Ex c IIC T4..T6 Gb (-40°C ≤ Ta ≤ +70°C)
Standards:
EN 13463-1:2009, EN 13463-5:2011

With content of :

Sensor Assembly: Type 3711 MSR Module B EC type examination certificate / Marking sensor assembly:
BASEEFA 11ATEX0280X II 2 G Ex ia IIC T4..T6 Gb (-40°C ≤ ta ≤ +70°C)

Conformity assessment notified body for Production Quality Assurance / Annex VII (Module: E) for
sensor types 37xx: CSANe 21ATEXM811
CSA Group Netherlands B.V. ; notified body number 2813
Standards:
EN 60079-0:2012, EN 60079-11:2012

4 2014/30/EU (Electro Magnetic Compatibility Directive)

The product fulfills the requirements of the directive as it meets with the following harmonized standards:
EN61000-6-2; EN61000-6-3:2007, EN60947-5-6:2000
The sensor types 3700, 3711 and 3740 fulfil the directive requirements for use in industrial environments.
Standards:
EN55011:2009+A1:2010, EN61000-3-2:2006+A1:2009+A2:2009, EN61000-3-3:2013, EN61000-6-2:2005
Attestation of conformity electromagnetic compatibility by:
DEKRA Certification B.V. ; Notified Body Number 0344

The object of the declaration described above is in conformity with the relevant Union harmonization legislation:

Directive 2004/22/EC (until April 19th, 2016) and Directive 2014/32/EU (from April 20th, 2016)
Directive 97/23/EC (until July 18th, 2016) and Directive 2014/68/EU (from July 19th, 2016)
Directive 94/9/EC (until April 19th, 2016) and Directive 2014/34/EU (from April 20th, 2016)
Directive 2004/108/EC (until April 19th, 2016) and Directive 2014/30/EU (from April 20th, 2016)

Doetinchem, 2021/03/18

Name: Frank Wieskamp
Position: CQO Flow Meter Group B.V.

Signature:

