



**LABORATOR DE ANALIZE SI INCERCARI IN ACTIVITATEA DE  
CONSTRUCTII - AXA CERT S.R.L.**

*Autorizat ISC sub nr. 3782/21*

Ferestre, usi, fatade cortina, EVI-uri, geam securizat, geam laminat,  
termosistem ETICS, reactie la foc



**Anexa 2 la certificatul nr. 3067-CPF -22**

**FERESTRE SI USI EXTERIOARE PENTRU PIETONI sistem WDS seria 7S** (ferestre si usi de exterior fabricate din profile de PVC, compuse din unul, doua sau mai multe canate compartimentate prin montanti fiksi si/sau mobili echipate cu geam termoizolant) -vezi DoP 002/2022

| Caracteristici de performanță        | Clasă performanță          | Rapoarte/ Autoritate emitenta/        | Standarde de incercare/clasificare                                                                            |
|--------------------------------------|----------------------------|---------------------------------------|---------------------------------------------------------------------------------------------------------------|
| Rezistenta la incarcare din vant     | <b>C4</b>                  | 3054/2022-AXA CERT                    | SR EN 12211:2016<br>SR EN 12210:2016                                                                          |
| Etansietate la apa - neprotejata     | <b>9A</b>                  | 3054/2022-AXA CERT                    | SR EN 1027:2016<br>SR EN 12208:2001                                                                           |
| Permeabilitate la aer                | <b>4</b>                   | 3054/2022-AXA CERT                    | SR EN 1026:2016<br>SR EN 12207:2016                                                                           |
| Performanta acustica*<br>Rw (C ;Ctr) | <b>32 dB<br/>(-1 ; -5)</b> | Determinare/<br>SR EN 14351-1+A2:2016 | Determinare/<br>SR EN 14351-1+A2:2016<br>SR EN ISO 140-3:1998<br>SR EN ISO 717-1:2000<br>SR EN ISO 717-1:2000 |
| Transmitanta termica*                | <b>1,3 W/m²K</b>           | Determinare/<br>SR EN 14351-1+A2:2016 | Determinare/<br>SR EN 10077-1:2018<br>SR EN ISO 12567-1:2011/AC:2011                                          |

\*Functie de geamul termoizolant folosit

Autoritate emitenta: AXA CERT SRL (Laborator Grad I), Tancabesti, jud. Ilfov,  
Autorizatie ISC nr. 3782/21

**Data emiterii**  
**19.09.2022**

**DIRECTOR,**

**Aud. Mincu Eduard**

