

HSP Hochspannungsgeräte GmbH • P.O. Box 3185 • 53831 Troisdorf • Germany



Phone: +49 (0) 22 41- 25 26- 0  
Fax: +49 (0) 22 41- 25 26- 116

E-mail: [contact@hspkoeln.de](mailto:contact@hspkoeln.de)  
[www.hspkoeln.de](http://www.hspkoeln.de)

HSP Hochspannungsgeräte GmbH  
Camp-Spich-Str. 18  
53842 Troisdorf-Spich  
Germany

Deutsche Bank Cologne  
BIC (SWIFT-Code): DEUTDE33HAN  
IBAN: DE69 3707 0060 0596 7831 00

Managing Directors:  
Matthias Baca, Georg von Rohr

Registered office: Troisdorf-Spich  
Local County Court Siegburg  
Reg.-No. HRB 9858

10.01.2022

### Certificate of Quality

HSP Order No.: 1313166 PO No.: 9500941502	
10) RIP CONDENSER BUSHING TRANSFORMER - OUTDOOR  <b>ETFT 1050-252-D E7,2 SPEZ.</b> SPEC. NO.: 351210	2 pcs  Serial No.: 301256 + 301257
30) RIP CONDENSER BUSHING TRANSFORMER - OUTDOOR  <b>ETFT 650-172-D E5 SPEZ.</b> SPEC. NO.: 337920	3 pcs  Serial No.: 301113 – 301115
60) RIP CONDENSER BUSHING TRANSFORMER - OUTDOOR  <b>ETFT 550-126-C E4 SPEZ.</b> SPEC. NO.: 324703	4 pcs  Serial No.: 301258 - 301261

We, HSP Hochspannungsgeräte GmbH, the manufacturer, certify that our manufactures are produced under permanent control according to the ISO 9001 and tested in our test laboratory which is released for tests to IEC standards and other standards deviated here from.

HSP has received the ISO 9001 certificate No. 00135 – QM 15 UM of the DQS valid until 17 November 2023.

We certify that the goods covered by this certificate, are with regards to quality according to our technical specifications and to our order acknowledgement.

#### HSP Hochspannungsgeräte GmbH

Vasilyev  
Alexei

Digital signiert von Vasilyev Alexei  
DN: cn=Vasilyev Alexei,  
o=Siemens,  
email=alexei.vasilyev@hspkoeln.de  
Datum: 2023.01.10 11:22:00  
+01'00'



Pioneering  
high voltage.

Digital signiert von  
Korosoglou Nina  
Datum: 2023.01.10  
10:51:08 +01'00'

Vasilyev

Korosoglou




## CANTILEVER LOAD WITHSTAND TEST

No.: 1310299-10-F Page 1/3

Test laboratory HSP Hochspannungsgeräte GmbH  
 HS-Prüflaboratorium, Camp-Spich-Str. 18 D-53842 Troisdorf

Customer HSP Hochspannungsgeräte GmbH  
 Camp-Spich-Str. 18 D-53842 Troisdorf

<b>Test Object:</b>	<b>RIP Condenser Bushing, Transformer – Outdoor</b>
Type	<b>STARIP® – Si+ 123 – 800 E0</b>
Specification	344120 (see last page)
Highest voltage for equipment	123 kV
Rated current	800 A
Serial number	<b>283352</b>



Begin of tests 09.12.2019  
 End of tests 15.12.2019  
 Test standard IEC 60137 (2017)  
 Test plan HSP 1310299/20 - TTP  
 Test equipment Documented in the laboratory test records

# HIGH VOLTAGE TEST LABORATORY

The equipment passed all indicated tests successfully.  
 The test results are valid for the tested equipment only.

Troisdorf 11.02.2020

HSP Hochspannungsgeräte GmbH  
**HS-Prüflaboratorium**  
  
 Camp-Spich-Straße 18  
 53842 Troisdorf GERMANY



*Haberecht*  
 i.A. Haberecht  
 Senior Test Engineer

*Adams*  
 i.A. Adams  
 Senior Test Engineer

## CANTILEVER LOAD WITHSTAND TEST

No.: 1310299-10-F Page 2/3

The following tests were executed successively:

50 Hz AC routine test before type test									Date of test: 09.12.2019						
U [kV]	10	36	75	107	129	160	230	255	230	160	129	107	75	36	10
C <sub>1</sub> [pF]	260	260	260	260	260	260	260	Test voltage 72 sec.	260	260	260	260	260	260	260
tan δ [%]	0.37	0.37	0.37	0.37	0.37	0.37	0.37	0.37	0.37	0.37	0.37	0.37	0.37	0.37	0.37
p.d. [pC]	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1


## CANTILEVER LOAD WITHSTAND TEST

Date of test: 10.12.2019

### Test setup:

The bushing was fixed in a steel frame at its flange in horizontal position.

Atmospheric conditions: 19 °C



### Specified test force:

3150 N perpendicular to the axis of the bushing at air terminal

### Distance between fixing- and force points:

Specified: 1470 mm

Applied: 1470 mm

### Test equipment:

6 weights 50 kg each, 1 weight 20 kg plus mass of the support

### Test:

F [N]

Duration [sec.]

3200

60

### Result of test:

Neither damage nor deformation of the bushing was visible.

## 50 Hz AC routine test after type test

Date of test: 15.12.2019

U [kV]	10	36	75	107	129	160	230	255	230	160	129	107	75	36	10
C <sub>1</sub> [pF]	259	259	259	259	259	259	259	Test voltage 72 sec.	259	259	259	259	259	259	259
tan δ [%]	0.38	0.38	0.38	0.38	0.38	0.38	0.38	0.38	0.38	0.38	0.38	0.38	0.38	0.38	0.38
p.d. [pC]	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1

Troisdorf 11.02.2020



## CANTILEVER LOAD WITHSTAND TEST

No.: 1310299-10-F Page 3/3

### Supplemental Information - Test Object Specification

		Spec. No.: <b>344120</b>																																									
Zng.:	Type: <b>STARIP-Si+ 123- 800 E0</b>	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 50%;">Repl. for issue: <b>20.12.2019</b></td> <td style="width: 50%;">Issue date: <b>10.01.2020</b></td> </tr> <tr> <td>Offer-No.:</td> <td>Order-No.:</td> </tr> </table>	Repl. for issue: <b>20.12.2019</b>	Issue date: <b>10.01.2020</b>	Offer-No.:	Order-No.:																																					
Repl. for issue: <b>20.12.2019</b>	Issue date: <b>10.01.2020</b>																																										
Offer-No.:	Order-No.:																																										
<b>Condenser graded bushing, Transformer-Outdoor, dry filling</b>																																											
<p style="font-size: small;">09.07.19 T/lid</p>	<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th colspan="2" style="text-align: left;">Technical Data</th> </tr> </thead> <tbody> <tr> <td>Rated highest voltage for Equipment Um, (50/60Hz) phase-phase:</td> <td style="text-align: right;">123.0 kV</td> </tr> <tr> <td>Rated phase-to-earth voltage:</td> <td style="text-align: right;">71 kV</td> </tr> <tr> <td>Partial discharge level at test voltage:</td> <td style="text-align: right;">≤ 4 pC</td> </tr> <tr> <td>Power-frequency withstand voltage 50Hz, 1.2 min. dry:</td> <td style="text-align: right;">255 kV</td> </tr> <tr> <td>Rated lightning impulse withstand voltage (BIL): 1.2/50µs</td> <td style="text-align: right;">550 kV</td> </tr> <tr> <td>Rated switching impulse withstand voltage (SIL): 250/2500µs</td> <td style="text-align: right;">0 kV</td> </tr> <tr> <td>Rated current:</td> <td style="text-align: right;">800 A</td> </tr> <tr> <td>Max. service current:</td> <td style="text-align: right;">800 A</td> </tr> <tr> <td>CT accommodation length:</td> <td style="text-align: right;">0 mm</td> </tr> <tr> <td>Flashover distance:</td> <td style="text-align: right;">1138 mm</td> </tr> <tr> <td>Creepage distance, min.:</td> <td style="text-align: right;">3906 mm</td> </tr> <tr> <td>Cantilever test load:</td> <td style="text-align: right;">3150 N</td> </tr> <tr> <td>Mounting position:</td> <td style="text-align: right;">0-90°</td> </tr> <tr> <td>Ambient temperature:</td> <td style="text-align: right;">-30...+40°C</td> </tr> <tr> <td>Temperature of transformer oil:</td> <td style="text-align: right;">max.100°C max. daily mean 90 °C</td> </tr> <tr> <td>Test tap - test voltage:</td> <td style="text-align: right;">2kV, 50Hz, 1.2min.</td> </tr> <tr> <td>Routine test according to</td> <td style="text-align: right;">IEC 60137-2017</td> </tr> <tr> <td>Mass, approx.:</td> <td style="text-align: right;">57 kg</td> </tr> <tr> <td colspan="2">Dry insulation foam is free of SF6</td> </tr> <tr> <td colspan="2"> <b>Remarks:</b>            - RIP (resin impregnated paper)            - Draw lead bolt, E-Cu, cable cross section 450mm<sup>2</sup> </td> </tr> </tbody> </table>	Technical Data		Rated highest voltage for Equipment Um, (50/60Hz) phase-phase:	123.0 kV	Rated phase-to-earth voltage:	71 kV	Partial discharge level at test voltage:	≤ 4 pC	Power-frequency withstand voltage 50Hz, 1.2 min. dry:	255 kV	Rated lightning impulse withstand voltage (BIL): 1.2/50µs	550 kV	Rated switching impulse withstand voltage (SIL): 250/2500µs	0 kV	Rated current:	800 A	Max. service current:	800 A	CT accommodation length:	0 mm	Flashover distance:	1138 mm	Creepage distance, min.:	3906 mm	Cantilever test load:	3150 N	Mounting position:	0-90°	Ambient temperature:	-30...+40°C	Temperature of transformer oil:	max.100°C max. daily mean 90 °C	Test tap - test voltage:	2kV, 50Hz, 1.2min.	Routine test according to	IEC 60137-2017	Mass, approx.:	57 kg	Dry insulation foam is free of SF6		<b>Remarks:</b> - RIP (resin impregnated paper) - Draw lead bolt, E-Cu, cable cross section 450mm <sup>2</sup>	
Technical Data																																											
Rated highest voltage for Equipment Um, (50/60Hz) phase-phase:	123.0 kV																																										
Rated phase-to-earth voltage:	71 kV																																										
Partial discharge level at test voltage:	≤ 4 pC																																										
Power-frequency withstand voltage 50Hz, 1.2 min. dry:	255 kV																																										
Rated lightning impulse withstand voltage (BIL): 1.2/50µs	550 kV																																										
Rated switching impulse withstand voltage (SIL): 250/2500µs	0 kV																																										
Rated current:	800 A																																										
Max. service current:	800 A																																										
CT accommodation length:	0 mm																																										
Flashover distance:	1138 mm																																										
Creepage distance, min.:	3906 mm																																										
Cantilever test load:	3150 N																																										
Mounting position:	0-90°																																										
Ambient temperature:	-30...+40°C																																										
Temperature of transformer oil:	max.100°C max. daily mean 90 °C																																										
Test tap - test voltage:	2kV, 50Hz, 1.2min.																																										
Routine test according to	IEC 60137-2017																																										
Mass, approx.:	57 kg																																										
Dry insulation foam is free of SF6																																											
<b>Remarks:</b> - RIP (resin impregnated paper) - Draw lead bolt, E-Cu, cable cross section 450mm <sup>2</sup>																																											

Rev.: 7534, 7556, 7562

Troisdorf 11.02.2020






Test laboratory HSP Hochspannungsgeräte GmbH  
 HS-Prüflaboratorium, Camp-Spich-Str. 18 D-53842 Troisdorf

Customer HSP Hochspannungsgeräte GmbH  
 Camp-Spich-Str. 18 D-53842 Troisdorf

<b>Test Object:</b>	<b>RIP Condenser Bushing, Transformer – Outdoor</b>
Type	<b>STARIP® – Si+ 123 – 800 E0</b>
Specification	344120 (see last page)
Highest voltage for equipment	123 kV
Rated current	800 A
Serial number	<b>283352</b>



Begin of tests 09.12.2019  
 End of tests 15.12.2019  
 Test standards IEC 60137 (2017) and 60060-1 (2010)  
 Test plan HSP 1310299/20 - TTP  
 Test equipment Documented in the laboratory test records

## HIGH VOLTAGE TEST LABORATORY

The equipment passed all indicated tests successfully.  
 The test results are valid for the tested equipment only.

Troisdorf 11.02.2020


HSP Hochspannungsgeräte GmbH  
**HS-Prüflaboratorium**  
  
 Camp-Spich-Straße 18  
 53842 Troisdorf GERMANY



*Haberecht*  
 i.A. Haberecht  
 Senior Test Engineer

*Adams*  
 i.A. Adams  
 Senior Test Engineer

## Basic Circuits & Principal Test Setup



Troisdorf 11.02.2020

## DRY LIGHTNING IMPULSE VOLTAGE WITHSTAND TEST No.: 1310299-10-H Page 3/15

The following tests were executed successively:

50 Hz AC routine test before type test													Date of test: 09.12.2019			
U [kV]	10	36	75	107	129	160	230	255	230	160	129	107	75	36	10	
C <sub>1</sub> [pF]	260	260	260	260	260	260	260	Test voltage	260	260	260	260	260	260	260	
tan δ [%]	0.37	0.37	0.37	0.37	0.37	0.37	0.37	72 sec.	0.37	0.37	0.37	0.37	0.37	0.37	0.37	
p.d. [pC]	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	

## DRY LIGHTNING IMPULSE VOLTAGE WITHSTAND TEST Date of test: 13.12.2019

### Test setup:

The bushing was mounted on a solidly grounded test vessel filled with oil. The effective test vessel diameter was reduced by an inserted grounded aluminium cylinder Ø 340 mm x 710 mm. The test object was connected to the impulse generator and to the measuring divider by wires.

### Atmospheric conditions:

Temperature: 20 °C  
 Air pressure: 974 hPa  
 Relative humidity: 39 %  
 Correction factor: 0.96 (not applied)

Wave shape: 1.2 µs / 50 µs

Specified test voltage: 550 kV full wave



### Test:

Level [%]	U [kV]	quantity	figure	comment
80	+ 440	1	1	calibration impulse
100	+ 550	15	2-16	test impulses full wave
80	- 440	1	17	calibration impulse
110	- 605	1	18	test impulse full wave
121	- 666	5	19-28	test impulses chopped wave
110	- 605	14	29-42	test impulses full wave

### Result of test:

During the test no flashover has occurred. See oscillograms on the next pages.

50 Hz AC routine test after type test													Date of test: 15.12.2019			
U [kV]	10	36	75	107	129	160	230	255	230	160	129	107	75	36	10	
C <sub>1</sub> [pF]	259	259	259	259	259	259	259	Test voltage	259	259	259	259	259	259	259	
tan δ [%]	0.38	0.38	0.38	0.38	0.38	0.38	0.38	72 sec.	0.38	0.38	0.38	0.38	0.38	0.38	0.38	
p.d. [pC]	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	

Troisdorf 11.02.2020




Fig. 1

calibration impulse

Ut = 441.9 kV  
 T1 = 1.365 µs  
 T2 = 49.30 µs  
 $\beta' = -1.346 \%$




Fig. 2

test impulse  
 full wave

Ut = 550.9 kV  
 T1 = 1.366 µs  
 T2 = 49.49 µs  
 $\beta' = -1.476 \%$




Fig. 3

test impulse  
 full wave

Ut = 551.1 kV  
 T1 = 1.369 µs  
 T2 = 49.51 µs  
 $\beta' = -1.464 \%$




Fig. 4

test impulse  
 full wave

Ut = 550.9 kV  
 T1 = 1.369 µs  
 T2 = 49.51 µs  
 $\beta' = -1.475 \%$

Troisdorf 11.02.2020






Fig. 5

test impulse  
full wave

Ut = 550.6 kV  
 T1 = 1.364 µs  
 T2 = 49.54 µs  
 $\beta'$  = -1.535 %




Fig. 6

test impulse  
full wave

Ut = 550.5 kV  
 T1 = 1.369 µs  
 T2 = 49.52 µs  
 $\beta'$  = -1.470 %




Fig. 7

test impulse  
full wave

Ut = 550.5 kV  
 T1 = 1.368 µs  
 T2 = 49.50 µs  
 $\beta'$  = -1.507 %




Fig. 8

test impulse  
full wave

Ut = 550.5 kV  
 T1 = 1.366 µs  
 T2 = 49.54 µs  
 $\beta'$  = -1.482 %

Troisdorf 11.02.2020




Fig. 9

test impulse  
full wave

$U_t = 550.2 \text{ kV}$   
 $T_1 = 1.366 \text{ µs}$   
 $T_2 = 49.54 \text{ µs}$   
 $\beta' = -1.507 \%$




Fig. 10

test impulse  
full wave

$U_t = 550.4 \text{ kV}$   
 $T_1 = 1.365 \text{ µs}$   
 $T_2 = 49.54 \text{ µs}$   
 $\beta' = -1.507 \%$




Fig. 11

test impulse  
full wave

$U_t = 550.2 \text{ kV}$   
 $T_1 = 1.366 \text{ µs}$   
 $T_2 = 49.59 \text{ µs}$   
 $\beta' = -1.511 \%$




Fig. 12

test impulse  
full wave

$U_t = 550.3 \text{ kV}$   
 $T_1 = 1.364 \text{ µs}$   
 $T_2 = 49.57 \text{ µs}$   
 $\beta' = -1.454 \%$

Troisdorf 11.02.2020




Fig. 13

test impulse  
full wave

Ut = 550.3 kV  
 T1 = 1.367 µs  
 T2 = 49.58 µs  
 $\beta' = -1.495 \%$




Fig. 14

test impulse  
full wave

Ut = 550.3 kV  
 T1 = 1.367 µs  
 T2 = 49.56 µs  
 $\beta' = -1.478 \%$




Fig. 15

test impulse  
full wave

Ut = 550.1 kV  
 T1 = 1.366 µs  
 T2 = 49.56 µs  
 $\beta' = -1.518 \%$




Fig. 16

test impulse  
full wave

Ut = 550.5 kV  
 T1 = 1.368 µs  
 T2 = 49.55 µs  
 $\beta' = -1.420 \%$

Troisdorf 11.02.2020




Fig. 17  
 calibration impulse

$U_t = -439.9 \text{ kV}$   
 $T_1 = 1.316 \text{ μs}$   
 $T_2 = 49.35 \text{ μs}$   
 $\beta' = -1.434 \%$




Fig. 18  
 test impulse  
 full wave

$U_t = -605.6 \text{ kV}$   
 $T_1 = 1.328 \text{ μs}$   
 $T_2 = 49.52 \text{ μs}$   
 $\beta' = -1.464 \%$




Fig. 19  
 test impulse  
 chopped wave

$U_t = -667.9 \text{ kV}$   
 $T_1 = 1.296 \text{ μs}$   
 $T_c = 3.491 \text{ μs}$






Fig. 20  
 test impulse  
 chopped wave

$U_t = -667.9 \text{ kV}$   
 $T_1 = 1.296 \text{ μs}$   
 $T_c = 3.491 \text{ μs}$


Troisdorf 11.02.2020




**Fig. 21**  
 test impulse  
 chopped wave  
 Ut = -668.3 kV  
 T1 = 1.298 µs  
 Tc = 3.319 µs



**Fig. 22**  
 test impulse  
 chopped wave  
 Ut = -668.3 kV  
 T1 = 1.298 µs  
 Tc = 3.319 µs



**Fig. 23**  
 test impulse  
 chopped wave  
 Ut = -668.3 kV  
 T1 = 1.302 µs  
 Tc = 4.368 µs



**Fig. 24**  
 test impulse  
 chopped wave  
 Ut = -668.3 kV  
 T1 = 1.302 µs  
 Tc = 4.368 µs

Troisdorf 11.02.2020




Fig. 25

test impulse  
 chopped wave

$U_t = -668.2 \text{ kV}$   
 $T_1 = 1.301 \text{ μs}$   
 $T_c = 3.933 \text{ μs}$




Fig. 26

test impulse  
 chopped wave

$U_t = -668.2 \text{ kV}$   
 $T_1 = 1.301 \text{ μs}$   
 $T_c = 3.933 \text{ μs}$




Fig. 27

test impulse  
 chopped wave

$U_t = -668.1 \text{ kV}$   
 $T_1 = 1.299 \text{ μs}$   
 $T_c = 3.842 \text{ μs}$




Fig. 28

test impulse  
 chopped wave

$U_t = -668.1 \text{ kV}$   
 $T_1 = 1.299 \text{ μs}$   
 $T_c = 3.842 \text{ μs}$




Fig. 29

test impulse  
full wave

$U_t = -606.1 \text{ kV}$   
 $T_1 = 1.331 \text{ µs}$   
 $T_2 = 49.47 \text{ µs}$   
 $\beta' = -1.452 \%$




Fig. 30

test impulse  
full wave

$U_t = -606.0 \text{ kV}$   
 $T_1 = 1.329 \text{ µs}$   
 $T_2 = 49.45 \text{ µs}$   
 $\beta' = -1.459 \%$




Fig. 31

test impulse  
full wave

$U_t = -605.7 \text{ kV}$   
 $T_1 = 1.328 \text{ µs}$   
 $T_2 = 49.47 \text{ µs}$   
 $\beta' = -1.480 \%$




Fig. 32

test impulse  
full wave

$U_t = -605.8 \text{ kV}$   
 $T_1 = 1.332 \text{ µs}$   
 $T_2 = 49.47 \text{ µs}$   
 $\beta' = -1.423 \%$

Troisdorf 11.02.2020




Fig. 33

test impulse  
full wave

$U_t = -605.8 \text{ kV}$   
 $T_1 = 1.331 \text{ µs}$   
 $T_2 = 49.48 \text{ µs}$   
 $\beta' = -1.452 \%$




Fig. 34

test impulse  
full wave

$U_t = -605.9 \text{ kV}$   
 $T_1 = 1.335 \text{ µs}$   
 $T_2 = 49.47 \text{ µs}$   
 $\beta' = -1.471 \%$




Fig. 35

test impulse  
full wave

$U_t = -605.9 \text{ kV}$   
 $T_1 = 1.330 \text{ µs}$   
 $T_2 = 49.46 \text{ µs}$   
 $\beta' = -1.441 \%$




Fig. 36

test impulse  
full wave

$U_t = -605.8 \text{ kV}$   
 $T_1 = 1.332 \text{ µs}$   
 $T_2 = 49.47 \text{ µs}$   
 $\beta' = -1.447 \%$

Troisdorf 11.02.2020






Fig. 37

test impulse  
full wave

$U_t = -605.8 \text{ kV}$   
 $T_1 = 1.336 \text{ µs}$   
 $T_2 = 49.47 \text{ µs}$   
 $\beta' = -1.410 \%$




Fig. 38

test impulse  
full wave

$U_t = -605.9 \text{ kV}$   
 $T_1 = 1.333 \text{ µs}$   
 $T_2 = 49.47 \text{ µs}$   
 $\beta' = -1.398 \%$




Fig. 39

test impulse  
full wave

$U_t = -605.8 \text{ kV}$   
 $T_1 = 1.332 \text{ µs}$   
 $T_2 = 49.47 \text{ µs}$   
 $\beta' = -1.434 \%$




Fig. 40

test impulse  
full wave

$U_t = -605.7 \text{ kV}$   
 $T_1 = 1.329 \text{ µs}$   
 $T_2 = 49.52 \text{ µs}$   
 $\beta' = -1.394 \%$

Troisdorf 11.02.2020




Fig. 41

test impulse  
full wave

$U_t = -605.8 \text{ kV}$   
 $T_1 = 1.332 \text{ µs}$   
 $T_2 = 49.51 \text{ µs}$   
 $\beta' = -1.421 \%$




Fig. 42

test impulse  
full wave

$U_t = -605.7 \text{ kV}$   
 $T_1 = 1.331 \text{ µs}$   
 $T_2 = 49.52 \text{ µs}$   
 $\beta' = -1.403 \%$

Troisdorf 11.02.2020

**Supplemental Information - Test Object Specification**

		Spec. No.: <b>344120</b>																																					
Repl. for issue: <b>20.12.2019</b>		Issue date: <b>10.01.2020</b>																																					
Offer-No.:		Order-No.:																																					
Zng.:	Type: <b>STARIP-Si+ 123- 800 E0</b>																																						
Condenser graded bushing, Transformer-Outdoor, dry filling																																							
		<b>Technical Data</b> <table border="0" style="width: 100%;"> <tr> <td>Rated highest voltage for Equipment Um, (50/60Hz) phase-phase:</td> <td style="text-align: right;">123.0 kV</td> </tr> <tr> <td>Rated phase-to-earth voltage:</td> <td style="text-align: right;">71 kV</td> </tr> <tr> <td>Partial discharge level at test voltage:</td> <td style="text-align: right;">≤ 4 pC</td> </tr> <tr> <td>Power-frequency withstand voltage 50Hz, 1.2 min. dry:</td> <td style="text-align: right;">255 kV</td> </tr> <tr> <td>Rated lightning impulse withstand voltage (BIL): 1.2/50µs</td> <td style="text-align: right;">550 kV</td> </tr> <tr> <td>Rated switching impulse withstand voltage (SIL): 250/2500µs</td> <td style="text-align: right;">0 kV</td> </tr> <tr> <td>Rated current:</td> <td style="text-align: right;">800 A</td> </tr> <tr> <td>Max. service current:</td> <td style="text-align: right;">800 A</td> </tr> <tr> <td>CT accommodation length:</td> <td style="text-align: right;">0 mm</td> </tr> <tr> <td>Flashover distance:</td> <td style="text-align: right;">1138 mm</td> </tr> <tr> <td>Creepage distance, min.:</td> <td style="text-align: right;">3906 mm</td> </tr> <tr> <td>Cantilever test load:</td> <td style="text-align: right;">3150 N</td> </tr> <tr> <td>Mounting position:</td> <td style="text-align: right;">0-90°</td> </tr> <tr> <td>Ambient temperature:</td> <td style="text-align: right;">-30...+40°C</td> </tr> <tr> <td>Temperature of transformer oil:</td> <td style="text-align: right;">max. 100°C max. daily mean 90 °C</td> </tr> <tr> <td>Test tap - test voltage:</td> <td style="text-align: right;">2kV, 50Hz, 1.2min.</td> </tr> <tr> <td>Routine test according to</td> <td style="text-align: right;">IEC 60137-2017</td> </tr> <tr> <td>Mass, approx.:</td> <td style="text-align: right;">57 kg</td> </tr> </table> <p>Dry insulation foam is free of SF6</p> <b>Remarks:</b> <ul style="list-style-type: none"> <li>- RIP (resin impregnated paper)</li> <li>- Draw lead bolt, E-Cu, cable cross section 450mm<sup>2</sup></li> </ul>		Rated highest voltage for Equipment Um, (50/60Hz) phase-phase:	123.0 kV	Rated phase-to-earth voltage:	71 kV	Partial discharge level at test voltage:	≤ 4 pC	Power-frequency withstand voltage 50Hz, 1.2 min. dry:	255 kV	Rated lightning impulse withstand voltage (BIL): 1.2/50µs	550 kV	Rated switching impulse withstand voltage (SIL): 250/2500µs	0 kV	Rated current:	800 A	Max. service current:	800 A	CT accommodation length:	0 mm	Flashover distance:	1138 mm	Creepage distance, min.:	3906 mm	Cantilever test load:	3150 N	Mounting position:	0-90°	Ambient temperature:	-30...+40°C	Temperature of transformer oil:	max. 100°C max. daily mean 90 °C	Test tap - test voltage:	2kV, 50Hz, 1.2min.	Routine test according to	IEC 60137-2017	Mass, approx.:	57 kg
Rated highest voltage for Equipment Um, (50/60Hz) phase-phase:	123.0 kV																																						
Rated phase-to-earth voltage:	71 kV																																						
Partial discharge level at test voltage:	≤ 4 pC																																						
Power-frequency withstand voltage 50Hz, 1.2 min. dry:	255 kV																																						
Rated lightning impulse withstand voltage (BIL): 1.2/50µs	550 kV																																						
Rated switching impulse withstand voltage (SIL): 250/2500µs	0 kV																																						
Rated current:	800 A																																						
Max. service current:	800 A																																						
CT accommodation length:	0 mm																																						
Flashover distance:	1138 mm																																						
Creepage distance, min.:	3906 mm																																						
Cantilever test load:	3150 N																																						
Mounting position:	0-90°																																						
Ambient temperature:	-30...+40°C																																						
Temperature of transformer oil:	max. 100°C max. daily mean 90 °C																																						
Test tap - test voltage:	2kV, 50Hz, 1.2min.																																						
Routine test according to	IEC 60137-2017																																						
Mass, approx.:	57 kg																																						
09.07.19 T/lid 																																							

Rev.: 7534, 7556, 7562

Troisdorf 11.02.2020




## LONG DURATION POWER-FREQUENCY VOLTAGE WITHSTAND TEST

No.: 1310299-10-M Page 1/5

Test laboratory HSP Hochspannungsgeräte GmbH  
 HS-Prüflaboratorium, Camp-Spich-Str. 18 D-53842 Troisdorf

Customer HSP Hochspannungsgeräte GmbH  
 Camp-Spich-Str. 18 D-53842 Troisdorf

<b>Test Object:</b>	<b>RIP Condenser Bushing, Transformer – Outdoor</b>
Type	<b>STARIP® – Si+ 123 – 800 E0</b>
Specification	344120 (see last page)
Highest voltage for equipment	123 kV
Rated current	800 A
Serial number	<b>283352</b>



Begin of tests 09.12.2019  
 End of tests 15.12.2019  
 Test standards IEC 60137 (2017) and 60060-1 (2010)  
 Test plan HSP 1310299/20 - TTP  
 Test equipment Documented in the laboratory test records

## HIGH VOLTAGE TEST LABORATORY

The equipment passed all indicated tests successfully.  
 The test results are valid for the tested equipment only.

Troisdorf 11.02.2020

HSP Hochspannungsgeräte GmbH  
**HS-Prüflaboratorium**  
  
 Camp-Spich-Straße 18  
 53842 Troisdorf GERMANY




*Haberecht*  
 i.A. Haberecht  
 Senior Test Engineer

*Adams*  
 i.A. Adams  
 Senior Test Engineer

## LONG DURATION POWER-FREQUENCY VOLTAGE WITHSTAND TEST

No.: 1310299-10-M Page 2/5

### Basic Circuits & Principal Test Setup



Troisdorf 11.02.2020

## LONG DURATION POWER-FREQUENCY VOLTAGE WITHSTAND TEST

No.: 1310299-10-M Page 3/5

The following tests were executed successively:

50 Hz AC routine test before type test									Date of test: 09.12.2019						
U [kV]	10	36	75	107	129	160	230	255	230	160	129	107	75	36	10
C <sub>1</sub> [pF]	260	260	260	260	260	260	260	Test voltage 72 sec.	260	260	260	260	260	260	260
tan δ [%]	0.37	0.37	0.37	0.37	0.37	0.37	0.37		0.37	0.37	0.37	0.37	0.37	0.37	0.37
p.d. [pC]	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1

### DRY POWER-FREQUENCY VOLTAGE WITHSTAND TEST WITH PARTIAL DISCHARGE MEASUREMENT

#### Test setup:

The bushing was mounted on a solidly grounded test vessel filled with oil. The effective test vessel diameter was reduced by an inserted grounded aluminium cylinder Ø 340 mm x 710 mm.

#### Atmospheric conditions:

Temperature: 20 °C  
 Air pressure: 973 hPa  
 Relative humidity: 38 %

According to IEC standard is the test applicable to all transformer bushings with Um 170 kV and above.

#### Test:

Applied 50 Hz test voltage: 107 kV  
 Duration: 60 minutes



#### p.d. measurement:

U [kV]	107	107	107	107	107	107	107	107	107	107	107	107	107	107	107
duration [min.]	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5
p.d. [pC]	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1

#### Result of test:


Neither a flashover nor a puncture has occurred.  
 During the complete test time no partial discharges above the background noise level were detected.  
 The background noise level was measured at 1 pC. See the complete test sequence on the next page

50 Hz AC routine test after type test									Date of test: 15.12.2019						
U [kV]	10	36	75	107	129	160	230	255	230	160	129	107	75	36	10
C <sub>1</sub> [pF]	259	259	259	259	259	259	259	Test voltage 72 sec.	259	259	259	259	259	259	259
tan δ [%]	0.38	0.38	0.38	0.38	0.38	0.38	0.38		0.38	0.38	0.38	0.38	0.38	0.38	0.38
p.d. [pC]	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1

Troisdorf 11.02.2020

## LONG DURATION POWER-FREQUENCY VOLTAGE WITHSTAND TEST

No.: 1310299-10-M Page 4/5



Troisdorf 11.02.2020



## LONG DURATION POWER-FREQUENCY VOLTAGE WITHSTAND TEST

No.: 1310299-10-M Page 5/5

### Supplemental Information - Test Object Specification

		Spec. No.: <b>344120</b>																																							
Zng.:	Type: <b>STARIP-Si+ 123- 800 E0</b>	Repl. for issue: <b>20.12.2019</b> Issue date: <b>10.01.2020</b> Offer-No.:                                      Order-No.:																																							
<b>Condenser graded bushing, Transformer-Outdoor, dry filling</b>																																									
<p style="font-size: small;">09.07.19 T/lid</p>	<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th colspan="2" style="text-align: left;">Technical Data</th> </tr> </thead> <tbody> <tr><td>Rated highest voltage for Equipment Um, (50/60Hz) phase-phase:</td><td style="text-align: right;">123.0 kV</td></tr> <tr><td>Rated phase-to-earth voltage:</td><td style="text-align: right;">71 kV</td></tr> <tr><td>Partial discharge level at test voltage:</td><td style="text-align: right;">≤ 4 pC</td></tr> <tr><td>Power-frequency withstand voltage 50Hz, 1.2 min. dry:</td><td style="text-align: right;">255 kV</td></tr> <tr><td>Rated lightning impulse withstand voltage (BIL): 1.2/50µs</td><td style="text-align: right;">550 kV</td></tr> <tr><td>Rated switching impulse withstand voltage (SIL): 250/2500µs</td><td style="text-align: right;">0 kV</td></tr> <tr><td>Rated current:</td><td style="text-align: right;">800 A</td></tr> <tr><td>Max. service current:</td><td style="text-align: right;">800 A</td></tr> <tr><td>CT accommodation length:</td><td style="text-align: right;">0 mm</td></tr> <tr><td>Flashover distance:</td><td style="text-align: right;">1138 mm</td></tr> <tr><td>Creepage distance, min.:</td><td style="text-align: right;">3906 mm</td></tr> <tr><td>Cantilever test load:</td><td style="text-align: right;">3150 N</td></tr> <tr><td>Mounting position:</td><td style="text-align: right;">0-90°</td></tr> <tr><td>Ambient temperature:</td><td style="text-align: right;">-30...+40°C</td></tr> <tr><td>Temperature of transformer oil:</td><td style="text-align: right;">max. 100°C max. daily mean 90 °C</td></tr> <tr><td>Test tap - test voltage:</td><td style="text-align: right;">2kV, 50Hz, 1.2min.</td></tr> <tr><td>Routine test according to</td><td style="text-align: right;">IEC 60137-2017</td></tr> <tr><td>Mass, approx.:</td><td style="text-align: right;">57 kg</td></tr> <tr><td colspan="2">Dry insulation foam is free of SF6</td></tr> </tbody> </table> <p><b>Remarks:</b></p> <ul style="list-style-type: none"> <li>- RIP (resin impregnated paper)</li> <li>- Draw lead bolt, E-Cu, cable cross section 450mm<sup>2</sup></li> </ul>	Technical Data		Rated highest voltage for Equipment Um, (50/60Hz) phase-phase:	123.0 kV	Rated phase-to-earth voltage:	71 kV	Partial discharge level at test voltage:	≤ 4 pC	Power-frequency withstand voltage 50Hz, 1.2 min. dry:	255 kV	Rated lightning impulse withstand voltage (BIL): 1.2/50µs	550 kV	Rated switching impulse withstand voltage (SIL): 250/2500µs	0 kV	Rated current:	800 A	Max. service current:	800 A	CT accommodation length:	0 mm	Flashover distance:	1138 mm	Creepage distance, min.:	3906 mm	Cantilever test load:	3150 N	Mounting position:	0-90°	Ambient temperature:	-30...+40°C	Temperature of transformer oil:	max. 100°C max. daily mean 90 °C	Test tap - test voltage:	2kV, 50Hz, 1.2min.	Routine test according to	IEC 60137-2017	Mass, approx.:	57 kg	Dry insulation foam is free of SF6	
Technical Data																																									
Rated highest voltage for Equipment Um, (50/60Hz) phase-phase:	123.0 kV																																								
Rated phase-to-earth voltage:	71 kV																																								
Partial discharge level at test voltage:	≤ 4 pC																																								
Power-frequency withstand voltage 50Hz, 1.2 min. dry:	255 kV																																								
Rated lightning impulse withstand voltage (BIL): 1.2/50µs	550 kV																																								
Rated switching impulse withstand voltage (SIL): 250/2500µs	0 kV																																								
Rated current:	800 A																																								
Max. service current:	800 A																																								
CT accommodation length:	0 mm																																								
Flashover distance:	1138 mm																																								
Creepage distance, min.:	3906 mm																																								
Cantilever test load:	3150 N																																								
Mounting position:	0-90°																																								
Ambient temperature:	-30...+40°C																																								
Temperature of transformer oil:	max. 100°C max. daily mean 90 °C																																								
Test tap - test voltage:	2kV, 50Hz, 1.2min.																																								
Routine test according to	IEC 60137-2017																																								
Mass, approx.:	57 kg																																								
Dry insulation foam is free of SF6																																									

Rev.: 7534, 7556, 7562

Troisdorf 11.02.2020








Test laboratory HSP Hochspannungsgeräte GmbH  
 HS-Prüflaboratorium, Camp-Spich-Str. 18 D-53842 Troisdorf

Customer HSP Hochspannungsgeräte GmbH  
 Camp-Spich-Str. 18 D-53842 Troisdorf

<b>Test Object:</b>	<b>RIP Condenser Bushing, Transformer – Outdoor</b>
Type	<b>STARIP® – Si+ 123 – 800 E0</b>
Specification	344120 (see last page)
Highest voltage for equipment	123 kV
Rated current	800 A
Serial number	<b>283352</b>



Begin of tests 09.12.2019  
 End of tests 15.12.2019  
 Test standards IEC 60137 (2017) and 60060-1 (2010)  
 Test plan HSP 1310299/20 - TTP  
 Test equipment Documented in the laboratory test records

The equipment passed all indicated tests successfully.  
 The test results are valid for the tested equipment only.

Troisdorf, 11.02.2020


HSP Hochspannungsgeräte GmbH  
**HS-Prüflaboratorium**  
  
 Camp-Spich-Straße 18  
 53842 Troisdorf GERMANY



*Haberecht*  
 i.A. Haberecht  
 Senior Test Engineer

*Adams*  
 i.A. Adams  
 Senior Test Engineer

### Basic Circuits & Principal Test Setup



Troisdorf 11.02.2020

HSP Hochspannungsgeräte GmbH  
HS-Prüflaboratorium

Camp-Spich-Straße 18  
53842 Troisdorf GERMANY

Eine auszugsweise Vervielfältigung ist ohne schriftliche Genehmigung von HSP nicht gestattet.



A duplication in extracts is allowed only with written permission of HSP.

## WET POWER-FREQUENCY VOLTAGE WITHSTAND TEST

No.: 1310299-10-N Page 3/4

The following tests were executed successively:

50 Hz AC routine test before type test													Date of test: 09.12.2019		
U [kV]	10	36	75	107	129	160	230	255	230	160	129	107	75	36	10
C <sub>1</sub> [pF]	260	260	260	260	260	260	260	Test voltage 72 sec.	260	260	260	260	260	260	260
tan δ [%]	0.37	0.37	0.37	0.37	0.37	0.37	0.37	72 sec.	0.37	0.37	0.37	0.37	0.37	0.37	0.37
p.d. [pC]	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1

WET POWER-FREQUENCY VOLTAGE WITHSTAND TEST													Date of test: 13.12.2019		
--	--	--	--	--	--	--	--	--	--	--	--	--	--------------------------	--	--

**Test setup:**


The bushing was mounted on an oil filled and grounded test vessel. The test object was connected to the transformer by a wire.

**Atmospheric conditions:**

Temperature: 20 °C  
 Air pressure: 976 hPa

**Rain:**

Average rainfall (vert.): 1.8 mm/min.  
 Average rainfall (hor.): 1.6 mm/min.  
 Resistivity at 20 °C 98 Ω m



Pre-wetting-time was more than 15 minutes.

**Specified test voltage:** 230 kV for 60 seconds

**Test:**

Applied test voltage [kV]	Duration [sec.]
255	72

**Result of test:**

During the test time neither a flashover nor a puncture has occurred.

50 Hz AC routine test after type test													Date of test: 15.12.2019		
U [kV]	10	36	75	107	129	160	230	255	230	160	129	107	75	36	10
C <sub>1</sub> [pF]	259	259	259	259	259	259	259	Test voltage 72 sec.	259	259	259	259	259	259	259
tan δ [%]	0.38	0.38	0.38	0.38	0.38	0.38	0.38	72 sec.	0.38	0.38	0.38	0.38	0.38	0.38	0.38
p.d. [pC]	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1

Troisdorf 11.02.2020



## Supplemental Information - Test Object Specification

		Spec. No.: <div style="font-size: 1.2em; font-weight: bold;">344120</div>																																					
Zng.:	Type: <b>STARIP-Si+ 123- 800 E0</b>	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="font-size: 0.8em;">Repl. for issue:</td> <td style="font-size: 0.8em;">Issue date:</td> </tr> <tr> <td style="text-align: center;">20.12.2019</td> <td style="text-align: center;">10.01.2020</td> </tr> <tr> <td style="font-size: 0.8em;">Offer-No.:</td> <td style="font-size: 0.8em;">Order-No.:</td> </tr> </table>	Repl. for issue:	Issue date:	20.12.2019	10.01.2020	Offer-No.:	Order-No.:																															
Repl. for issue:	Issue date:																																						
20.12.2019	10.01.2020																																						
Offer-No.:	Order-No.:																																						
Condenser graded bushing, Transformer-Outdoor, dry filling																																							
<p style="font-size: 0.8em;">Composite silicone insulator Colour: light grey</p> <p style="font-size: 0.8em;">E-Cu Copper</p> <p style="font-size: 0.8em;">M12x30</p> <p style="font-size: 0.8em;">90</p> <p style="font-size: 0.8em;">150</p> <p style="font-size: 0.8em;">127</p> <p style="font-size: 0.8em;">1138</p> <p style="font-size: 0.8em;">1425±5</p> <p style="font-size: 0.8em;">A</p> <p style="font-size: 0.8em;">CT</p> <p style="font-size: 0.8em;">60°</p> <p style="font-size: 0.8em;">15</p> <p style="font-size: 0.8em;">350±4</p> <p style="font-size: 0.8em;">Sealing area</p> <p style="font-size: 0.8em;">min. 160</p> <p style="font-size: 0.8em;">B</p> <p style="font-size: 0.8em;">8 x 45°</p> <p style="font-size: 0.8em;">45°</p> <p style="font-size: 0.8em;">Earthing hole M12</p> <p style="font-size: 0.8em;">Transformer air vent</p> <p style="font-size: 0.8em;">Lifting hole M12</p> <p style="font-size: 0.8em;">Test tap</p> <p style="font-size: 0.8em;">A-A</p> <p style="font-size: 0.8em;">"B"</p> <p style="font-size: 0.8em;">50</p> <p style="font-size: 0.8em;">65</p> <p style="font-size: 0.8em;">130</p> <p style="font-size: 0.8em;">40</p>	<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th colspan="2" style="text-align: left; font-weight: normal;">Technical Data</th> </tr> </thead> <tbody> <tr> <td style="font-size: 0.8em;">Rated highest voltage for Equipment Um, (50/60Hz) phase-phase:</td> <td style="text-align: right;">123.0 kV</td> </tr> <tr> <td style="font-size: 0.8em;">Rated phase-to-earth voltage:</td> <td style="text-align: right;">71 kV</td> </tr> <tr> <td style="font-size: 0.8em;">Partial discharge level at test voltage:</td> <td style="text-align: right;">≤ 4 pC</td> </tr> <tr> <td style="font-size: 0.8em;">Power-frequency withstand voltage 50Hz, 1.2 min. dry:</td> <td style="text-align: right;">255 kV</td> </tr> <tr> <td style="font-size: 0.8em;">Rated lightning impulse withstand voltage (BIL): 1.2/50µs</td> <td style="text-align: right;">550 kV</td> </tr> <tr> <td style="font-size: 0.8em;">Rated switching impulse withstand voltage (SIL): 250/2500µs</td> <td style="text-align: right;">0 kV</td> </tr> <tr> <td style="font-size: 0.8em;">Rated current:</td> <td style="text-align: right;">800 A</td> </tr> <tr> <td style="font-size: 0.8em;">Max. service current:</td> <td style="text-align: right;">800 A</td> </tr> <tr> <td style="font-size: 0.8em;">CT accommodation length:</td> <td style="text-align: right;">0 mm</td> </tr> <tr> <td style="font-size: 0.8em;">Flashover distance:</td> <td style="text-align: right;">1138 mm</td> </tr> <tr> <td style="font-size: 0.8em;">Creepage distance, min.:</td> <td style="text-align: right;">3906 mm</td> </tr> <tr> <td style="font-size: 0.8em;">Cantilever test load:</td> <td style="text-align: right;">3150 N</td> </tr> <tr> <td style="font-size: 0.8em;">Mounting position:</td> <td style="text-align: right;">0-90°</td> </tr> <tr> <td style="font-size: 0.8em;">Ambient temperature:</td> <td style="text-align: right;">-30...+40°C</td> </tr> <tr> <td style="font-size: 0.8em;">Temperature of transformer oil:</td> <td style="text-align: right;">max.100°C max. daily mean 90 °C</td> </tr> <tr> <td style="font-size: 0.8em;">Test tap - test voltage:</td> <td style="text-align: right;">2kV, 50Hz, 1.2min.</td> </tr> <tr> <td style="font-size: 0.8em;">Routine test according to</td> <td style="text-align: right;">IEC 60137-2017</td> </tr> <tr> <td style="font-size: 0.8em;">Mass, approx.:</td> <td style="text-align: right;">57 kg</td> </tr> </tbody> </table> <p style="font-size: 0.8em;">Dry insulation foam is free of SF6</p> <p style="font-size: 0.8em;"><b>Remarks:</b></p> <ul style="list-style-type: none"> <li>- RIP (resin impregnated paper)</li> <li>- Draw lead bolt, E-Cu, cable cross section 450mm<sup>2</sup></li> </ul>	Technical Data		Rated highest voltage for Equipment Um, (50/60Hz) phase-phase:	123.0 kV	Rated phase-to-earth voltage:	71 kV	Partial discharge level at test voltage:	≤ 4 pC	Power-frequency withstand voltage 50Hz, 1.2 min. dry:	255 kV	Rated lightning impulse withstand voltage (BIL): 1.2/50µs	550 kV	Rated switching impulse withstand voltage (SIL): 250/2500µs	0 kV	Rated current:	800 A	Max. service current:	800 A	CT accommodation length:	0 mm	Flashover distance:	1138 mm	Creepage distance, min.:	3906 mm	Cantilever test load:	3150 N	Mounting position:	0-90°	Ambient temperature:	-30...+40°C	Temperature of transformer oil:	max.100°C max. daily mean 90 °C	Test tap - test voltage:	2kV, 50Hz, 1.2min.	Routine test according to	IEC 60137-2017	Mass, approx.:	57 kg
Technical Data																																							
Rated highest voltage for Equipment Um, (50/60Hz) phase-phase:	123.0 kV																																						
Rated phase-to-earth voltage:	71 kV																																						
Partial discharge level at test voltage:	≤ 4 pC																																						
Power-frequency withstand voltage 50Hz, 1.2 min. dry:	255 kV																																						
Rated lightning impulse withstand voltage (BIL): 1.2/50µs	550 kV																																						
Rated switching impulse withstand voltage (SIL): 250/2500µs	0 kV																																						
Rated current:	800 A																																						
Max. service current:	800 A																																						
CT accommodation length:	0 mm																																						
Flashover distance:	1138 mm																																						
Creepage distance, min.:	3906 mm																																						
Cantilever test load:	3150 N																																						
Mounting position:	0-90°																																						
Ambient temperature:	-30...+40°C																																						
Temperature of transformer oil:	max.100°C max. daily mean 90 °C																																						
Test tap - test voltage:	2kV, 50Hz, 1.2min.																																						
Routine test according to	IEC 60137-2017																																						
Mass, approx.:	57 kg																																						

Rev.: 7534, 7556, 7562

Troisdorf 11.02.2020




## EMISSION TEST

No.: 1310299-10-R Page 1/5

Test laboratory HSP Hochspannungsgeräte GmbH  
 HS-Prüflaboratorium, Camp-Spich-Str. 18 D-53842 Troisdorf

Customer HSP Hochspannungsgeräte GmbH  
 Camp-Spich-Str. 18 D-53842 Troisdorf

<b>Test Object:</b>	<b>RIP Condenser Bushing, Transformer – Outdoor</b>
Type	<b>STARIP® – Si+ 123 – 800 E0</b>
Specification	344120 (see last page)
Highest voltage for equipment	123 kV
Rated current	800 A
Serial number	<b>283352</b>



Begin of tests 09.12.2019  
 End of tests 15.12.2019  
 Test standards IEC 60137 (2017) and 60060-1 (2010)  
 Test plan HSP 1310299/20 - TTP  
 Test equipment Documented in the laboratory test records

The equipment passed all indicated tests successfully.  
 The test results are valid for the tested equipment only.

Troisdorf 11.02.2020


HSP Hochspannungsgeräte GmbH  
**HS-Prüflaboratorium**  
  
 Camp-Spich-Straße 18  
 53842 Troisdorf GERMANY



*Haberecht*  
 i.A. Haberecht  
 Senior Test Engineer

*Adams*  
 i.A. Adams  
 Senior Test Engineer

## Basic Circuits & Principal Test Setup



Troisdorf 11.02.2020

## EMISSION TEST

No.: 1310299-10-R Page 3/5

The following tests were executed successively:

50 Hz AC routine test before type test										Date of test: 09.12.2019					
U [kV]	10	36	75	107	129	160	230	255	230	160	129	107	75	36	10
C <sub>1</sub> [pF]	260	260	260	260	260	260	260	Test voltage 72 sec.	260	260	260	260	260	260	260
tan δ [%]	0.37	0.37	0.37	0.37	0.37	0.37	0.37		0.37	0.37	0.37	0.37	0.37	0.37	0.37
p.d. [pC]	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1

## EMISSION TEST

Date of test: 13.12.2019

### Test setup:

The bushing was mounted on a solidly grounded test vessel filled with oil. The effective test vessel diameter was reduced by an inserted grounded aluminium cylinder Ø 340 mm x 710 mm. The test object was connected to the high voltage by steel rod Ø 30 mm x 700 mm.

### Atmospheric conditions:

Temperature: 20 °C  
 Air pressure: 974 hPa  
 Relative humidity: 39 %



### Test:

50 Hz AC test voltage: series of voltage steps from  $1.1 \times U_m / \sqrt{3}$  to  $0.3 \times U_m / \sqrt{3}$

### p.d. measurement


U [kV]	78	71	64	57	50	43	36	28	21
p.d. [pC]	1	1	1	1	1	1	1	1	1

### Result of test:

During the test no partial discharges above the background noise level were detected. The background noise level was measured at 1 pC. See the complete test sequence on the next page.

50 Hz AC routine test after type test										Date of test: 15.12.2019					
U [kV]	10	36	75	107	129	160	230	255	230	160	129	107	75	36	10
C <sub>1</sub> [pF]	259	259	259	259	259	259	259	Test voltage 72 sec.	259	259	259	259	259	259	259
tan δ [%]	0.38	0.38	0.38	0.38	0.38	0.38	0.38		0.38	0.38	0.38	0.38	0.38	0.38	0.38
p.d. [pC]	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1

Troisdorf 11.02.2020



Troisdorf 11.02.2020



## EMISSION TEST

No.: 1310299-10-R Page 5/5

### Supplemental Information - Test Object Specification

		Spec. No.: <div style="text-align: right; font-weight: bold;">344120</div>
Zng.:	Type: <b>STARIP-Si+ 123- 800 E0</b>	Repl. for issue: <div style="text-align: right; font-weight: bold;">20.12.2019</div>
		Issue date: <div style="text-align: right; font-weight: bold;">10.01.2020</div>
		Offer-No.: <div style="text-align: right; font-weight: bold;">Order-No.:</div>

Condenser graded bushing, Transformer-Outdoor, dry filling

Composite silicone insulator  
Colour: light grey

E-Cu  
Copper

CT

Sealing area

min. 160

8 x 45°  
45°

Earthing hole M12

Transformer air vent

Lifting hole M12

Test tap

A-A

"B"

#### Technical Data

Rated highest voltage for Equipment Um, (50/60Hz) phase-phase:	123.0 kV
Rated phase-to-earth voltage:	71 kV
Partial discharge level at test voltage:	≤ 4 pC
Power-frequency withstand voltage 50Hz, 1.2 min. dry:	255 kV
Rated lightning impulse withstand voltage (BIL): 1.2/50µs	550 kV
Rated switching impulse withstand voltage (SIL): 250/2500µs	0 kV
Rated current:	800 A
Max. service current:	800 A
CT accommodation length:	0 mm
Flashover distance:	1138 mm
Creepage distance, min.:	3906 mm
Cantilever test load:	3150 N
Mounting position:	0-90°
Ambient temperature:	-30...+40°C
Temperature of transformer oil:	max.100°C max. daily mean 90 °C
Test tap - test voltage:	2kV, 50Hz, 1.2min.
Routine test according to	IEC 60137-2017
Mass, approx.:	57 kg

Dry insulation foam is free of SF6

#### Remarks:

- RIP (resin impregnated paper)
- Draw lead bolt, E-Cu, cable cross section 450mm<sup>2</sup>

Rev.: 7534, 7556, 7562

Troisdorf 11.02.2020