

Certificate of Compliance

Certificate Number:

UL-US-2554352-0

Report Reference:

E542849-20250205

Issue Date:

2025-02-11

Issued to:

**Tianhong Power Technology Co., Ltd.
No. 318-1 North Xuhai Road, Xuzhou Economic And
Technological Development Zone Xuzhou, Js 221000
China**

This certificate confirms that representative samples of:

**XPLH - Transformers, Distribution, Liquid-filled Type, Over 600
Volts**

See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.

**IEEE C57.12.00, Issue Date: 2021-11-09, IEEE C57.12.28, Issue
Date 2023-12-06**

Additional Information:

See UL Product iQ® at <https://iq.ulprospector.com> for additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



A handwritten signature in black ink that reads 'David Piecuch'.

David Piecuch
UL Mark Certification Program Owner

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.

CERTIFICATE OF COMPLIANCE

Certificate number UL-US-2554352-0
Report reference E542849-20250205
Date 2025-02-11

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Model	Product Description
<p>ZGSABC-DE-XXXX/YY.YYY/Z.ZZZ, where ZG represents pad-mounted transformer, S represents three phases, A represents insulation oil type, may be blank or R, blank represents mineral oil, R represents less-flammable vegetable oil. B represents winding material, L represents Aluminum. C represents core material, blank represents electrical grade steel. D represents primary connection, may be H or Z, H represents loop, Z represents radial. E represents bushing type, blank represents dead front. XXXX represents rate capacity, may be 45, 75, 112.5, 150, 225, 300, 500, 750, 1000, 1500, 2000, 2500, 3000, 3750, 5000 KVA. "YY.YYY" = represents Hv rated voltage, maybe 34.5 represents 34500 or 34500GrdY Vac, "Z.ZZZ" is optional, represents rated Lv voltage, may be 0.6 represents 600 or 600Y/347 Vac, 0.48 represents 480 or 480Y/277 Vac, 0.415 represents 415 or 415Y/240 Vac, 0.24 represents 240 Vac, 0.208 represents 208Y/120 Vac. (X or Y or Z may be blank).</p>	<p>Three phase Distribution, Liquid-Immersed Pad-Mounted Transformers - Over 600 Volts</p>



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.

Certificate of Compliance

Certificate Number:

UL-CA-2540857-0

Report Reference:

E542849-20250205

Issue Date:

2025-02-11

Issued to:

**Tianhong Power Technology Co., Ltd.
No. 318-1 North Xuhai Road, Xuzhou Economic And
Technological Development Zone Xuzhou, Js 221000
China**

This certificate confirms that representative samples of:
**XPLH7 - Transformers, Distribution, Liquid-filled Type, Over 750
Volts Certified for Canada**

See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.

CSA C227.4, 3rd Ed., Issue Date: 2021-03-01

Additional Information:

See UL Product iQ® at <https://iq.ulprospector.com> for additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



A handwritten signature in black ink that reads 'David Piecuch'.

David Piecuch
UL Mark Certification Program Owner

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.

CERTIFICATE OF COMPLIANCE

Certificate number UL-CA-2540857-0
Report reference E542849-20250205
Date 2025-02-11

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Model	Product Description
ZGSABC-DE-XXXX/YY.YYY/A.AAA, where ZG represents pad-mounted transformer, S represents three phases, A represents insulation oil type, may be blank or R, blank represents mineral oil, R represents less-flammable vegetable oil. B represents winding material, L represents Aluminum. C represents core material, blank represents electrical grade steel. D represents primary connection, may be H or Z, H represents loop, Z represents radial. E represents Bushing type, blank represents dead front. XXXX represents rate capacity, may be 75, 150, 225, 300, 500, 750, 1000, 1500, 2000, 3000. "YY.YYY" = represents Hv rated voltage, maybe 34.5 represents 34500 or 34500GrdY Vac, "Z.ZZZA.AAA" is optional, represents rated Lv voltage, may be 0.6 represents 600 or 600Y/347 Vac, 0.48 represents 480 or 480Y/277 Vac, 0.415 represents 415 or 415Y/240 Vac, 0.24 represents 240 Vac, 0.208 represents 208Y/120 Vac. (X or Y or Z A may be blank).	Three phase Distribution, Liquid-Immersed Pad-Mounted Transformers - Over 750 Volts



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.