



TESTCOM – Certifying Body for Certification of Products, No.:3136 accredited by CAI according to ČSN EN ISO/IEC 17 065:2013;  
Hvoždanská 3, 148 00 Praha 4; phone: +420 271 192 158, e-mail: fsebek@cmi.cz

## CERTIFICATE OF THE PRODUCT

No. 0120-CC-V0018-16

**Applicant:** SUNDRAx Ltd.  
707, Westgate House, Westgate Road  
London W5 1YY, Great Britain

**Manufacturer:** SUNDRAx Ltd.  
707, Westgate House, Westgate Road  
London W5 1YY, Great Britain

**Product:** Central Controller

**Type:** Qulon-C S/N ---

**Basic parameters:**

Relay outputs	4
Max. voltage and current at inputs	230V, 5A
Max. voltage and current at outputs	230V, 5A
Number of sensor inputs	2
Radio channel used	GSM900/1800/1900
Interfaces supported	RS485, CAN
Setup	remotely over GSM, locally over RS 485 (MODBUS)
Operating temperature range	-40°C to +60 °C
Power supply	100VAC - 240VAC, 50/60 Hz
Size	(105x210x75) mm

**This certificate confirms:**

The compliance  
of the above mentioned product with essential requirements of  
EU Directive 1999/5/EC (Government Decree No.: 426/2000 Coll.),  
and the following technical regulations (standards, specifications):  
ETSI EN 301 489-1 V1.9.2, ETSI EN 301 489-7 V1.3.1,  
EN 60950-1, ed.2:2006, +A1:2010, +A11: 2009, +A12:2011, +Cor.:2011-10

**The Basis of the assessment:**

- Certification scheme according to EU Directive 1999/5/EC, Annex IV (Government Decree No.: 26/2000 Coll., Annex 4).
- The Certifications System is based on the product testing and its documentation verification.  
The basis for the issuing of the certificate are the following documents:
- The final report 0120-ZA-Z0018-16 issued by TESTCOM-COV in Prague, which is its an integral part.  
The Instruction for use is on the second page of this Certificate.

Prague, October 20<sup>th</sup>, 2016



  
Miloš Prchlík  
Head of Certification Body

The Certificate can be used as a basis for the "Declaration of Conformity, in pursuing the Act No. 22/97 Coll., as amended by the Act No. 71/2000 Coll., on technical requirements for products.

The Certificate confirming the measures implemented in the production domain is only valid for the manufacturer and his/her business premises that are indicated in the Certification.

The Certificate is valid only for the Product (Equipment) who's Serial Number (S/N) is identical with S/N mentioned in this Certificate.

The Holder of the Certificate is obligated use only this range of the declaration, which is writing on the Certificate.