

Customer code

V.A.T. No. Bank

Telephone

Payment

SALVATORE ROBUSCHI & C. s.r.l. Via Segré, 11/A - 43122 PARMA (ITALIA) Telefono ++39 0521 606285 r.a. Telefax ++39 0521 606278 E-mail : sr@salvatorerobuschi.com PEC : salvatorerobuschi@pecwise.it Web : http://www.salvatorerobuschi.com

Spett.

AXIMA GRUP SRL GH. ASACHI 19 B MUN. CHISINAU MOLDAVIA

Goods receiver

AXIMA GRUP SRL GH. ASACHI 19 B MUN. CHISINAU MOLDAVIA

Delivery	F
	\mathbf{P}_{i}
Expedition	
Carrier	
D	

REE CARRIER

ARMA

Package

QUOTATION Nº 1000096486 dd 10.04.2025

373 22 84 44 01

- Before shipment

Before shipment

Your ref. The salted water pump request FOR INFORMATION: Fiorani Davide

300934

Agent **NA**

Pos.	Code	Description	UM	Qty	Unit list p.	Total net	VAT
10	CPUMP00	RDM 32-16D 2B22 M181 3/A	NR	1			Vб
		Goods ready for shipment: 21 days from order					
		Q:12,5 H:21,3 LIQUID:WATE WITH SALT (12%)					
		Installation area: Safe Area					
		Pump Execution: Close Coupled					
		Pump Casing Material: EN1.4408-A351 CF8M-AISI 316					
		Seal Execution: M (Standard) (Single Seal)					
		Electric Motor Supply: Included					
		Motor Power: 2,20 kW					
		Electric Motor Poles: 2					
		Nominal Motor Frequency: 50 HZ					
		Motor Shape: B5					
		Included certificates:					
		CE Declaration of Conformity					
		Note:					
		PLEASE NOTE: 24-MONTH WARRANTY FOR PUMP COMPONENTS					
		SUBJECT TO WEAR AND TEAR COSIDERING THE RELIABILITY OF THE PUMPED LIQUID					
		See details in the attached Data Sheet					
		see details in the attached bata sheet					
	Rateable va	lue Total V.A.T.	Ca	sh disco	ount	Total net ar	nount

Our general sales condition in use

SALVATORE ROBUSCHI & C. s.r.l. - Via Segré 11/A - 43122 PARMA (ITALIA) - Tel. +39 0521 606285 r.a. - Fax. 039 0521 606278 - sr@salvatorerobuschi.com - www.salvatorerobuschi.com CAPITALE SOCIALE 93.600€ i.v. - COD.FISC./part.iva 00738820349 - COD.IDENTIF.CEE IT 00738820349 - R.E.A. N. 142953 - TRIBUNALE REG. IMPR. DI PARMA N 00738820349

Valid until 30.04.2025



Customer code V.A.T. No.

Bank

Telephone

SALVATORE ROBUSCHI & C. s.r.l. Via Segré, 11/A - 43122 PARMA (ITALIA) Telefono ++39 0521 606285 r.a. Telefax ++39 0521 606278 E-mail : sr@salvatorerobuschi.com PEC : salvatorerobuschi@pecwise.it Web : http://www.salvatorerobuschi.com

Spett.

AXIMA GRUP SRL GH. ASACHI 19 B MUN. CHISINAU MOLDAVIA

Goods receiver

AXIMA GRUP SRL GH. ASACHI 19 B MUN. CHISINAU MOLDAVIA

Delivery	F
	P
Expedition	
Carrier	

REE CARRIER

Package

PARMA

Payment Before shipment

300934

- Before shipment

373 22 84 44 01

QUOTATION Nº 1000096486 dd 10.04.2025

Your ref. The salted water pump request FOR INFORMATION: Fiorani Davide

Agent **NA**

Pos.	Code	Description		UM	Qty	Unit list p.	Total net	VAT
		We are at your disposal for information With effect from 1st July 2 class IE4 will be mandatory with power between 75 and 2 with efficiency class IE3 w available while stocks last including IE3 motors no lon will be updated in terms of delivery date with new IE4	023, efficiency for motors 00 kW.Motors fill be . Quotations ger available price and					
		The supply is subjected to the ge conditions of #SALVATORE ROBUSCHI disposal on demand. Standard certificates: pumps are operating and maintenance handboo certificates. Further certificate request.	# that are at your supplied with k and CE					
		Please send Purchase Orders to em orders@salvatorerobuschi.com For Shipments please email to spe@salvatorerobuschi.com For Invoices please email to amm@salvatorerobuschi.com	ail					
	Rateable va	lue Total V.A.T. 0,00		Ca	sh disco	ount	 Total net ar	nount

Our general sales condition in use

SALVATORE ROBUSCHI & C. s.r.l. - Via Segré 11/A - 43122 PARMA (ITALIA) - Tel. +39 0521 606285 r.a. - Fax. 039 0521 606278 - sr@salvatorerobuschi.com - www.salvatorerobuschi.com CAPITALE SOCIALE 93.600€ i.v. - COD.FISC./part.iva 00738820349 - COD.IDENTIF.CEE IT 00738820349 - R.E.A. N. 142953 - TRIBUNALE REG. IMPR. DI PARMA N 00738820349

Valid until 30.04.2025



Pumps: RDM 32-16D 2B22 M181 3/A

Item:

LIQUIDO

Liquid	WATE WITH SALT (12%)	Liquid Temperature	40	
Liquid	CLEAN, NO SOLIDS	Density	1,06	kg/dm
Liquid	-	Kinematic Viscosity	1,0	mm2/

DESIGN PARAMETER

Working Capacity	12,5	m3/h	Working Absorbed Power	1,51	kW
Working Head	21,3	m	Nominal Working Speed	2.930	1/min
Required Capacity	12,5	m3/h	Service	-	
Required Head	20,0	m	Suction Conditions	-	
Min. Capacity	0,6	m3/h	Geodetic Suction Head	-	
Max. Capacity	16,2	m3/h	Gauge Suction Pressure	0,00	bar
Max. Head	26,4	m	Minimum ambient temperature	-20	°C
NPSH available	0,00	m	Altitude of Installation	<1000 m ASL	
NPSHr (Required from the pump)	1,17	m			•
Efficiency at Working Point	51,0				

PUMP DETAILS

Pump Standard	ISO 2858/ISO 5199		Pump Flanges Norm	EN 1092 PN16	
Pump Designation	RD		Rated Impeller Trim	D	
Pump Size	32-16		Impeller Type	Closed	
Pump Group	1		Rated Impeller Diameter	140	mm
Installation area	Safe Area		Maximum Impeller Diameter	169	mm
GAS Atex Marking			Minimum Impeller Diameter	120	mm
DUST Atex Marking			Solids Free Passage [mm]	N.A.	
Design Pressure	16	bar	Casing Drain Hole	1/4 G	
Hydrostatic Test Pressure	24	bar	Casing Venting Hole	1/4 G	
Suction Port Diameter [DN]	50		Painting Cycle	STD-RAL5010-Poliacr.cat.	
Discharge Port Diameter [DN]	32		Pump RAL	5010	

PUMPS EXECUTION

Pump Configuration Horizontal		Pump Execution	Close Coupled	
-------------------------------	--	----------------	---------------	--

PUMPS MATERIALS

Pump Casing Material	EN1.4408-A351 CF8M-AISI 316	Wear Ring Material	EN1.4404-A351 CF3M-AISI 316L	
Impeller Material	EN1.4408-A351 CF8M-AISI 316	Lantern Bracket Material	EN1561 - GJL200	
Close Coupled Shaft Material	316L	Gasket Main Material	SIL C-4400	
Wear Plate Material	Not Present			

CONFIDENTIAL AGREEMENT NO PART OF THIS REPORT MAY BE REPRODUCED AND TRASMITTED IN ANY FORM OR ANY MEANS WITHOUT PRIOR WRITTEN PERMISSION OF SR pumps. THIS DOCUMENT MAY BE USED ONLY AS A PIECE OF CONFIDENTIAL TECHNICAL REFERENCE AND NEVER AS AN OFFICIAL DOCUMENT AGAINST SR pumps INTEREST.

MECHANICAL SEALS

M (Standard) (Single Seal)		API PLAN	Not Present	
33	mm	Plan Pipes material	N.A.	
Included		Flushing Pressure	Ext. Flushing not required	
UN L4K		Flushing Tank Supply	Tank Not Included	
Uniten		Flushing Tank	Not Present	
181				
SIC/SIC/VITON				
Not Present				
-				
-				
-				
Not Available				
	33 Included UN L4K Uniten 181 SIC/SIC/VITON Not Present - -	33 mm Included Included UN L4K Included 181 SIC/SIC/VITON Not Present Included - Included	33 mm Plan Pipes material Included Flushing Pressure UN L4K Flushing Tank Supply Uniten Flushing Tank 181 SIC/SIC/VITON Not Present - - - - - - -	33 mm Plan Pipes material N.A. Included Flushing Pressure Ext. Flushing not required UN L4K Flushing Tank Supply Tank Not Included Uniten Flushing Tank Not Present 181 SIC/SIC/VITON Not Present - - - - - -

FXT	RA
-//	

Heating/Cooling Casing Chamber	Not Present	Pump Impeller Treatments	Not Present	
Seal Heating Jacket	Not Present	Special Pump Treatments	Not Present	
Heat Exchanger	Not Present	Special Casing Execution	Not Present	
Pump Casing Treatments	Not Present			

MOTOR

Electric Motor Brand	WEG		Motor Class Tolerances	YES - Precision Class	
El. Motor Serie	W22		Additional Fan Cooling	-	
Electric Motor Poles	2		Motor Roof	-	
Motor Power	2,20	kW	PT100 Probes	-	
Motor Size	90L		Auxiliary Electric Box	-	
El. Motor Flange Diameter	200		Ambient Temp. < -20°C	-	
Electric Motor Supply	Included		Working Temp. >40°C	-	
El Motor Standard/Customized	Standard		Motor Casing Material	Cast Iron	
Motor Category	IEC (not Atex)		Downsized Motor	-	
Std. Electric Motor Brand	WEG		Derated Engine Power	-	kW
Nominal Motor Frequency	50	HZ	Additional Label	-	
Operating motor voltage	230/400		Insulated Ball Bearing for VFD	-	
Motor Efficiency Class	IE3		Motor Extras	-	
Motor Shape	B5		Extras	-	
Motor Protection	IP55		Extras	-	
Insulation Class	F		Extras	-	
PTC	Included		Extras	-	
Number of PTC Required	-				
Max Frequency (Inverter Use)	60				
Min. Frequency (Inverter Use)	30		1		


TEST AND CERTIFICATES

Food Certificate	No Certification Issue	NPSH Test	No Certification Issue	
ATEX Declaration of Conformity	No	Noise Test	No Certificate Issue	
Impeller Balancing Certificate	No Certificate Issue (P-1006)	Painting Check	No Certificate Issue	
CE Declaration of Conformity	Yes	Certificate of Quality	No	
Drawing Acc.To Customer Spec.	No	End Supply Certification Book	No	
Certificate of Warranty	No	Performance Test (Q-H-P)	No Certificate Issue	
Hydrostatic Test	No Certificate Issue (P-1005)	Visual a Dimensional Check	No Certificate Issue (P-1012)	
Inspection and Test Plan	No	Vibration Test	No Certificate Issue	
Material Certificate	-	Working Conformity Certificate	No Certification Issue	
Mechanical Running Test	No Certification Issue	Preferential Origin	Not Included	

CONFIDENTIAL AGREEMENT NO PART OF THIS REPORT MAY BE REPRODUCED AND TRASMITTED IN ANY FORM OR ANY MEANS WITHOUT PRIOR WRITTEN PERMISSION OF SR pumps. THIS DOCUMENT MAY BE USED ONLY AS A PIECE OF CONFIDENTIAL TECHNICAL REFERENCE AND NEVER AS AN OFFICIAL DOCUMENT AGAINST SR pumps INTEREST.

NOTE:

PLEASE NOTE: 24-MONTH WARRANTY FOR PUMP COMPONENTS SUBJECT TO WEAR AND TEAR COSIDERING THE RELIABILITY OF THE PUMPED LIQUID



CONFIDENTIAL AGREEMENT NO PART OF THIS REPORT MAY BE REPRODUCED AND TRASMITTED IN ANY FORM OR ANY MEANS WITHOUT PRIOR WRITTEN PERMISSION OF SR pumps. THIS DOCUMENT MAY BE USED ONLY AS A PIECE OF CONFIDENTIAL TECHNICAL REFERENCE AND NEVER AS AN OFFICIAL DOCUMENT AGAINST SR pumps INTEREST.

