

To:

Company: Jiangsu Jinghua New Energy
Operation Management Co., Ltd.

Contact: Mr. He Kaikai

Email: hekaikai@jinghuaenergy.com

From:

Company: TÜV NORD (HANGZHOU) CO., LTD.

Contact: Ms. Miley Li

Email: wli@tuv-nord.com

2020-11-16

Subject: Declaration of cancellation

File No.: SHV01045/20-02

License holder: **Jiangsu Jinghua New Energy Operation Management Co., Ltd.**
No.88, Wenchang East Road, Jiangdu District, Yangzhou City, P.R. China

Manufacturer: **YANGZHOU JINGHUA New Energy Technology Co., Ltd.**
No. 1 Weili Road, Xiancheng Industrial Park, Jiangdu District
Yangzhou City, Jiangsu Province, P.R. China

Certificate No.: 44 780 20 406749 - 181

Product: Crystalline Silicon Terrestrial Photovoltaic (PV) Modules

Herewith it is declared, that the above noted certificate(s) has (have) been invalidated since the date 2020-11-16.

The cancellation is to:

- ☐ License holder applied for cancellation.
- ☒ New certificate(s) has (have) been issued to replace the cancelled one(s).
(New certificate(s) : 44 780 20 406749 - 181M1)
- ☐ Annual factory inspection is refused by the license holder or the manufacturer.
- ☐ Factory Inspection fee or annual fee or registration fee is not paid by License Holder or Manufacturer.
- ☐ Others. (N/A)

Please pay attention to stop using the invalid certificate(s) from 2020-11-16. Meanwhile, please send back the original copies of above mentioned certificate(s) to us.

TÜV NORD reserved the right of final explanation about the cancellation of certificate(s). TÜV NORD will not take any responsibility for the circumstance of misusing the invalid certificate(s) by the license holder or the manufacturer.

PV Business - Renewable Energy
TÜV NORD (Hangzhou) Co., Ltd.

Miley Li
Technical Support

TÜV NORD (Hangzhou) Co., Ltd.
杭州汉德质量认证服务有限公司
Member of TÜV NORD Group
TÜV NORD 集团成员之一

5th floor, No.50, Jiu Huan Road,
Hangzhou City, Zhejiang Province, 310019, P.R. China
中国浙江省杭州市九环路 50 号 5 楼

Tel / 电话:
+86 (0)571 85386989
Fax / 传真:
+86 (0)571 85386986

Website / 网站:
www.tuv-nord.com
www.tuv-nord.com/cn
www.tuev-nord-cert.de

CERTIFICATE

TÜV NORD CERT GmbH

herewith declares that

Jiangsu Jinghua New Energy Operation Management Co., Ltd.
No.88, Wenchang East Road, Jiangdu District
Yangzhou City
P.R. China

is authorized to provide the product mentioned below with the mark as illustrated:

Description of product (details see Annex 2):

PV Modules with 6" Mono-crystalline Silicon Solar Cells

PV Modules with 6" Half-cut Mono-crystalline Silicon Solar Cells



Valid from: 2020-11-16

Valid until: 2025-09-21

Tested according to: IEC / EN 61215-1:2016;
IEC / EN 61215-1-1:2016;
IEC 61215-2:2016 / EN 61215-2:2017 + AC:2017 + AC:2018;
IEC 61730-1:2016 / EN IEC 61730-1:2018 + AC:2018;
IEC 61730-2:2016 / EN IEC 61730-2:2018 + AC:2018.

Registered No.: 44 780 20 406749 - 181M1

Manufacturer: see Annex 1

Test Report No.: 492011512.002

File No.: PVP07069/20P-01

A handwritten signature in purple ink.

TÜV NORD CERT GmbH
Certification Body
Consumer Products



Essen, 2020-11-16

Please also pay attention to the information stated overleaf.

Anlage 1 zum Zertifikat Nr.: / Annex 1 to Certificate No.: **44 780 20 406749 - 181M1**

Seite / Page **1** von / of **1**

Aktenzeichen: / File reference: **PVP07069/20P-01**

2020-11-16

Manufacturer:

Manufacturer: **YANGZHOU JINGHUA New Energy Technology Co., Ltd.**
No. 1 Weili Road, Xiancheng Industrial Park, Jiangdu District
Yangzhou City, Jiangsu Province, P.R. China

Factory inspection report no.: **862010511.001**

Remark:

Factory inspection is mandatory to be performed annually. Please refer to factory inspection report for detailed information.



TÜV NORD CERT GmbH
Certification Body
Consumer Products

Description of product(s):

Module types:	PV Modules with 6" Mono-crystalline Silicon Solar Cells: 72 cells: JHM6/72Hxxx (xxx = 375-385, in increment of 5) 60 cells: JHM6/60Hxxx (xxx = 315-320, in increment of 5)
Maximum system voltage:	1500V
Fuse rating:	20A
Electrical protection class:	Class II
Pollution degree:	1
Material group:	I
Design load (positive / negative):	3600Pa / 1600Pa
Safety factors:	1.5
Fire safety class:	Class C according to ANSI/UL 1703-2018 (as per ANSI/UL 790-2018)

Module types:	PV Modules with 6" Half-cut Mono-crystalline Silicon Solar Cells: 144 cells: JHM3/72Hxxx (xxx = 380-415, in increment of 5) 120 cells: JHM3/60Hxxx (xxx = 315-345, in increment of 5) 144 cells: JHM4/72Hxxx (xxx = 425-465, in increment of 5) 120 cells: JHM4/60Hxxx (xxx = 355-385, in increment of 5)
Maximum system voltage:	1500V
Fuse rating:	20A
Electrical protection class:	Class II
Pollution degree:	1
Material group:	I
Design load (positive / negative):	3600Pa / 1600Pa
Safety factors:	1.5
Fire safety class:	Class C according to ANSI/UL 1703-2018 (as per ANSI/UL 790-2018)

Remark:

For detailed product information, please refer to CDF (Constructional Data Form) in Annex 1 of test report.



TÜV NORD CERT GmbH
Certification Body
Consumer Products