



## Certificate of conformity

001/006925

AENOR certifies that the organization

### FORMÜL PLASTIK VE METAL SANAYI A.S.

Registered office CUMHURİYET MAT., GURPINAR YOLU CAD. KAYA MİLENYUM İS MERKEZİ  
SIT., CARSI APT KAT 8, N° 5A/144, B CEKMECE-İSTANBUL (Turquía)

Supplies **Polypropylene pipes (PP-R) / polypropylene glass fiber (PP-R FV) / polypropylene (PP-R) for installation of hot and cold water inside the building structure**

In compliance with TECHNICAL SPECIFICATION TO RP 01.72

Description Trademark: FORMÜL  
Fiberglass content: 5%  
Fiberglass content of the middle layer: 17%

See annex for more information.

Production site VELİKÖY OSB MAH. SANAYI BULVARI, No. 19/4A VELİKÖY ÇERKEZKÖY  
(Tekirdag - Turquía)

Certification scheme In order to grant this Certificate, AENOR has tested the product and has verified the quality system implemented for its manufacture. AENOR performs these tasks periodically while the Certificate has not been cancelled, in accordance with Specific Rules RP 01.72.

First issued on 2019-04-22

Last issued on 2024-04-22

Validity 2029-04-22

Rafael GARCÍA MEIRO  
CEO



## Certificate of conformity

001/006925

### Annex to Certificate

DESCRIPTION Trademark: FORMÜL  
Fiberglass content: 5%  
Fiberglass content of the middle layer: 17%

SERIE	DIAMETERS (mm)	APPLICATION CLASS / DESIGN PRESSURE (bar)	OPACITY
2,5	20 - 25 - 32 - 40 - 50 - 63 - 75 - 90 - 110	1/10; 2/8; 4/10; 5/6	NO
3,2	20 - 25 - 32 - 40 - 50 - 63 - 75 - 90 - 110	1/8; 2/6; 4/10; 5/6	NO

First issued on 2019-04-22  
Last issued on 2024-04-22  
Validity 2029-04-22

