

23.07.2024

As EMTAŞ, our boilers are tested with 4,5 bar pressure after the production is finished, the recommended working pressure is between 1,5-4 bar.

PRODUCT AND QUALIYT MANAGER

**emtaş**<sup>®</sup>  
Panel Radyatör ve Isı San. Tic. Ltd. Şti.  
Tic. Sic. No: 4181 - Oda Sicil No: 527  
Eğirdir Yolu 4. Km. - İSPARTA  
Tel.: (0246) 224 13 53 - Fax: 224 19 70  
E-Posta: info@emtasenerji.com