

**CERT**

DVGW type examination certificate

DVGW-Baumusterprüfzertifikat

DW-8143CP0420Registration Number
Registriernummer**Field of Application**
*Anwendungsbereich*products of water supply
*Produkte der Wasserversorgung***Owner of Certificate**
*Zertifikatinhaber*Peštan d.o.o.
1300 Kaplara 189, RS-34301 Bukovik**Distributor**
*Vertreiber*Peštan d.o.o.
1300 Kaplara 189, RS-34301 Bukovik**Product Category**
Produktart

plastic pressure tubes for supply pipelines: PE-HD pipe with integrated layers for water supply, manufacturing group 15 (8143)

Product Description
Produktbezeichnung

PE-HD pipe with integrated layers for water supply

Model
Modell

PE100RC pipe

Test Reports
*Prüfberichte*laboratory control test: K 19 1497.7 from 28.01.2020 (MPD)
type testing: K 13 1995.3+K 13 1995.4 from 17.09.2014 (MPD)
KTW testing: KR 088/19 from 01.07.2019 (TZW)
hygienic testing: MO 112/17 from 16.10.2017 (TZW)**Test Basis**
*Prüfgrundlagen*DVGW GW 335-A2 (01.11.2005)
DVGW GW 335-A2/B1 (01.12.2010)
UBA KTW (07.03.2016)
DVGW W 270 (01.11.2007)**Date of Expiry / File No.** 17.09.2024 / 20-0135-WNV
Ablaufdatum / Aktenzeichen

18.03.2020 LE A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to DIN EN ISO/IEC 17065:2013 for certification of products for energy and water supply industry.

DVGW CERT GmbH ist von der DAkkS nach DIN EN ISO/IEC 17065:2013 akkreditierte Stelle für die Zertifizierung von Produkten der Energie- und Wasserversorgung.

Deutsche
Akkreditierungsstelle
D-ZE-16028-01-05DVGW CERT GmbH
ZertifizierungsstelleJosef-Wirmer-Str. 1-3
53123 BonnTel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993www.dvgw-cert.com
info@dvgw-cert.com

Type	Technical Data	Remarks
Typ	Technische Daten	Bemerkungen
PE100RC pipe	manufacturing group: 15	diameters: 75 up to 225 mm