



Product Service

# Attestation of Conformity

No. N8A 118443 0002 Rev. 09

**Holder of Attestation:** **Jinko Solar Co., Ltd.**  
No.1, Yingbin Road, Economic Development Zone  
334100 Shangrao City, Jiangxi  
PEOPLE'S REPUBLIC OF CHINA

**Product:** **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**  
**Mono-Crystalline Silicon Photovoltaic Module**

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for conformity assessment. For details see: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert)

**Test report no.:** 704062217002-16

**Date,** 2024-01-22

( Zhulin Zhang )

Page 1 of 3

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.

**TUV®**



Product Service

# Attestation of Conformity

No. N8A 118443 0002 Rev. 09

## Model(s):

JKxxxM-66R5-BGV (xxx=630-665, in steps of 5, 132 cells)  
 JKxxxM-66H5-BGV (xxx=635-670, in steps of 5, 132 cells)  
 JKMxxxN-78HL4-BDV, JKMxxxN-78HL4R-BDV, JKMxxxN-78HL4-BDV-J  
 (xxx=570-645, in steps of 5, 156 cells)  
 JKMxxxN-72HL4-BDV, JKMxxxN-72HL4-BDV-J, JKMxxxN-72HL4-BDV-U  
 JKMxxxN-72HL4R-BDV (xxx=480-610, in steps of 5, 144 cells)  
 JKMxxxN-66HL4-BDV (xxx=440-520, in steps of 5, 132 cells)  
 JKMxxxN-60HL4-BDV (xxx=400-505, in steps of 5, 120 cells)  
 JKMxxxN-60HL4R-BDV (xxx=400-505, in steps of 5, 120 cells)  
 JKMxxxN-54HL4-BDV (xxx=360-455, in steps of 5, 108 cells)  
 JKMxxxN-54HL4R-BDV (xxx=360-455, in steps of 5, 108 cells)  
 JKMxxxN-54HL4R-BDB (xxx=360-455, in steps of 5, 108 cells)  
 JKMxxxN-7RL4-BDV, JKMxxxN-7RL4-BDV-J  
 (xxx=535-595, in steps of 5, 156 cells)  
 JKMxxxN-7TL4-BDV, JKMxxxN-7TL4-BDV-J, JKMxxxN-7TL4R-BDV (xxx=495-  
 590, in steps of 5, 144 cells)  
 JKMxxxN-6RL4-BDV (xxx=455-500, in steps of 5, 132 cells)  
 JKMxxxN-6TL4-BDV (xxx=415-455, in steps of 5, 120 cells)  
 JKMxxxN-5RL4-BDV (xxx=375-410, in steps of 5, 108 cells)  
 JKMxxxM-72H-DV (xxx=390-415, in steps of 5, 144 cells)  
 JKMxxxM-60H-DV (xxx=325-345, in steps of 5, 120 cells)  
 JKMxxxM-7RL4-BDVP, JKMxxxM-7RL4-BDVP-J  
 (xxx=535-595, in steps of 5, 156 cells)  
 JKMxxxM-72HL4-BDVP, JKMxxxM-72HL4-BDVP-J  
 (xxx=500-575, in steps of 5, 144 cells)  
 JKMxxxM-66HL4-BDVP (xxx=460-500, in steps of 5, 132 cells)  
 JKMxxxM-60HL4-BDVP (xxx=420-455, in steps of 5, 120 cells)  
 JKMxxxM-54HL4-BDVP (xxx=375-410, in steps of 5, 108 cells)  
 JKMxxxM-7TL4-BDVP, JKMxxxM-7TL4-BDVP-J  
 (xxx=500-565, in steps of 5, 144 cells)  
 JKMxxxM-6RL4-BDVP (xxx=460-500, in steps of 5, 132 cells)  
 JKMxxxM-6TL4-BDVP (xxx=420-455, in steps of 5, 120 cells)  
 JKMxxxM-5RL4-BDVP (xxx=375-410, in steps of 5, 108 cells)  
 JKMxxxM-72HL-BDV (xxx=390-410, in steps of 5, 144 cells)  
 JKMxxxM-72H-BDV (xxx=390-410, in steps of 5, 144 cells)  
 JKMxxxM-60HL-BDV (xxx=325-340, in steps of 5, 120 cells)  
 JKMxxxM-60H-BDV (xxx=325-340, in steps of 5, 120 cells)  
 JKMxxxN-72H-MBB-BDV (xxx=390-415, in steps of 5, 144 cells)  
 JKMxxxN-60H-MBB-BDV (xxx=330-345, in steps of 5, 120 cells)  
 JKMxxxM-72HL-BDVP (xxx=375-430, in steps of 5, 144 cells)  
 JKMxxxM-72H-BDVP (xxx=375-430, in steps of 5, 144 cells)  
 JKMxxxM-60HL-BDVP (xxx=310-355, in steps of 5, 120 cells)  
 JKMxxxM-60H-BDVP (xxx=310-355, in steps of 5, 120 cells)  
 JKMxxxM-72H-MBB-BDVP (xxx=380-415, in steps of 5, 144 cells)  
 JKMxxxM-60H-MBB-BDVP (xxx=315-345, in steps of 5, 120 cells)  
 JKSN3-DDCA-xxx (xxx=405-435, in steps of 5, 156 cells)  
 JKSN3-CDCA-xxx (xxx=345-365, in steps of 5, 132 cells)  
 JKSM3-DDCA-xxx (xxx=405-430, in steps of 5, 156 cells)  
 JKSM3-CDCA-xxx (xxx=345-360, in steps of 5, 132 cells)  
 JKMxxxN-78H-BDV (xxx=415-460, in steps of 5, 156 cells)  
 JKMxxxN-66H-BDV (xxx=350-385, in steps of 5, 132 cells)  
 JKMxxxN-7RL3-BDV (xxx=440-490, in steps of 5, 156 cells)  
 JKMxxxN-7RL3-BDV-J (xxx=440-490, in steps of 5, 156 cells)  
 JKMxxxN-6RL3-BDV (xxx=375-410, in steps of 5, 132 cells)  
 JKMxxxM-78H-BDVP (xxx=415-455, in steps of 5, 156 cells)  
 JKMxxxM-66H-BDVP (xxx=350-385, in steps of 5, 132 cells)  
 JKMxxxM-7RL3-BDVP, JKMxxxM-7RL3-BDVP-J  
 (xxx=440-465, in steps of 5, 156 cells)  
 JKMxxxM-6RL3-BDVP, JKMxxxM-6RL3-BDVP-J  
 (xxx=375-390, in steps of 5, 132 cells)  
 JKMxxxM-78HL3-BDVP, JKMxxxM-78HL3-MBB-BDVP

Page 2 of 3

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.





Product Service

# Attestation of Conformity

No. N8A 118443 0002 Rev. 09

(xxx=450-480, in steps of 5, 156 cells)  
 JK MxxxM-66HL3-BDVP, JK MxxxM-66HL3-MBB-BDVP  
 (xxx=380-405, in steps of 5, 132 cells)  
 JK MxxxM-72HLM-BDVP (xxx=415-460, in steps of 5, 144 cells)  
 JK MxxxM-60HLM-BDVP (xxx=345-380, in steps of 5, 120 cells)  
 JK MxxxM-72L-BDV (xxx=375-405, in steps of 5, 72 cells)  
 JK MxxxM-72-BDV (xxx=375-405, in steps of 5, 72 cells)  
 JK MxxxM-60L-BDV (xxx=310-335, in steps of 5, 60 cells)  
 JK MxxxM-60-BDV (xxx=310-335, in steps of 5, 60 cells)  
 JK MxxxM-72L-BDVP (xxx=370-410, in steps of 5, 72 cells)  
 JK MxxxM-72-BDVP (xxx=370-410, in steps of 5, 72 cells)  
 JK MxxxM-60L-BDVP (xxx=305-340, in steps of 5, 60 cells)  
 JK MxxxM-60-BDVP (xxx=305-340, in steps of 5, 60 cells)  
 JK MxxxM-72-DV (xxx=385-405, in steps of 5, 72 cells)  
 JK MxxxM-78HL4-BDVP (xxx=570-595, in steps of 5, 156 cells)  
 JKBSxxxN-48HL4-BDV (xxx=330-380, in steps of 5, 96 cells)  
 JKBSxxxN-22.5HL4-BDV (xxx=155-180, in steps of 5, 45 cells)  
 JKBSxxxM-48HL4-BDVP (xxx=335-375, in steps of 5, 96 cells)  
 JKBSxxxM-22.5HL4-BDVP (xxx=160-175, in steps of 5, 45 cells)  
 JK MxxxN-60HL4-MDV (xxx=450-505, in steps of 5, 120 cells)  
 JK MxxxN-60HL4R-MDV (xxx=450-505, in steps of 5, 120 cells)  
 JK MxxxN-54HL4-MDV (xxx=405-450, in steps of 5, 108 cells)  
 JK MxxxN-54HL4R-MDV (xxx=405-450, in steps of 5, 108 cells)  
 JKxxxN-66H5-BGV (xxx=625-710, in steps of 5, 132 cells)  
 JK MxxxN-66HL5-BDV (xxx=625-710, in steps of 5, 132 cells)  
 JK MxxxM-60HL4-MDVP (xxx=450-465, in steps of 5, 120 cells)  
 JK MxxxM-54HL4-MDVP (xxx=405-415, in steps of 5, 108 cells)  
 JK MxxxM-5RL4-MDVP (xxx=405-415, in steps of 5, 108 cells)  
 JK MxxxN-5RL4-MDV (xxx=420-430, in steps of 5, 108 cells)  
 JK MxxxN-72HL4U-BDV (xxx=590-610, in steps of 5, 144 cells)  
 JK MxxxN-66HL4M-BDV (xxx=590-620, in steps of 5, 132 cells)  
 JKBSxxxN-48HL4-BDVW, (xxx=370-395, in steps of 5, 96 cells)  
 xxx is standing for rated output power at STC

## Parameters:

Fire Safety Class: Class C according to UL790.  
 Safety Class: Class II  
 Max. System Voltage: 1500V DC  
 Construction: Framed or frameless, double glass with Junction box, cable and connector.

## Tested according to:

EN IEC 61730-1:2018  
 EN IEC 61730-1:2018/AC:2018-06  
 EN IEC 61730-2:2018  
 EN IEC 61730-2:2018/AC:2018-06

Page 3 of 3

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.

