



2272821.52

**Degree of protection provided by enclosures  
against external mechanical impacts, acc. IK10  
requirements on Blackbird Series Luminaires**

Arnhem, February 15, 2023

Author: R.D. Mindiola Romero  
DEKRA Certification B.V.

On request of:

SIA VIZULO  
Bukultu str. 11  
LV-1005 Riga  
Latvia

---

Author : R.D. Mindiola Romero

9 pages 0 annexes

© DEKRA Certification B.V., Arnhem, the Netherlands. All rights reserved.

It is prohibited to change any and all versions of this document in any manner whatsoever, including but not limited to dividing it into parts. In case of a conflict between the electronic version (e.g. PDF file) and the original paper version provided by DEKRA, the latter will prevail.

DEKRA Certification B.V. and/or its associated companies disclaim liability for any direct, indirect, consequential or incidental damages that may result from the use of the information or data, or from the inability to use the information or data contained in this document.

The contents of this report may only be transmitted to third parties in its entirety and provided with the copyright notice, prohibition to change, electronic versions' validity notice and disclaimer.

## TABLE OF CONTENTS

	page
TABLE OF CONTENTS .....	3
1 INTRODUCTION.....	4
2 TESTED PRODUCT AND TEST DESCRIPTION.....	5
3 RESULTS/CONCLUSION.....	9

## 1 INTRODUCTION

On request of SIA VIZULO, Riga, Latvia, an IK10 test was conducted on different housing parts of a representative model of the Blackbird series, street- and floodlight luminaires.


All the series of luminaire were tested for IK10.

**Test results in this test report are representative for all models in Blackbird product family**

The requirements as well as the method of testing and test equipment of the IK10 test are described in EN 62262:2002 and IEC/TR 62696:2011 standards and as detailed on the following pages.

## 2 TESTED PRODUCT AND TEST DESCRIPTION

### Product overview



Figs. 1 and 2 – Front side and bottom side of Blackbird toolless model BBAT 085 730 L01  
AB048 CB NG1



Figs. 3 and 4 – Front side and top side of Blackbird suspended mounted, model BBA 100 730 L05 BL024 CS NG1

The luminaire was supported by a wooden surface and subjected by 5 single impacts on the following luminaire parts:

- Aluminum housing (weakest spot)
- Glass cover

Three single impacts shall be conducted on the same location. The other two single impacts may be on a different location on the subjected surface/area.

The wire mounted (suspended mounted) luminaire was tested also with IK08. Details shown below.

#### 4.2 Characteristic group numerals of the IK code and their meanings

Each characteristic group numeral represents an impact energy value as shown in table 1.

**Table 1 – Relation between IK code and impact energy**

IK code	IK00	IK01	IK02	IK03	IK04	IK05	IK06	IK07	IK08	IK09	IK10
Impact energy, J	*	0,14	0,2	0,35	0,5	0,7	1	2	5	10	20
* Not protected according to this standard.											
NOTE 1 When higher impact energy is required, the value of 50 J is recommended.											
NOTE 2 A characteristic group numeral of two figures has been chosen to avoid confusion with some national standards which used a single numeral for a specific impact energy.											

#### 5.2 Height of fall

To produce impacts of the required severity, the striking element shall be released from a height depending on the equivalent mass of the pendulum, according to Table 2.

**Table 2 – Height of fall**

Energy J	0,14	0,2	(0,3)	0,35	(0,4)	0,5	0,7	1	2	5	10	20	50		
Equivalent mass kg	0,25	(0,2)	0,25	(0,2)	0,25	(0,2)	(0,2)	0,25	0,25	0,25	0,5	1,7	5	10	
Height of fall mm ± 1 %	56	(100)	80	(150)	140	(200)	(250)	200	280	400	400	300	200	400	500
NOTE 1 Figures in brackets appear in previous IEC 60068-2 standards; although no longer recommended, they may be used for historic consistency.															
NOTE 2 In this part of IEC 60068, the energy, J, is calculated taking the standard acceleration due to the earth's gravity ( $g_n$ ), rounded up to the nearest whole number, that is 10 m/s <sup>2</sup> .															

**Pass criteria:**

After the test, the enclosure shall show no cracks or deformation and shall not affect the normal function of the equipment, reduce the insulation and/or creepage distances or reduce the specified degree of protection against access to hazardous parts below the permitted values. Superficial damage, such as removal of paint, breaking of cooling ribs or of similar parts, or depression of small dimensions can be ignored.



### 3 RESULTS/CONCLUSION

After the test there was no damage or deformation visible on the enclosure and the glass cover of the Blackbird series Street Luminaire. The degree of protection and the integrity of the enclosure was still intact.

The product passed the test and complies with the specified requirements for IK10.

Test conducted by:

A handwritten signature in blue ink, appearing to read 'A Pomp', with a large, stylized flourish at the end.

A Pomp

Reviewed by:

A handwritten signature in blue ink, appearing to read 'L.H.N Huynh', with a long horizontal stroke extending to the left.

L.H.N Huynh

**END OF EXAMINATION REPORT**