

CERTIFICATE OF COMPLIANCE

Certificate Number 20160218-E477638
Report Reference E477638-20160218
Issue Date 2016-FEBRUARY-18

Issued to: Ardic Elektrik San Ve Tic Ltd Sti
Evren Mah Bahar Cad No 2
Polat Is Merkezi, K:3 D.8
Gunesli, Bagcilar
Istanbul TURKEY

**This is to certify that
representative samples of** CABLE TRAYS
See Addendum Page

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: NEMA VE 1-2009, Metal Cable Tray Systems.
UL 5, Surface Metal Raceways and Fittings.

Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20160218-E477638
Report Reference E477638-20160218
Issue Date 2016-FEBRUARY-18

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.


Products Covered:

Trough Type Series A with suffixes and optional suffix ED, and fittings consisting of 90° bends, tees, crosses, 45° bends, reducing couplings, angle couplings, straight couplings, adjustable inside/outside vertical bends, stationary inside/outside vertical bends, dividers, end caps.

Ladder Type Series A with suffixes, and fittings consisting of 90° horizontal bends, tees, crosses, 45° bends, level change, straight couplings, reducing couplings.

Embossed Type Series AMF with suffixes, and fittings consisting of 90° bends, tees, crosses, adjustable inside/outside vertical bends, covers.

Trough and Ladder Covers.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>





Harun Kartal
 Ardıc Elektrik San Ve Tic Ltd Sti
 Kapakli OSB Mahallesi 103
 Cadde No 23
 Kapakli Tekirdag
 Istanbul TURKEY

Date: 2017/11/03
 Subscriber: None
 PartySite: 1396292
 File No: E477638
 Project No: 17SR4393390
 PD No: 17M42499
 Type: R
 PO Number:

Subject: **Procedure And/Or Report Material**

The following material resulting from the investigation under the above numbers is enclosed.

Issue

<u>Date</u>	<u>Vol</u>	<u>Sec</u>	<u>Pages</u>	<u>Revised Date</u>
2016/02/18	1	1	Revised Description Page(s) 1	2017/11/03
2016/02/18	1		New Test Record 2	2017/11/03

MARIUSZ PYRCIK, FIELD SERVICE AREA MANAGER,UL INSPECTION CENTER TURKEY, UL INTERNATIONAL POLSKA SP Z
 O O,ALEJA KRAKOWSKA 81, SEKOCIN NOWY, K WARSZAWY, Poland, 05-090.,PHONE: 48.509.855.437, FAX:
 48.22.336.33.01, EMAIL: Mariusz.Pyrcik@ul.com

Please file revised pages and illustrations in place of material of like identity. New material should be filed in its proper numerical order.

NOTE: Follow-Up Service Procedure revisions DO NOT include Cover Pages, Test Records and Conclusion Pages. Report revisions DO NOT include Authorization Pages, Indices, Section General Pages and Appendixes.

Please review this material and report any inaccuracies to UL's Customer Service Professionals. Contact information for all of UL's global offices can be found at <http://ul.com/aboutul/locations>.

If you'd like to receive updated materials FASTER, UL offers electronic access and/or delivery of this material. For more details, contact UL's Customer Service Professionals as shown above.

This material is provided on behalf of UL LLC (UL) or any authorized licensee of UL.

MEL File

UL INSPECTION CENTER 353

DESCRIPTION

PRODUCT COVERED:

USC - Cable Trays, Trough Type Series A with suffixes and optional suffix ED, and fittings consisting of 90° bends, tees, crosses, 45° bends, reducing couplings, angle couplings, straight couplings, adjustable inside/outside vertical bends, stationary inside/outside vertical bends, dividers, end caps.

USC - Cable Trays, Ladder Type Series A with suffixes, and fittings consisting of 90° horizontal bends, tees, crosses, 45° bends, level change, straight couplings, reducing couplings.

USC - Cable Trays, Embossed Type Series AMF with suffixes, and fittings consisting of 90° bends, tees, crosses, adjustable inside/outside vertical bends, covers.

USC - Cable Tray, Trough and Ladder Covers.

GENERAL:

These are zinc galvanized steel cable trays.

ENGINEERING CONSIDERATIONS:

Cable Trays are intended for assembly in the field and for use in accordance with the National Electrical Code.

* USC - Indicates **the products have been investigated to determine their suitability for use as an equipment grounding conductor in accordance with sections 392.60(A) and 392.60(B) of NFPA 70 National Electric Code with AMD 1-5 Edition 2017 - Revision date 2017-07-18 and NEMA VE1 Metal Cable Tray Systems, Edition 6, dated 2017-07-14..**

DESCRIPTION

PRODUCT COVERED:

USC - Cable Trays, Trough Type Series A with suffixes and optional suffix ED, and fittings consisting of 90° bends, tees, crosses, 45° bends, reducing couplings, angle couplings, straight couplings, adjustable inside/outside vertical bends, stationary inside/outside vertical bends, dividers, end caps.

USC - Cable Trays, Ladder Type Series A with suffixes, and fittings consisting of 90° horizontal bends, tees, crosses, 45° bends, level change, straight couplings, reducing couplings.

USC - Cable Trays, Embossed Type Series AMF with suffixes, and fittings consisting of 90° bends, tees, crosses, adjustable inside/outside vertical bends, covers.

USC - Cable Tray, Trough and Ladder Covers.

GENERAL:

These are zinc galvanized steel cable trays.

ENGINEERING CONSIDERATIONS:

Cable Trays are intended for assembly in the field and for use in accordance with the National Electrical Code.

* USC - Indicates **the products have been investigated to determine their suitability for use as an equipment grounding conductor in accordance with sections 392.60(A) and 392.60(B) of NFPA 70 National Electric Code with AMD 1-5 Edition 2017 - Revision date 2017-07-18 and NEMA VE1 Metal Cable Tray Systems, Edition 6, dated 2017-07-14..**

TEST RECORD NO. 2

SAMPLES:

Samples of the cable trays Series A Trough and Ladder Types and Series AMF Embossed Type, constructed as described herein, were submitted by the manufacturer for examination and test.

GENERAL:

As a result of an Informal File Review the Products have been investigated to determine their suitability for use as an equipment grounding conductor in accordance with sections 392.60(A) and 392.60(B) of NFPA 70 National Electric Code with AMD 1-5 Edition 2017 - Revision date 2017-07-18 and test requirement in NEMA VE1 Metal Cable Tray systems - Edition 6 - Issued 2017-07-14.

Test Record Summary:

The results of this investigation indicate that the products evaluated comply with the applicable requirements in NFPA 70 National Electric Code with AMD 1 - 5 Edition 2017 - Revision Date 2017/07/18 and NEMA VE1 Metal Cable Tray Systems-Edition 6-Issue date 2017/07/14, and therefore, such products are judged eligible to bear UL's Mark as described on the Conclusion Page of this Report.

Test Record by:

Reviewed by:

Bonnie Bennett

Hopeton Wright

Staff Engineering Associate

Staff Engineer

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL.