



# EU Declaration of Conformity



No: RMD 1045 Rev. 0

We,

**Rosemount, Inc.**  
**6021 Innovation Boulevard**  
**Shakopee, MN 55379-4676**  
**USA**

declare under our sole responsibility that the product,


**Rosemount™ 3144P Temperature Transmitter**

manufactured by,

**Rosemount, Inc.**  
**6021 Innovation Boulevard**  
**Shakopee, MN 55379-4676**  
**USA**

to which this declaration relates, is in conformity with the provisions of the European Union Directives, including the latest amendments, as shown in the attached schedule.

Assumption of conformity is based on the application of the harmonized standards and, when applicable or required, a European Union notified body certification, as shown in the attached schedule.

  
\_\_\_\_\_  
(signature)

Mark Lee  
\_\_\_\_\_  
(name)

Vice President of Global Quality  
\_\_\_\_\_  
(function)

August 27, 2021  
\_\_\_\_\_  
(date of issue)



# EU Declaration of Conformity

No: RMD 1045 Rev. 0



## EMC Directive (2014/30/EU)

Harmonized Standards: EN61326-1:2013, EN61326-2-3: 2013

## ATEX Directive (2014/34/EU)

### Rosemount 3144P Temperature Transmitter (4-20mA/HART Output)

#### **BAS01ATEX1431X – Intrinsic Safety Certificate**

Equipment Group II, Category 1 G (Ex ia IIC T5/T6 Ga)

Harmonized Standards:

EN IEC 60079-0:2018, EN60079-11:2012

#### **BAS01ATEX3432X – Type n Certificate**

Equipment Group II, Category 3 G (Ex nA IIC T5/T6 Gc)

Harmonized Standards:

EN IEC 60079-0:2018, EN60079-15:2010

### Rosemount 3144P Temperature Transmitter (Fieldbus Output)

#### **Baseefa03ATEX0708X – Intrinsic Safety Certificate**

Equipment Group II, Category 1 G (Ex ia IIC T4 Ga)

Harmonized Standards:

EN IEC 60079-0:2018, EN60079-11:2012

#### **Baseefa03ATEX0709 – Type n Certificate**

Equipment Group II, Category 3 G (Ex nA IIC T5 Gc)

Harmonized Standards:

EN IEC 60079-0:2018, EN60079-15:2010



# EU Declaration of Conformity

No: RMD 1045 Rev. 0



## Rosemount 3144P Temperature Transmitter (all Output Protocols)

### DEKRA 19ATEX0076 X – Dust Certificate

Equipment Group II, Category 2 D (Ex tb IIIC T130°C Db)

Harmonized Standards:

EN IEC 60079-0:2018, EN 60079-31:2014

### DEKRA 19ATEX0076 X – Flameproof Certificate

Equipment Group II, Category 2 G (Ex db IIC T6...T1 Gb)

Harmonized Standards:

EN IEC 60079-0:2018, EN 60079-1:2014

## ATEX Notified Bodies

### SGS FIMKO OY [Notified Body Number: 0598]

Takomotie 8  
00380 HELSINKI  
Finland

### FM Approvals Europe Limited [Notified Body Number: 2809]

One Georges Quay Plaza  
Dublin, Ireland. D02 E440

## ATEX Notified Body for Quality Assurance

### SGS FIMKO OY [Notified Body Number: 0598]

Takomotie 8  
00380 HELSINKI  
Finland