

Reg.no.: ME000161392(01)

List of clarifications and deviations

For transformer 25 / 25 / 25 MVA, 115 / 38,5 / 11 kV

1. TECHNICAL REQUIREMENTS for 110/35/10 kV 25 MVA POWER TRANSFORMER
CHANGE (technical requirements. power transformer.pdf)

- Text part of document (page 1 - 55) vs TECHNICAL DATA SHEET (page 55 - 63). These two parts of this document have different values for same parameters, there are not united.

ETD offer:

For the contract purposes will be ETD guaranteed only parameters applied in the point 8. TECHNICAL DATA SHEET, of this document and set of standards IEC

25. 5. 2023

Elaborated by: Ing. Vild