



**Tarkett AB**  
**Report No. TA 1304-646**

# Cleanroom<sup>®</sup> Suitable Materials

**iQ Toro SC**  
**Particle (vs. PA6): ISO 3**

## Flooring & Coating

### Qualification Certificate

We hereby certify that the material stated above, provided by

**Tarkett AB**  
Ronneby, Sweden

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number TA 1304-646.

iQ Toro SC (color 100) was tested regarding particle emission during the application of frictional stress according to VDI 2083-17. The tested material obtained the following classification:

Material pairing and test		Suitable for Air Cleanliness Class (ISO 14644-1)
iQ Toro SC; color 100	vs. PA6	ISO Class: 3
Reel-on-disc test Normal force 300 N		

Detailed information regarding specific product data such as date of manufacture, color, and serial number as well as test environment and parameters can be obtained from the CSM test report issued by the Fraunhofer-Gesellschaft.

Stuttgart, June 26, 2013

i. A.  
Project manager

The validity of this certificate is temporary indefinite and limited to the named product. It can be verified on [www.tested-device.com](http://www.tested-device.com).

For more CSM information, please visit [www.ipa-csm.com](http://www.ipa-csm.com).

DUPLICATE