



**LABORATOR DE ANALIZE SI INCERCARI IN ACTIVITATEA DE  
CONSTRUCTII - AXA CERT S.R.L.**

*Autorizat ISC sub nr. 3782/21*

Ferestre, usi, fatade cortina, EVI-uri, geam securizat, geam laminat,  
termosistem ETICS, reactie la foc



**Anexa 2 la certificatul nr. 3067-CPF -22**

**FERESTRE SI USI EXTERIOARE PENTRU PIETONI sistem WDS seria 7S** (ferestre si usi de exterior fabricate din profile de PVC, compuse din unul, doua sau mai multe canate compartimentate prin montanti fiksi si/sau mobili echipate cu geam termoizolant) -vezi DoP 002/2022

Caracteristici de performanță	Clasă performanță	Rapoarte/ Autoritate emitenta/	Standarde de incercare/clasificare
Rezistenta la incarcare din vant	<b>C4</b>	3054/2022-AXA CERT	SR EN 12211:2016 SR EN 12210:2016
Etansietate la apa - neprotejata	<b>9A</b>	3054/2022-AXA CERT	SR EN 1027:2016 SR EN 12208:2001
Permeabilitate la aer	<b>4</b>	3054/2022-AXA CERT	SR EN 1026:2016 SR EN 12207:2016
Performanta acustica* Rw (C ;Ctr)	<b>32 dB (-1 ; -5)</b>	Determinare/ SR EN 14351-1+A2:2016	Determinare/ SR EN 14351-1+A2:2016 SR EN ISO 140-3:1998 SR EN ISO 717-1:2000 SR EN ISO 717-1:2000
Transmitanta termica*	<b>1,3 W/m²K</b>	Determinare/ SR EN 14351-1+A2:2016	Determinare/ SR EN 10077-1:2018 SR EN ISO 12567-1:2011/AC:2011

\*Functie de geamul termoizolant folosit

Autoritate emitenta: AXA CERT SRL (Laborator Grad I), Tancabesti, jud. Ilfov,  
Autorizatie ISC nr. 3782/21

**Data emiterii**  
**19.09.2022**

**DIRECTOR,**

**Aud. Mincu Eduard**

