



SCOPE OF ACCREDITATION TO ISO/IEC 17025:2017

NOJA POWER SWITCHGEAR PTY LTD.
16 Archimedes Pl
Murarrie, QLD, 4172
Brisbane, Australia
Samuel Griffiths (Authorized Rep) Phone: +617 3907 8777
Email: SamG@nojapower.com.au

ELECTRICAL

Valid To: January 31, 2027

Certificate Number: 6056.01

In recognition of the successful completion of the A2LA evaluation process, accreditation is granted to this laboratory for the following electrical and mechanical tests:

Test Type/Technology:

Test Methods¹:

Dielectric²

Power Frequency voltage

Up to 200 kV, 200 mA, 50/60 Hz

IEC 60060-1; IEC 62271-1;
IEC 62271-100, -103, -111; IEC 60137;
IEC 61869-1, -3

Lightning Impulse voltage

600 kV, 60 kJ

IEC 60060-1; IEC 62271-1;
IEC 62271-100, -103, -111; IEC 61869-1;
IEC 60137

Partial Discharge

(1–100) pC

IEC 60270; IEC 62271-1;
IEC 62271-111; IEC 60137; IEC 61869-1

Contact Resistance Measurement²

(100–1000) $\mu\Omega$ at 1A

(50–500) $\mu\Omega$ at 10A

(50–500) $\mu\Omega$ at 100

IEC 62271-1;
IEC 62271-100, -103, -111

Minimum Tripping Current

IEC 62271-111

Over/Under Current Protection

IEC 60255-151

Over/Under Voltage Protection

IEC 60255-127

Frequency Protection

IEC 60255-181

Controller Characteristics

NOJA-3327

Measuring / Protection Injection Testing²

Voltage Testing - (0 – 300) V NOJA-3331
 Current Testing - (0 – 30) A
 Phase Angle Testing - (0 – 360) °
 Frequency Testing - (0 – 10) kHz

Simulated Surge Arrestor Operation²

Up to 7kA, 160kV IEC 62271-111

Time-Current Tests

Up to 16 kA IEC 62271-111

Protocol Testing

IEC 61850 Ed 2.0 & Ed 2.1, Parts 6, 7-1, 7-2, 7-3, 7-4, and 8-1

MECHANICAL**Test Type/Technology:****Test Methods¹:****Environmental Chamber²**

(Cold, Dry and Damp Heat Cycle) IEC 60068-2-1; IEC 60068-2-2;
 Temperature: (-65 to +110) °C IEC 60068-2-30
 Relative Humidity: (10 to 95) %

Mechanical Operation

IEC 62271-1;
 IEC 62271-100, -103, -111

Temperature Rise / Continuous Current

Single-phase / Three-phase up to IEC 62271-1; IEC 61869-1, -3;
 3000 A, 50/60 Hz IEC 62271-100, -103, -111; IEC 60137

Salt Fog (1000 Hr)²

Test Voltage: (2 to 30) kV IEC 62217

Degrees of Protection Against Mechanical Impacts (IK)²

IK 08, IK 09, IK 10 IEC 62262; IEC 60068-2-75 clause 5

Types of products, materials, and/or industry that the laboratory tests:

Testing Products
 Automatic Circuit Reclosers
 Circuit Breakers
 Disconnectors
 Load Break Switches
 Voltage Transformers
 Insulated Bushings
 Measuring / Protection Relays
 Enclosures

¹ When the date, edition, version, etc. is not identified in the scope of accreditation, laboratories may use the version that immediately precedes the current version for a period of one year from the date of publication of the standard test method, per Annex A, Part C of A2LA *R101 - General Requirements: Accreditation of Conformity Assessment Bodies*.

² Also using customer specifications directly related to the types of test parameters listed above.



Accredited Laboratory

A2LA has accredited

NOJA POWER SWITCHGEAR PTY LTD

Brisbane, AUSTRALIA

for technical competence in the field of

Electrical Testing

This laboratory is accredited in accordance with the recognized International Standard ISO/IEC 17025:2017 *General requirements for the competence of testing and calibration laboratories*. This accreditation demonstrates technical competence for a defined scope and the operation of a laboratory quality management system (refer to joint ISO-ILAC-IAF Communiqué dated April 2017).



Presented this 9th day of June 2025.

A blue ink signature of Mr. Trace McInturff, written in a cursive style.

Mr. Trace McInturff, Vice President, Accreditation Services
For the Accreditation Council
Certificate Number 6056.01
Valid to January 31, 2027

For the tests to which this accreditation applies, please refer to the laboratory's Electrical Scope of Accreditation.