

**Danfoss A/S**6430 Nordborg
Denmark
CVR nr.: 20 16 57 15Telephone: +45 7488 2222
Fax: +45 7449 0949**EU DECLARATION OF CONFORMITY****Danfoss A/S**

Danfoss DEN Controls

declares under our sole responsibility that the

Product category: JIP Ball Valves**Type designation(s): JIP**

PN(PS)	DN ≤32	DN 40	DN 50	DN 65	DN 80	DN 100	DN 125	DN 150	DN 200	DN 250	DN 300	DN 350	DN 400	DN 450	DN 500	DN 600
6	Art. 4 §3	Art. 4 §3	Art. 4 §3	Art. 4 §3	Art. 4 §3	Art. 4 §3	Art. 4 §3	Art. 4 §3	Cat. I	Cat. I	Cat. I	Cat. I	Cat. I	Cat. I	Cat. I	Cat. II
10	Art. 4 §3	Art. 4 §3	Art. 4 §3	Art. 4 §3	Art. 4 §3	Art. 4 §3	Cat. I	Cat. I	Cat. I	Cat. I	Cat. I	Cat. I	Cat. II	Cat. II	Cat. II	Cat. III
16	Art. 4 §3	Art. 4 §3	Art. 4 §3	Cat. I	Cat. I	Cat. I	Cat. I	Cat. I	Cat. I	Cat. II	Cat. II	Cat. III	Cat. III	Cat. III	Cat. III	Cat. III
25	Art. 4 §3	Art. 4 §3	Cat. I	Cat. I	Cat. I	Cat. I	Cat. I	Cat. II	Cat. II	Cat. II	Cat. III	Cat. III	Cat. III	Cat. III	Cat. III	Cat. III
40	Art. 4 §3	Cat. I	Cat. I	Cat. I	Cat. I	Cat. I	Cat. II	Cat. II	Cat. II	Cat. II	Cat. III	Cat. III	Cat. III	Cat. III	Cat. III	Cat. III

Covered by this declaration is in conformity with the following directive(s), standard(s) or other normative document(s), provided that the product is used in accordance with our instructions.

Pressure Equipment Directive 2014/68/EU

EN 19:2016

Industrial valves - Marking of metallic valves


EN 1092-1:2018

Flanges and their joints - Circular flanges for pipes, valves, fittings and accessories,
PN designated - Part 1: Steel flanges

EN 12266-1:2012

Industrial valves - Testing of metallic valves - Part 1: Pressure tests, test
procedures and acceptance criteria - Mandatory requiremenConformity
assessment procedure according to Module H - Full quality assurance.

A risk assessment has been performed and documented according to Annex I.

Products in category I, II and III are marked with  0062 and evaluated by:

Bureau Veritas Services SAS

8 Cours du Triangle,

92800 Puteaux - La Défense - FRANCE

Date: 18.5.2021 Place of issue: Ljubljana	Issued by Signature: Name: Milan Jungić Title: PPM Director	Date: 18.05.2021 Place of issue: Ljubljana	Approved by Signature: Name: Saška Rihtaršič Title: DEN R&D Senior Director
---	---	--	---

Danfoss only vouches for the correctness of the English version of this declaration. In the event of the declaration being translated into any other language, the translator concerned shall be liable for the correctness of the translation

TULKOJUMS

Danfoss A/S
DK-6430 Nordborg
Dānija
CVR nr.: 2016 57 15
Tel. +45 7488 2222
Faks. +45 7449 0949

ES DEKLARĀCIJAS TULKOJUMS

Danfoss A/S

Danfoss kontrole, centralizēta siltumapgāde

deklarē ar pilnu atbildību, ka

Produkts:
Tips:

JIP Lodveida noslēgvārsti
JIP

PN (PS)	DN <=32	DN40	DN50	DN65	DN80	DN100	DN125	DN150	DN200	DN250	DN300	DN350	DN400	DN450	DN500	DN600
6	Pants 4§3	Pants 4§3	Pants 4§3	Pants 4§3	Pants 4§3	Pants 4§3	Pants 4§3	Pants 4§3	Kat. I	Kat. I	Kat. I	Kat. I	Kat. I	Kat. I	Kat. I	Kat. II
10	Pants 4§3	Pants 4§3	Pants 4§3	Pants 4§3	Pants 4§3	Pants 4§3	Kat. I	Kat. I	Kat. I	Kat. I	Kat. I	Kat. I	Kat. II	Kat. II	Kat. II	Kat. III
16	Pants 4§3	Pants 4§3	Pants 4§3	Kat. I	Kat. I	Kat. I	Kat. I	Kat. I	Kat. I	Kat. II	Kat. II	Kat. III	Kat. III	Kat. III	Kat. III	Kat. III
25	Pants 4§3	Pants 4§3	Kat. I	Kat. I	Kat. I	Kat. I	Kat. I	Kat. II	Kat. II	Kat. II	Kat. III	Kat. III	Kat. III	Kat. III	Kat. III	Kat. III
40	Pants 4§3	Kat. I	Kat. I	Kat. I	Kat. I	Kat. I	Kat. II	Kat. II	Kat. II	Kat. II	Kat. III	Kat. III	Kat. III	Kat. III	Kat. III	Kat. III

Uz kuru ir attiecināma šī deklarācija ir atbilstībā ar sekojošām direktīvām, standartiem vai citiem normatīviem dokumentiem un kuri tiek lietoti saskaņā ar ražotāja instrukcijām:


Spiedieniekārtu direktīva 2014/68/ES

EN 19:2016 Industriālie vārsti – metāla vārstu marķējums

EN 1092-1:2018 Atloki un to savienojumi - Apļveida atloki caurulēm, vārstiem, piederumiem un aksesuāriem, noteikts PN - 1. daļa: Tērauda atloki.

EN 12266-1:2012 Industriālie vārsti - Metāla vārstu testēšana 1. daļa: Spiediena testi, testu procedūras un pieņemšanas kritēriji - Obligātās prasības. Atbilstības novērtēšanas procedūra saskaņā ar H moduli - pilnīga kvalitātes pārbaude.

Riska novērtējums ir veikts un dokumentēts saskaņā ar I pielikumu.

I, II un III kategorijas produkti ir marķēti ar  0062 un novērtēti:

Bureau Veritas Services SAS

8 Cours du Triangle,

92800 Puteaux – La Defense – FRANCIJA

Datums: 18.05.2021	Izdevis (paraksts)	Datums: 18.05.2021	Apstiprināts: (paraksts)
	Vārds, Uzvārds: Milan Jungic Amats: PPM Direktors		Vārds, Uzvārds: Saška Rihtaršič Amats: DEN R&D vecākais direktors

Danfoss uzņemas pilnu atbildību par ražotāja deklarācijas versiju angļu valodā. Gadījumos par deklarācijas tulkošanu citā valodā tulks uzņemas atbildību par deklarācijas pareizu tulkojumu.

Tulkoja: Irena Omelana, SIA Danfoss, Pārdošanas atbalsta speciāliste
ID nr. VJKDA402

Versijas Nr. 03



Lapa 1 no 1