

《CEEG 中电电气

CEEG Transformer Co.,Ltd

ADDRESS 22 Chengxin Street, 3F4F, CITIC Investment Building, Yuhuatai District, Nanjing City, Jiangsu Province.

6 Yuema Road, Binjiang Economic Development Zone, Jiangning District, Nanjing City, Jiangsu Province.

Building 10, Rongning Entrepreneurship Park, Chongming West Road, Economic Development Zone, Jurong City, Jiangsu Province.

WEBSITE en.ceeg.cn
TEL. 025-52095855
15301592833

CEEG | 《CEEG 中电电气 | CEEG copyright reserved

June 2023 Edition







+ CONTENTS



PO3 COMPANY PROFILE

P40 SERVICE NETWORK

PO7 PRODUCT INTRODUCTION









Founded in 1990, CEEG Transformer Co., LTD (CEEG) has always adhered to the core value concept of "Vision, Innovation and Responsibility", taking "Delivering Premium Power to The World " as its responsibility, focusing on production and manufacturing for more than 30 years, forming electricity Power transformers, new energy and system solutions three pillar industries.

CEEG guided by the green concept of "Safety, Energy saving and Environmental protection", is committed to the research and development and production of transmission and distribution equipment, which is a collection of research and development, manufacturing and sales in one. CEEG has won the honorary title of national innovative enterprise, Top 500 Asian brands, China famous trademark, and national End-users' satisfaction products, and has the relatively larger dry type transformer production base in the world with American DuPont Nomex® paper as insulation material transformer manufacturer, the company registered capital of 300 million yuan, covers a total area of 82.4 acres, with an annual output of 40,000MVA transformer production capacity, sales and service outlets all over the country in major cities.

The company's main products are: 220kV and 110kV railway traction transformer, Scott railway traction transformers, 2x27.5kV railway auto transformers, 220kV and below oil-immersed type transformers, 35kV and below cast resin transformers, SG series open ventilated transformer and SCR semi-enclosed dry type transformers, energy storage specialized transformer, hydrogen-specific rectifier transformer, urban railway traction rectifier transformer apparatus, urban rail railway traction rectifier group, amorphous alloy dry type transformer, mining explosion-proof transformer and explosion-proof switch, high and low voltage switch cabinet, frequency conversion transformer, anti-harmonic transformer, marine transformer, urban rail transit intelligent pad-mounted, pad-mounted & European type substation, wind and photovoltaic substation,

reactor, etc. Sales cover railway, electricity, electronics, urban rail transit, hydropower, nuclear power, wind power, coal mining, communications, construction, petroleum, chemical, aerospace and other industries.

CEEG has an advanced three-dimensional integrated design cloud platform in the industry, which improves the design quality of products and meets with customer needs to the maximum extent with reliable power solutions. In recent years, the company has participated in the construction of many national key projects, such as the Beijing Olympic Games project, Nanjing South Railway Station, Shenyang National Games, Nanjing Youth Olympic Games, Shanghai WorldExpo project, manned spaceflight project, Beijing South Railway Station, Shanghai Yangtze River Tunnel and Bridge, Shenzhen Lingao Nuclear PowerProject, and its products are exported to Europe, Australia, Southeast Asia, the Middle East, Africa and other parts of the world.

Walking with giants and keeping pace with the world!

The company has established long-term strategic partnerships with world-class enterprises such as DuPont, ABB and Siemens. The pursuit of innovation, the fulfillment of responsibilities, by continuously upgrading products, quality, and services, we have developed into a large domestic supplier of power transmission and distribution equipment, the industrial foundation is strong. The series of products produced by the company have been exported to more than 80 countries and regions in the world, the strategic layout of brand internationalization and service globalization has been formed, and is transforming to" manufacturing globalization + terminal solution + service", and committed to making CEEG the world's top choice!













220kV, 110kV (66kV) Power Transformer

Precision Craftsmanship Perfect Quality

Scope of Application

It is beneficial for meeting peak electricity demand during summer and is suitable for high-load distribution networks in high-temperature environments. It is also suitable for locations with impact loads and continuous overload requirements, such as the steel and metallurgical industry, railway transportation, power plants, hydroelectric stations, etc

Product Introduction

- 1. Utilization of DuPont's Nomex insulation system, registered trademark: Anleide.
- 2. Advanced seven-level temperature control technology.
- 3. High overload capacity: Meets typical overload curves, capable of sustained 30% overload.
- 4. Low partial discharge: Routine Partial discharge is less than 40pC.
- 5. Short-circuit withstand capability: Meets the operationalcharacteristics of frequent near-end short circuits in electrified railways.

Scope of Application

Suitable for electrified high-speed railway passenger dedicated lines as well as heavy-duty freight dedicated lines

Reference

Jing-Shi-Wu High-speed Railway, Jin-QinLine, Lan-Xin Line, Dun-Ge Line, Da-Qin Line, Guangzhou-Zhuhai Line, Chongqing-Fuling Line, and many other domestic electrified railway lines. Export destinations include Siba, En Bi, A.E. Distribution sh.p.k and more.

Product Introduction

- 1. Adopting a fully enclosed manufacturing process with constant temperature, humidity, and dust control to ensure lean and controlled product quality.
- 2. Utilizing the original "Seven-level Temperature Control Technology" system in conjunction with finite element analysis of temperature distribution to fully leverage the performance advantages of various insulation materials.
- 3. Implementing unique noise-reduction methods in different components to ensure noise levels surpass national standards.
- 4. Employing one-time molding technology for sealing components and conducting multiple leakage tests, including fluorescent, positive pressure, and negative pressure methods, to ensure leakage-free products.
- 5. The core adopts Swiss advanced stacking manufacturing technology & production process, with low no-load loss.
- 6. Successfully passing the short-circuit test conducted by the National Transformer Testing Center, ensuring the safety and reliability of the product

Product performance

Beijing Zhongmei Electric Co., Ltd., Beijing Lufeng Times Technology Development Co., Ltd., Shenhua United Construction Co., Ltd., Chongqing Yuzhan Electric Co., Ltd., Hubei Power Survey and Design Institute Co., Ltd. (Yuanwanghe Storage Jiangdong 100MW PV Field Project), Xinjiang Production and Construction Corps, Huazi Technology Co., Ltd., Pinggao Group International Engineering Co., Ltd., Wuxi Metro, Yuanhe Power Station, etc.



SGBH19 series Open Ventilated Dry Type Transformer

High Efficiency Energy-saving Superior Insulation Green and Environmentally Friendly





Product Introduction

- new generation of Class 1 energy-efficient products.
- losses by 60% and achieving significant energy savings.
- allowing for easy assembly and occupying a small footprint.
- in low mechanical stress and reduced noise.
- tion heat resistance.
- 6. Excellent flame resistance, and strong overload capacity.
- 7. Equipped with intelligent transformer terminals and integrated levels with IoT cloud platform for smart operation and maintenance.

Implementation standards

- 1. Complies with GB 20052-2020 energy efficiency standards, a 1. GB 20052-2020 Limits and energy efficiency grades for power transformers
 - 2. GB/T 1094.1-2013 Power transformers Part 1: General
- 2. Utilizes high-quality amorphous alloy strip, reducing no-load 3. GB/T 1094.3-2017 Power transformers Part 3: Insulation levels, Dielectric tests, and External clearances in air
- 3. Adopts a self-developed three-phase three-column structure, 4. GB/T 1094.5-2008 Power transformers Part 5: Ability to withstand short-circuit 5. GB/T 1094.11-2022 Dry type transformers
- 4. Incorporates a unique iron core mounting technology, resulting 6. GB/T 1094.12-2013 Power transformers Part 12 Load Guide for dry power transformers
- 5. Adopts DuPont Nomex® insulation system, ensuring high insula- 7. GB/T 22072-2018 Dry amorphous alloy iron core distribution transformer technical parameters and requirements
 - 8. GB/T 1094.10-2003 Power transformers Part 10: Determination of sound

SCBH series Amorphous Alloy Dry Type Transformer

Three-phase Three-column **Energy-saving Pioneer**





CEEG Product Family

- 1. Adopts high-quality amorphous alloy strip, reducing no-load losses by approximately
- 2. Use a self-developed three-phase three-column structure, occupying a small footprint.
- 3. Simulation analysis on the vibration model to reduce noise effectively. Unique core mounting technology and end sealing process to ensure low core stress and low noise.
- 4. Utilize a unique semi-enclosed structure with strong dustproof ability and high insulation performance.
- 5. High mechanical strength, strong waterproofing and short-circuit resistance capabilities.

Suitable for places under distribution grid with low efficiency, the place with flammability & explosive character, or the area with high requirement for flame-resistance, such as cloud computing data centers, rural power grids, high-rise buildings, commercial centers, subway systems, airports, power plants, etc.

China Telecom, China Mobile, China Unicom, People's Liberation Army of China (specific unit), Huawei Hubei Research Institute Data Center (IDC), Daging Zhonglan Petrochemical Co., Ltd., Beijing Mining and Metallurgy Research Institute, etc.

S(B)H-M series Oil-immersed Type Amorphous Alloy Distribution Transformer

Domestic Pioneer in Production Assembly Line



Product Introduction

- 1. Produced using a constant temperature, humidity, and dust-free fully enclosed manufacturing process.
- 2. Utilizes high-quality amorphous alloy strip, resulting in a reduction of approximately 60% in no-load losses compared to previous models.
- 3. Manufactured using the automated corrugated tank production line from Germany's Jörg, automatic forming a tank, and ensuring leakage-free tanks.
- 4. Adopts a fully vacuum oil-injection process online, resulting in high insulation performance and low partial discharge.
- 5. Utilizes fully automated testing equipment for product testing, with automatic comparative analysis of results.
- 6. Pioneered the SH15-M-6300/35 amorphous alloy transformer, successfully passing routine, special, type tests, short-circuit tests, in a single attempt.

Scope of Application

Suitable for the upgrading and reconstruction of agricultural grid and urban grid, as well as large-scale data computing centers.

Reference

Beijing Northern Energy Saving and Environmental Protection Co., Ltd., Tianjin Power Company, Shaanxi Power Company, Liaoning Power Company, Beijing Chaoyang Electric Power Engineering Company, Shenshuo Railway Branch, Nanjing China Post Air Express Logistics Distribution Center Phase II Apron Construction Project, etc.

S series Transformer

Low Noise Low partial Discharge Customized Low Temperature Rise Short-circuit Withstand Capability Impulse Withstand Capability



Product Introduction

The Class-one S22/Class-two S20/Class-three S13 series oil-immersed type transformers combine the traditional structure of oil-immersed type transformers with modern domestic and international oil-immersed type transformer structures. They feature a new insulation structure for power transformer.

Scope of Application

They are widely used in urban power grids, rural power grids, high-end power supply fields, as well as in industries such as steel, coal, chemical, cement, paper, and metallurgy.

Reference

Shougang Shuicheng Iron and Steel (Group) Co., Ltd., AVIC The Third Research Institute of China Electronics Technology Group Corporation (CETC), Wuxi Metro Line 1-4, Chongqing Metro Line 2, Nanjing Metro, Guangzhou Metro



Product Introduction

- 1. Strong overload capacity: With DuPont Nomex® paper as the core and a seven-level temperature control technology, it utilizes a hybrid insulation system effectively.
- 2. Wide applicability: Suitable for industries operating in high ambient temperatures or under long-term high loads, providing safe and reliable power supply.
- 3. Low maintenance cost: It exhibits excellent oxidation resistance, slow aging rate, more stable mechanical characteristic and electrical properties, resulting in a long lifespan.
- 4. Energy-saving and environmentally friendly: After the end of its service life, the materials can be recycled and reused, without causing pollution.
- 5. Safety and reliability: It possesses strong corrosion resistance and water-proof properties, ensuring safe and reliable long-term operation.

Scope of Application

High-end power supply sectors and customers in industries such as steel, coal, chemical, cement, paper, and metallurgy.

Reference

Guangzhou-Zhuhai Railway Co., Ltd., Beijing Shougang International Engineering Technology Co., Ltd., Guiyang Urban Rail Transit Co., Ltd., Heilongjiang Longmei Mining Group Co., Ltd., Guizhou Shuicheng Coal Mining Co., Ltd., Chongqing Energy Group, Lanzhou Railway Bureau, Liaoning Provincial Electric Power Co., Ltd., Shandong Luneng Materials Group Co., Ltd., Weiqiao Textile Co., Ltd., Shanxi Provincial Electric Power Company, Shaanxi Provincial Electric Power Company, Northwest Power Grid Co., Ltd., etc.

Mobile Transformer on vehicles

CEEG Intelligent Manufacturing Safe and Efficient

Product Introduction

The mobile transformer developed by CEEG is of vital importance to the overall performance of mobile substations. Although there is only a slight difference in wording between "mobile transformer" and "mobile transformer for vehicles," the design concepts differ significantly. Conventional mobile transformer as emergency power sources and typically only require short-term energized operation for a few days, their operating characteristics cannot be compared to those of substations. In contrast, the "mobile transformer on vehicles" for mobile substations, as a core equipment, must not only meet the transportation requirements of various road conditions but also fulfill the energized operation needs of the mobile substation for several months or even one to two years, essentially aligning with the operating characteristics of a substation.

Since it is a mobile substation, after the lease expires, it needs to be transported and leased to other projects multiple times. Therefore, the technical requirements for the "Mobile transformer on vehicles" are higher than those of tradition ones. This type of transformer can be integrated into a flatbed trailer or transported as a whole using conventional transport vehicles, without the need for complicated approval procedures for specialized vehicles, completely replacing conventional mobile transformers.

Reference

Jiangyin Second Yangtze River Crossing, Yuanhe Power Station Co., Ltd., Beijing Beikong Environmental Protection Co., Ltd., Pinggao Group International Engineering Co., Ltd., Suzhou Zhongcai Construction Co., Ltd., Wuxi Metro Group Co., Ltd., etc.





Oil-immersed Type Converter Transformer

High Temperature Resistance High Overload Capacity Low Noise High Reliability



Product Introduction

Power conversion refers to the collective term for rectification, inversion, and frequency conversion, among which rectification is widely used. Most industrial rectifier DC power supplies are generated by rectifier transformers and rectifiers connected to the AC power grid. The electrochemical industry is the most common application of rectifier transformers, used for the extraction of aluminum, magnesium, copper, and other metals through the electrolysis of metal compounds, as well as the production of chlorine-alkali through the electrolysis of salt, and the production of hydrogen and oxygen through the electrolysis of water. The explosive growth of the hydrogen energy industry is driven by factors such as depletion of fossil energy, environmental degradation, and frequent extreme climate events.


Hydrogen energy is a rich, green, and low-carbon secondary energy source, gradually becoming one of the important carriers in global energy transition. In the context of carbon peak and carbon neutrality goals, the combination of renewable energy sources such as photovoltaics, wind power, and hydropower with hydrogen production through rectifier equipment and water electrolysis technology can produce high-purity hydrogen and oxygen, leading to wider utilization in the global economy.

Product Performance

The oil-immersed rectifier transformers produced by CEEG have the characteristics of high temperature resistance, maintenance-free operation, high overload capacity, low noise, high reliability, lift-core free, leakage-free performance, and diverse product varieties. These features effectively improve electrolysis efficiency, reduce overall power consumption, and enhance operational reliability. The performance indicators meet or exceed the latest standards such as GB/T 18494.1-2014 and GB/T 18494.3-2012, demonstrating an advanced level among similar products in the domestic market.

Dry Type Converter Transformer

Professional Design Safe and Reliable



Product concept

Power conversion refers to the overall term for three working modes: rectification, inversion, and frequency conversion. Most of the rectifier and DC power supplies used in general industry, energy storage, photovoltaic, variable frequency speed regulation, subway railway traction, feed test, charging station and other places are generated by the rectifier equipment composed of transformer and rectifier in the AC power grid.

Product function

- The power supply voltage on the AC grid side is stepped down (or stepped up) to meet the required AC valve side voltage for DC output.
 Achieve electrical isolation between the DC side (AC valve side) and the AC grid side.
- 3. Convert the three-phase (or single-phase) AC power supply on the AC grid side into multi-phase AC power on the AC valve side to reduce the harmonic content on the AC grid side and improve the waveform of the DC voltage.

Product features

Core material: Optional choices include silicon steel or amorphous alloy strip.

Core structure: Optional choices include three-phase three-column or three-phase five-column.

Winding structure: Optional choices include axial split, radial split, or multiple windings on the valve side for multiple voltage outputs.

Insulation class: Optional choices include Class F or Class H.

Product process: Optional choices include epoxy resin casting process or vacuum pressure impregnation process.



SG series Dry Type Transformer

Safe Reliable Environmentally Friendly Energy Saving



Product Introduction

- 1. The product is rated as Class H insulation and Class C insulation materials, providing strong overload and short-circuit withstand capabilities and high safety performance.
- 2. High-quality high-permeability silicon steel is used with a multi-stage stepped process, resulting in low no-load losses.
- 3. Copper and silicon steel are recyclable, and the insulation materials are fully degradable, making it an environmentally friendly product.
- 4. DuPont ReliatraN® core technology is adopted, reducing the volume by 10% and saving materials by 10%.
- 5. Realizes full intelligent data collection and analysis, serving as an intelligent 'brain' for proactive operation and maintenance.

Scope of Application

- 1. Places with high population density such as shopping malls, residential areas, schools, hospitals, and entertainment venues that have strict safety requirements.
- 2. Locations with high energy consumption, high loads, susceptibility to overload, and uneven load distribution.
- 3. Harsh environments such as coal mines, nuclear power plants, and cement factories that have radiation hazards or high dust content.
- 4. Occasions that require high moisture resistance, resistance to salt spray, and corrosion protection.

Reference

National Olympic Sports Center Comprehensive Training Hall, Beijing Aerospace Times Laser Navigation Technology Co., Ltd., Chinese People's Armed Police Force, China University of Petroleum, Beijing Tiantan Hospital, and others.

Marine and Offshore Platform Transformer

Superior Insulation Seismic Resistance





Product Introduction

- 1. It adopts high-quality high-permeability silicon steel with multi-step process,resulting in low no-load losses.
- 2. The use of Nomex® paper insulation system for manufacturing marine transformers and offshore platform transformers is the first in China.
- 3. The transformer body adopts two kinds of process system: VPI (Vacuum Pressure Impregnation) process and epoxy vacuum casting process, both of which are applicable.
- 4. All fasteners and exposed conductive parts are treated with special processes to meet the requirements of waterproof, dustproof, and anti-corrosion.
- 5. The enclosure comes with a waterproof trough, with the highest protection level reaching IP44, ensuring safety and reliability.
- 6. It can adopt a combination of air cooling and water cooling, forming a hybrid air-water cooling structure, with strong overload capacity

Scope of Application

The scope of application for marine transformers includes bulk carriers, oil tankers, container ships, chemical tankers, LNG (liquefied natural gas) carriers, roll-on/roll-off (Ro-Ro) ships, passenger ferries, etc. They are also used in docks, offshore platforms, and other marine vessel-related products.

Reference

China Shipbuilding Industry Corporation (CSI) 712th Research Institute, Shanghai Zhenhua Heavy Industries Co., Ltd., Nantong COSCO Kawasaki Ship Engineering Co., Ltd., CNOOC (China National Offshore Oil Corporation) Shenzhen Branch, etc.

Cast Resin Transformer

Precision Manufacturing Perfect Quality

Product Introduction

- 1. High quality high permeability silicon steel with multi-stage stepping process leads to low no-load loss.
- 2. The surface adopting nano-paint & self-leveling process with low noise.
- 3. It has strong waterproof and short-circuit resistance, strong overload capacity, good electrical performance, safety and reliability.
- 4. Through the simulation analysis of electric field, temperature field and magnetic field, CEEG is the first company in China to pass KEMA's E2, C2 and F1 tests.
- 5. The product can adopt dual-mode structure scheme to meet the needs of different customer groups.
- 6. Special intelligent transformer solution and big data cloud diagnosis technology are adopted to be always online.



Product Category

10kV Series

- 1. Low loss, low partial discharge and low noise.
- 2. The product performance parameters are better than GB and IEC standards.
- 3. It is safe, flame-retardant, fireproof and pollution-free, and can be directly installed in the load center.
- 4. Maintenance free, convenient installation and low comprehensive operation cost.
- 5. Low temperature rise and high product reliability.
- 6. Stable structure and strong seismic capacity.
- 7. Moisture proof, corrosion-resistant, wide application range.

Scope of application: Strong adaptability to the product environment, especially suitable for the places where have seasonal load fluctuations or overloading cas.

35kV Series

- 1. Through the dynamic thermal stability simulation analysis, the winding structure is in reasonable arrangement and with strong short-circuit resistance.
- 2. Low loss, low noise and low partial discharge.
- 3. It can also operate under overload long time without air-cooling, with strong overload capacity.
- 4. Winding capacitance distribution is reasonable and impulse withstand ability is strong.
- 5. The product has the characteristics of flame retardant and self extinguishing, non-toxic and harmful gas generation, green and environmental protection.

Scope of application: densely populated and narrow urban substations, data centers, factories and mining enterprises.

Traction Rectifier Transformer

1. Low temperature rise, strong overload capacity and reliable operation under class VI load conditions.

CEEG Product Family

- 2. The key technical parameters are well balanced, the load is evenly distributed, and the amount of non-characteristic harmonics is effectively reduced.
- 3. The coil adopts double split structure in axial with smoothly the output DC waveform.
- 4. High mechanical strength, good moisture resistance, partial discharge≤10pc.
- 5. Low noise, low electromagnetic radiation pollution.

Scope of application: Rail transit.

Reference

Olympic Center Gymnasium, Qingdao International Sailing Center, Beijing Urban sub center, Beijing Chang'an Street lighting project, Beijing Winter Olympics, China Iron and Steel Research Institute, Wuxi Metro, Nanjing Metro, Shanghai Disney Land, Shanghai Expo Exhibition Center, etc.




ZPSG Frequency Conversion Transformer

Protecting Motor Energy Saving Efficiency Enhancement

Product Introduction

- 1. The core adopts a core-positioning structure with multi-stage stepped process, ensuring no lateral or longitudinal displacement of the core under various operating conditions.
- 2. The winding adopts various structural types, providing strong short-circuit withstand capability.
- 3. It utilizes a dedicated air-cooling guiding system, achieving high heat dissipation efficiency and ensuring product safety and reliability.
- 4. The magnetic leakage distribution is reasonable, meeting the requirements of frequency converter.



- 5. Multiple technologies are employed to effectively suppress harmonic content, achieving harmonic-free performance and extending motor lifespan.
- 6. There are various structural types available to meet the requirements of different frequency conversion systems.
- 7. The product's maximum capacity can reach 9000kVA, enabling 72-pulse rectification.

Scope of Application

Suitable for use with high-voltage inverters, mainly in industries such as municipal water supply, power, metallurgy, petrochemicals, cement, coal, and others.

Reference

Siemens (Shanghai) Electrical Drive Systems Ltd., ABB Electrical Drive Systems Co., Ltd. (Beijing), Beijing Dynamic Source Technology Co., Ltd., Beijing Kangyi Sheng Frequency conversion Technology Co., Ltd., Jiangsu Lipu Electronic Technology Co., Ltd., Wuxi Fuji Electric Co., Ltd., Hefei Chunyan Electric Switch Co., Ltd., and others.

KBSG2-T Mining Explosion-proof Transformer KBSGZY2-T Mining Explosion-proof Mobile Substation

National Patent Safety High Compression Strengh





Product Introduction

- 1. The unique full corrugated structure effectively improves the heat dissipation area, and has a national patent.
- 2. The cylindrical explosion-proof shell improves the strength of the shell, can withstand 1MPa pressure and has strong explosion-proof performance.
- 3. DuPont Nomex® Paper insulation system is adopted, which is more safe and reliable.
- 4. Adopting advanced design and processing technology, complete production and testing technology leading to more stable performance; 5. Low loss, low partial discharge, low noise and strong overload capaci-
- 6. Maintenance free, safe, flame-retardant, explosion-proof and fire-proof, pollution-free, and can be installed directly.

Scope of Application

It is widely used in power supply of underground devices in coal mines.

Reference

China Shenhua Group (including its subsidiaries), Datong Coal Mine Group Tongzhong Electric Co., Ltd., Shanxi Sanyuan Coal Industry group, Xinwen Mining Group, Shanxi China Resources Liansheng Energy Investment Co., Ltd., Inner Mongolia Beilian Power Energy Development Co., Ltd., etc.



KBZSGZY Mining Explosion-proof Converter Mobile Substation

Safe Reliable Environmentally Friendly

Product Introduction

- 1. The iron core adopts high-quality high magnetic conductivity silicon steel, full oblique joint and multi-stage stepping process, with low no-load loss.
- 2. The iron core adopts three-dimensional fastening structure. Under various working conditions, the iron core has no lateral and longitudinal displacement.
- 3. High and low voltage windings adopt a combined winding process, combined with VPI vacuum pressure impregnation and high-temperature curing, with high mechanical strength.
- 4. The shell adopts an oval structure, with low product height and short length, which is suitable for the space requirements of various mines.
- 5. The shell adopts the corrugated cylindrical structure of patented technology, with no ponding and dust on the top, good heat dissipation effect and strong explosion-proof performance.
- 6. It adopts the eight-point fastening method, which is firm and reliable and can go down the well vertically.
- 7. Nomex® paper insulation system is adopted, with thermal insulation up to Class C, recyclable, safe and environmental protection.
- 8. The integrated design scheme supplies power to the Flameproof Frequency Converter and communicates with the frequency converter to complete the functions of equipment operation status monitoring, fault breaking and centralized control.



Scope of Application

The product supplies power to the explosion-proof Frequency Converter and communicates with the frequency converter to complete the functions of equipment operation status monitoring, fault breaking and centralized control. It is widely used in coal mines to supply power to 1140V and 3300V explosion-proof Frequency conversion speed regulating devices with three-level technology.

Reference

China Coal Science and industry Tiandi (Jiyuan) electrical transmission Co., Ltd. (central enterprise), Qingdao Tianxin frequency conversion Co., Ltd., Liaoning Rongxin Electric Co., Ltd., Shenhua Ningxia Coal Industry Group Co., Ltd., Jincheng Lanyan Coal Industry Co., Ltd., Shenhua Xinjiang Energy Co., Ltd., etc

CEEG Product Family





PBG/KBG High-voltage Vacuum Switch for Mine Explosion-proof Mobile Substation BBD Low-voltage Protection Box for Mine Explosion-proof Mobile Substation

Advanced Craftsmanship Aesthetically Pleasing and Durable

Product Introduction

- 1. The core control system consists of an industrial programmable logic controller (PLC) and a human-machine interface (HMI). It provides stable performance, precise protection, and simple maintenance.
- 2. The HMI displays operational status, power parameters, and faults, with a fully Chinese-language LCD interface.
- 3. Current can be continuously set with a stepping value of 1A.
- 4. It supports live maintenance, ensuring safe and reliable operation and maintenance.
- 5. It features a small size, reasonable structure, and intuitive operation.
- 6. It offers comprehensive protection functions, including overload, short circuit, overvoltage, undervoltage, leakage, leakage lockout, phase loss, overtemperature, wind power and gas lockout, and emergency stop for the upstream power supply. It also protects against faults feedback from the low-voltage side of the mobile transformer.
- 7. The PLC intelligent protection system includes self-checking, fault diagnosis, inspection, and memory functions. It provides real-time detection, digital display of operational status, and fault indication for ease of

system use, maintenance, fault judgment, and handling.

- 8. It features a modular design and is equipped with standard RS232/485 communication interface for real-time monitoring and transmission of digital displays for operational status and fault indication. It can be integrated with the mine automation network to form a complete mine automation monitoring system.
- 9. All faults drive the high-voltage vacuum circuit breaker to disconnect through signal lines, reducing the breaking current.
- 10. The protection box has four circuits on two sides for output, meeting the connection requirements for multiple loads.

Scope of Application

Widely used for underground device power supply in coal mines.

Reference

China Shenhua Group (including subsidiary companies), Datong Coal Mine Group Tongzhong Electric Co., Ltd., Chongqing Energy Investment Group Co., Ltd., Xuzhou Mining Group Co., Ltd

25/26



Energy Storage Dedicated Open Ventilated Dry Type Transformer

Safer Transformer Safer Energy Storage



Product Introduction

- 1. The winding adopts an open and ventilated structure, which provides excellent heat dissipation, strong overload capacity, and ensures transformer safety.
- 2. It utilizes DuPont Nomex® VPI (Vacuum Pressure Impregnation) insulation system, offering a compact structure and reasonable layout.
- 3. The transformer is capable of withstanding high temperatures up to 220°C and low temperatures down to -40°C, providing strong insulation performance to meet various energy storage environment requirements.
- 4. It possesses flame retardant and non-combustible characteristics, making it more suitable for user-side energy storage applications such as hospitals, smart parks, solar energy storage charging stations, data centers, ensuring worry-free energy storage.
- 5. Equipped with intelligent terminal for the transformer and utilizing an Internet of Things (IoT) cloud platform, it enables intelligent operation and maintenance.

Scope of Application

Suitable for user-side energy storage applications such as hospitals, smart parks, solar energy storage charging stations, data centers, and more.

Implementation standards

- 1. GB 20052-2020 Limits and energy efficiency grades for power transformers
- 2. GB/T 1094.1-2013 Power transformers Part 1: General
- 3. GB/T 1094.3-2017 Power transformers Part 3: Insulation levels, Dielectric tests, and external clearances in air.
- 4. GB/T 1094.5-2008 Power transformers Part 5: Ability to withstand short-circuit
- 5. GB/T 1094.10-2022 Power transformers Part 10: Determination of Sound levels
- 6. GB/T 1094.11-2022 Power transformers Part 11: Dry-type transformers
- 7. GB/T 1094.12-2013 Power transformers Part 12: Load Guide for Dry-type power transformers
- 8. GB/T 10228-2015 Technical parameters and requirements of dry type power transformer



Product Introduction

- 1. The installation and usage environment is harsh, requiring high-level protection against dust, moisture, and vibration
- 2. Strong overload capacity and excellent resistance to thermal shock.
- 3. Strong ability to withstand harmonics.
- 4. Low self-loss and high efficiency.
- 5. Different high and low voltage terminals' input and output methods, with a compact structure.
- 6. Various requirements for capacity, voltage, and impedance.

The energy storage system dedicated dry type transformer, developed and produced using advanced technology, possesses highly reliable quality and offers excellent cost-effectiveness.

Implementation standards

- 1. GB 20052-2020 Limits and energy efficiency grades for power transformers
- 2. GB/T 1094.1-2013 Power transformers Part 1: General
- 3. GB/T 1094.3-2017 Power transformers Part 3: Insulation levels, Dielectric tests, and external clearances in air.
- 4. GB/T 1094.5-2008 Power transformers Part 5: Ability to withstand short-circuit
- 5. GB/T 1094.10-2022 Power transformers Part 10: Determinations of Sound levels
- 6. GB/T 1094.11-2022 Power transformers Part 11: Dry-type transformers
- 7. GB/T 1094.12-2013 Power transformers Part 12: Load Guide for Dry-type power transformers
- 8. GB/T 10228-2015 Technical parameters and requirements of dry type power transformer

27/28



Energy Storage Dedicated Oil-Immersed Type Transformer

Safer Transformer Safer Energy Storage



Structural advantages

- 1. The core structure has been changed from the traditional long circular core to a quasi-elliptical core structure. It has been validated through sudden short-circuit tests conducted by the Shenyang Transformer Research Institute, enhancing the ability of the new energy transformer to withstand sudden short-circuits.
- 2. High-density laminated wood is used as the spacer material. By changing the outlet way the copper busbars, the width of the internal oil tank has been significantly reduced, resulting in a more compact overall structure. This also has a certain inhibitory effect on stray losses caused by leakage magnetic fields.
- 3. The internal body positioning and switch installation methods have been modified, replacing the high-voltage elevation outlets with a new structure without hand holes, reducing the risk of oil leakage.

Quality control advantages

- 1. From the perspective of product quality, following the testing methods specified in GB/T 7354, we have intensified the assessment by conducting partial discharge tests on each new energy transformer. The aim is to ensure that the partial discharge level at 1.2 times the rated voltage (1.2Ur) is \leq 50pC and at 1.4 times the rated voltage (1.4Ur) is \leq 100pC (Ur represents the rated voltage of the transformer).
- 2. For products of the same model and batch, a sample size of 10% (>1 unit) is selected for lightning impulse tests and temperature rise tests. This further ensures the electrical insulation and mechanical performance of the products.
- 3. Based on the magnitude and frequency of the harmonic current injected into the transformer as provided by the user, due consideration is given to the losses caused by harmonic currents. This is done to prevent excessive temperature rise in the top layer of the transformer oil and windings. Additionally, the increased capacitance demand caused by harmonic currents is taken into account, ensuring the lifespan of the transformer.
- 4. According to user requirements and considering the operational environment on-site, the transformers are subjected to anti-corrosion treatment in strict accordance with the requirements of ISO 12944.

Hydrogen-specific Rectifier Transformer

Hydrogen Power in Action Electrifying Green Energy





CEEG Product Family

Product Introduction

Power conversion is a general term for the three modes of operation: rectification, inversion, and frequency conversion, with rectification being the most widely used. Most industrial rectifier power supplies are generated by rectification equipment composed of rectifier transformers and rectifiers, which are connected to the AC power grid. The electrochemical industry is the most prominent user of rectifier transformers, such as for the production of aluminum, magnesium, copper, and other metals through the electrolysis of metal compounds; the production of chlorine and alkali through the electrolysis of salt; and the production of hydrogen and oxygen through the electrolysis of water. The depletion of fossil energy, worsening ecological environment, and increasing occurrence of extreme climate events have driven the explosive growth of the hydrogen energy industry.

Hydrogen energy is a rich, green, and low-carbon secondary energy source, gradually becoming one of the important carriers for global energy transition. Under the requirements of carbon peak and carbon neutrality, combining renewable energy sources such as photovoltaics, wind energy, or hydropower with hydrogen production through rectification equipment and electrolysis of water allows for the production of high-purity hydrogen and oxygen. This will lead to broader utilization in the global economy.

Performance characteristic

- 1. Safety and reliability: The transformer is filled with non-toxic, flame-retardant epoxy resin, which provides high mechanical strength, flame resistance, and no pollution.
- 2. Convenient installation: Dry type rectifier transformers are delivered as a complete unit, ready for operation upon placement, ensuring convenience and efficiency.
- 3. High overload capacity: The maximum overload capacity can reach 200%.
- 4. Low noise: The noise level is reduced by 3 to 5 dB compared to the national standard.
- 5. Cost-saving: Dry type rectifier transformers can be installed together with rectifiers and other electrical equipment, eliminating the need for separate design of power distribution rooms. This saves space and reduces initial investment.
- 6. Customization: Flexibly designed and quickly responsive according to specific customer requirements.
- 7. Authoritative certification: Certified by the National Electrical Products Quality Supervision and Inspection Center.

29/30





Energy Storage Step-up Substation integrated with Converter (Dry Type Transformer)

New Energy Flexible Electricity Green Power

Product Introduction

1. Turn-key Solution


a.Integrated photovoltaic inverter, transformer, and switchgear in one unit, factory-tested as a whole, saving installation and commissioning time on-site.

b. The enclosure adopts a container design, eliminating the need for special lifting equipment, making transportation and installation convenient.

- 2. Strong Environmental Adaptability
- a. Strong corrosion resistance: The enclosure is containerized and made of high-weathering steel plate. High-weathering steel has stronger corrosion resistance than ordinary carbon steel.
- b. Thermal insulation: Insulation boards are installed inside the enclosure, providing good fire resistance, insulation, and thermal insulation.
- c. Ventilation and heat dissipation: The air inlet is specially designed to effectively prevent dust and sand.
- 3. High Reliability and Safety
- a. Adoption of epoxy resin cast dry type transformer, which is a flame-retardant product, eliminating the risk of explosion and fire. b. The dry type transformer has passed the C2E2 and F1 tests conducted by the National Transformer Quality Supervision and Inspection Center.
- 4. Low Investment, High Returns

Compared to the conventional 'inverter room + PV transformer cabinet' solution, the investment is reduced by 15% to 20%. The numbers of installation foundation are reduced from 2 to 1. Installation and commissioning time is reduced by 50%. Inverter and transformer are connected using copper busbars, eliminating the need for cables between the inverter room and PV transformer cabinet. Structural optimization saves two low-voltage switchgear cabinets between the inverter and transformer.

5. The product solution is flexible and diverse, completely tailored to meet the customer's actual needs, providing a satisfactory one-stop solution.



Energy Storage step up substation intergrated with Converter (Oil-immersed Type Transformer)

New Energy Flexible Electricity Green Power

Product Introduction

The energy storage boosting and conversion integrated machine has a high-voltage side voltage ranging from 6kV to 35kV, and the low-voltage side AC voltage of the transformer covers 0.315kV to 0.69kV. The transformer includes various models of oil-immersed, dry type, and Huabian (China) transformers. The energy efficiency grade meets the design requirements, and the maximum DC voltage on

the direct current side can reach up to 1500VDC. The standalone capacity of the Energy Storage substation can reach up to 6.8MW.

The energy storage system can be connected to the grid as an independent system, playing a role in peak shaving, valley filling, and reactive power compensation. The energy storage system can also be combined with new energy generation to form a wind-solar energy storage system, smoothing the power output from renewable sources to the grid. Moreover, the energy storage system can be integrated

with wind power, solar power, and other renewable energy systems, forming a microgrid system at the load center, which improves energy utilization efficiency, enhances power quality, increases power supply reliability, and promotes green and environmental-friendly practices. By optimizing the configuration of batteries, inverters, bidirectional converters, wind and solar equipment, we can provide engineering consulting, design, system integration, and station-level monitoring for energy storage systems, wind-solar energy storage systems, and energy storage microgrid systems.



Referrnce

Qinghai Geermu 100MW200MW Project, State Power Investment Corporation's 20MW Photovoltaic Energy Storage Project, Ronghe Yuan Shandong Peninsula Yantai Haiyang 15MW Energy Storage Project, Guoxuan High-Tech Energy Storage Project, Shanghai Electric Jinchang Energy Storage Project, Ganghua Era User-Side Energy Storage Project, JD.com Energy Storage Project, Ningxia Muhe Energy Storage Project, and others.





ZGS series Prefabricated Substation



Scope of Application

It is widely used in various power transformation and distribution places such as industrial parks, residential quarters, commercial centers and high-rise buildings.

Reference

Beijing Gongke Feida Transportation Engineering Development Co., Ltd., Inner Mongolia Xilin Gol Baiyinhua Coal Power Co., Ltd., Jiangsu Huaxi Group Co., Ltd., Zibo Mining Group material supply Co., Ltd., Anqing Hengjiang industry (Group) Co., Ltd., Gezhouba Group Power Co., Ltd., Qinghai Upper Yellow River Hydropower Development Co., Ltd., etc.

Product Introduction

- 1. The product has the advantages of compact structure, small volume, short construction cycle and easy installation and movement.
- 2. The shell adopts fully sealed design, with good protection effect.
- 3. The substation adopts unique guiding ventilation technology, with good heat dissipation effect and strong overload capacity.
- 4. Various power supply schemes of terminal or ring network can be adopted, with long service life and maintenance free.
- 5. Dry type, oil type, amorphous alloy and other types of transformers can be configured according to user requirements, and the schemes are flexible and diverse.
- 6. CT, PT, protection and communication devices can be installed at the high-voltage side, and multi-functional intelligent instruments for acquisition and protection can be installed at the low-voltage side, so as to realize the "three remotes" of high-voltage and low-voltage switches and transformers.
- 7. LED display screen can be installed on the surface of the shell to scroll all kinds of information, which is beautiful, environmentally friendly and economical.
- 8. It can realize fully intelligent data acquisition and analysis, realize active operation and maintenance, and provide energy management for various scenarios.

YB series Prefabricated Substation

Modular Manufacturing





Product Introduction

- 1. YB series prefabricated substation is a complete set of indoor and outdoor power transformation and distribution equipment composed of high-voltage switchgear, power transformer and low-voltage switchgear.
- 2. The product is a frame structure, which is welded with section steel or assembled from steel plate. The frame is covered with special paint layer, which has strong mechanical properties, weather resistance and corrosion resistance.
- 3. The top of the prefabricated substation is provided with a thermal insulation layer to prevent condensation caused by rapid temperature change. A thermal insulation layer can be added around the box.
- 4. YB series prefabricated substation is to install the secondary system (including telecontrol) of the substation into one or several movable, fully enclosed, moisture-proof and anti-corrosion boxes after installation and commissioning in the factory. After one-time installation in the factory, the box is transported to the site. Only the corresponding foundation and one-time connection are needed to transmit power.
- 5. It can realize fully intelligent data acquisition and analysis, realize active operation and maintenance, and provide energy management for various scenarios.
- 6. CT, PT, protection and communication devices can be installed at the high-voltage side, and multi-functional intelligent instruments for acquisition and protection can be installed at the low-voltage side, so as to realize the "three remotes" of high-voltage and low-voltage switches and transformers.

Scope of Application

In places without fire, explosion, chemical corrosion and violent vibration, the ground inclination shall not exceed 5°.

Reference

Beijing Olympic Doping Testing Center, Beijing Lvqi Kechuang Technology Co., Ltd., Qingdao International Sailing Center of the 29th Olympic Games of Qingdao East Olympic Development & Construction Group, 96201 Unit, 4822 plant of the Chinese people's Liberation Army, Wuhan Branch of China Petrochemical Corporation, State Grid Smart Grid Research Institute, Xinjiang Meihua Amino Acid Co., Ltd. and Sinopec (Hong Kong) Hainan Petroleum Co., Ltd., China Railway 14th Bureau Group Co., Ltd., etc.



Prefabricated Containerized Intelligent Substation

Precision Craftsmanship Perfect Quality

Product Introduction

The containerized enclosure features standardized design, factory-customized distribution, on-site modular construction, and the use of modular and combinable electrical equipment. It includes transformers, high-voltage switchgear and control equipment, internal wiring of low-voltage switchgear and control equipment, metering, compensation, surge arresters, and other auxiliary devices, configured within a common enclosure or a group of enclosures. There are multiple options for the enclosure, allowing for non-metallic or containerized selection based on specific needs. The equipment, following relevant standards, undergoes debugging and testing to form a complete substation.





Product Features

- 1. Factory production
- 2. Modular transportation
- 3. Convenient on-site installation
- 4. Small footprint
- 5. Short construction period
- 6. Low operation and maintenance costs
- 7. Fully enclosed, long service life, strong weather resistance

Reference

Zimbabwean Export Project



Product Introduction

- 1. Good sealing performance, wind and sand proof, salt fog proof, rain and snow
- 2. Advanced electric spray-coating technology, the shell is not easy to rust and fade.
- 3. The shell has strong adaptability to the environment, which can be selected according to different environments. It has the advantages of beautiful appearance and coordination between the shape & the windmill site.
- 4. Intelligent control, which can not only be controlled locally, but also be monitored remotely to realize the four remote functions.
- 5. Natural ventilation. The substation is equipped with sufficient natural ventilation and thermal insulation measures. When the ambient temperature is close to 40 °C, forced ventilation will be started to ensure the normal operation of step-up transformer.

Scope of Application

Windmill power plant. YBF series windmill power substation is a special equipment for grid connected output after raising the 0.6-0.69kV voltage sent by windmill power generator to 10kV or 35kV.

Reference

Inner Mongolia Ximeng zheligentu wind farm phase I, Saihan project of Beijing International Power New Energy Co., Ltd., zheligentu project, Gansu Xinguan Wind Power Co., Ltd., Huaneng Tianzhen Wind Power Co., Ltd., Dafeng Wind Power Co., Ltd., National Electricity Yunnan New Energy Co., Ltd., Jiangxi SPIC New Energy Power Generation Co., Ltd, Datang Zhangzhou Wind Power Generation Co., Ltd., Huaneng Fuxin Wind Power Generation Co., Ltd., etc.

KYN28A series/ASZ1 series Armored Movable AC Metal-enclosed Switchgear

Reasonable Structure Safe and Reliable



- 1. Equipped with ABB-produced VD4 vacuum circuit breaker or domestically produced VS1 vacuum circuit breaker.
- 2. Cabinet structure adopts fully assembled method.
- 3. Sufficient space in the cable compartment allows for the connection of multiple cables, making installation and maintenance convenient.
- 4. Cabinet can be reliably wall-mounted, reducing floor space occupation.
- 5. Excellent interchangeability of handcart.
- 6. Passed all type tests and full-load tests.
- 7. Equipped with interlocking functions to prevent pushing and pulling of circuit breaker handcart with load, prevent misoperation of circuit breaker, prevent closure of circuit breaker when grounding switch is closed, prevent accidental entry into live isolation compartment, and prevent accidental closure of grounding switch when energized.

The seismic intensity does not exceed 8 degrees, there are no fires, no explosion hazards, and no severely polluted or intensely vibrating areas. It is mainly used for power plants, power transmission of medium and small generators, power distribution in industrial and mining enterprises, and power reception, transmission, and large high-voltage motor starting in the secondary substations of the power system, implementing control, protection, and monitoring.

China Construction International Engineering Co., Ltd., Mengniu Dairy (Chabei) Co., Ltd., Guizhou Shuicheng Mining Co., Ltd., Offshore Petroleum Engineering (Zhuhai) Co., Ltd., China Coal Pingshuo Coal Industry Co., Ltd., China Railway 12th Bureau Group Electrification Engineering Co., Ltd., etc.



GGD, MNSZ, GCK, and GCS series are AC Low-voltage Switchgear Cabinets used for Power Distribution, lighting, metering, and other purposes

Modular Design with Good Scalability

Product Introduction

- 1. MNSZ low-voltage draw-out switchgear is a combination type low-voltage switchgear equipped with standard modular units. It is suitable for power distribution systems with an AC frequency of 50 (60) Hz and a rated operating voltage of 380V and below. It is used for the control of power generation, transmission, and electrical energy-consuming equipment.
- 2. GCK series draw-out switchgear is used in AC systems with a rated frequency of 50Hz and a voltage of 380V and below. It is used for power supply, feed, reactive power compensation, centralized control of electrical energy, and motors.
- 3. GCS low-voltage draw-out switchgear serves as a complete set of low-voltage distribution equipment for three-phase AC systems with a frequency of 50Hz, a rated operating voltage of 380V, and a rated current of 4000A and below. It is used for power distribution, centralized control of motors, reactor current limitation, and reactive power compensation.
- 4. GGD type AC low-voltage distribution cabinets are suitable for distribution systems with an AC frequency of 50Hz, a rated operating voltage of 380V, and a rated operating current of up to 6300A. They are used for the conversion, distribution, and control of electrical energy for power, lighting, and distribution equipment.

Scope of Application

Suitable for industries such as power plants, petrochemicals, metallurgy, textiles, high-rise buildings, and others, it is applied in large-scale power plants, petrochemicals, and similar places with high levels of automation and requirements for computer interfaces.

Reference

Beijing Guodian Electric Power Engineering Installation Co., Ltd., Beijing Guodian Tongfang Electric Power Construction Engineering Co., Ltd., Tongcheng State Grid Electric Equipment Co., Ltd., China Sea Network Technology Service Co., Ltd., Zhongzi Technology Traffic Engineering Co., Ltd., Xianju Jiuzhou Tong Pharmaceutical Co., Ltd.







SERVICE NETWORK





After more than 30 years of development, CEEG has successively obtained the ISO9001 Quality Management System Certification, IS014001 Environmental Management System Certification, and OHSAS18001 Occupational Health and Safety System Certification, CNAS test authority. It has also passed the 3C, UL, and EU product characteristic tests, as well as multiple product certifications such as IEC, CE, and TUV.

CEEG Customer Service Hotline (025-52095855 15301592833) serves as an information communication and customer response platform. We are committed to providing feedback on customer opinions and suggestions within 24 hours. For urgent requirements such as customer maintenance and installation guidance, our sales service network covering the globe will provide immediate support and response.



an la man la mantantantantantantantantan

号 321182000201702210083



(副 本)

统一社会信用代码 9132118233888785XM (1/1)

名 称 中电电气(江苏)变压器制造有限公司

类 型 有限责任公司

住 所 镇江市扬中市中电大道188号

法定代表人 陆瀚

注 册 资 本 16000万元整

成 立 日 期 2015年04月08日

营 VIV. 期 限 2015年04月08日至*****

输配电及控制设备研发、制造、设计及其他相关技术服 经 营 范 围 务;金属制品销售;自营和代理各类商品及技术的进出 口业务(国家限定企业经营或禁止进出口的商品和技术

除外)。(依法须经批准的项目,经相关部门批准后方

可开展经营活动)



机关

والمتعادي والمتعادي والمتعادي والمتعادي والمتعادي والمتعادي والمتعادي



BUSINESS LICENSE

(Copy)

NO.321182000201702210083 Unified Social Credit Code NO.9132118233888785XM (1/1)

Name of Enterprise: China Electric Equipment (Jiang Su) Transformer Manufacturing

Co., Ltd.

Character of Economy: Limited Liability Company

Address: No.188 Zhongdian Road, Yangzhong, Zhenjiang, Jiangsu Province, China

Legal Representative: Lu Han

Registered Captical: RMB 160,000,000 Yuan

Date of Foundation: April 8,2015

Business Term: From Apirl 8,2015 to present

Business Scope: Transmission and distribution and control equipment R&D

manufacturing, design and other related technical services; Sales of metal products; Independent management and agents of all types of goods and technology import and export business (Except for state limited business or prohibited imports and exports of goods and technology). (The project that shall be subject to approval according to law, they can carry out business

activities after approved by the relevant project department)

Registration Authority: (Seal) Yangzhong City Administration for market supervision February 21,2017

This certificate is translated into English by China Electric Equipment (Jiang Su) Transformer Manufacturing Co., Ltd



Export Reference/Supply Reference till 2023

No.	Country/Area of Customer	Туре	Products	Qty	Client	Delivery Date
1	Kirghizia	Oil	1600kVA/10kV	33	Electric company of Kirghizia	2003
2	Uganda	Oil	400kVA/11kV	12	Ministry of Foreign Affair of Uganda	2003
		Oil	2500kVA/3.5kV	2		
		Oil	4000kVA/3.5kV	1		
	Nigeria	Oil	100kVA/3.5kV	20		
3		Oil	630kVA/3.5kV	8	GOMBE water factory	2004
		Oil	3150kVA/33kV	4		
		Oil	6300kVA/33	3		
		Oil	13000kVA/132	2		
		Oil	16000kVA/110kV	2		2004
		Oil	12500kVA/110kV	1	Beijing China Electric	
4	Russia	Oil	1250kVA/10kV	5	Switch Company	
		Oil	630kVA/10kV	9		
		Oil	100kVA/11kV	21	India West Mengbon	0005
		Oil	315kVA/11kV	12		
		Oil	500kVA/33kV	14		
_		Oil	800kVA/33kV	2		
5	India	Oil	1250kVA/33kV	6	Sargadighi Burned-coal	2005
		Oil	1600kVA/33kV	12	Power factory	
		Oil	2000kVA/33kV	9		
		Oil	20000kVA/33kV	2		
		Oil	50kVA/11kV	12		
		Oil	160kVA/11kV	5		
		Oil	200kVA/11kV	5	United Arab Emirates	
6	UAE	Oil	630kVA/11kV	4	Cenmetn Corporation	2006
		Oil	1600kVA/6.6kV	3	Cement Power Grinding station	
		Oil	1000kVA/6.6kV	4	station	
		Oil	12500kVA/132kV	2		
7	I/C A	Oil	2000kVA/13.8kV	7	Saudi Arabia NAJRAN	2000
/	7 KSA	Oil	630kVA/13.8kV	11	cement Company Ltd	2006



		Oil	1600kVA/13.8kV	2		
		Oil	1250kVA/13.8kV	3		
8	Guinea	Oil	630kVA/15kV	2	Guinea Double Tree project	2006
9	Surinam	Oil	200kVA/11kV	4	Surinam Embassy	2006
40		Oil	200kVA/11kV	10	Yemen Republic Electric	0000
10	Yemem	Oil	3000kVA/33kV	5	power Bureau	2006
		Oil	2000kVA/6.6kV	2		
		Oil	2500kVA/6.6kV	3] <u></u>	
44		Oil	1600kVA/6.6kV	2	China National Building	2000
11	UAE	Oil	30kVA/11kV	3	Material Equipment Co., Ltd	2006
		Oil	250kVA/11kV	1	Liu	
		Oil	25000kVA/132	2		
12	Grenada	Oil	630kVA/11kV	4	Hefei Transmission & Distribution Equipment Co.	2006
		Oil	10000kVA/110kV	2		2006
	\	Oil	630kVA/10kV	3	Vietnam Longan Water	
13	Vietnam	Oil	100kVA/10kV	1	and electricity Plant	
		Oil	50kVA/10kV	1		
		Oil	1000kVA/6kV	2	Vietnam Yuanhe Familiar	2006
14	Vietnam	Oil	1250kVA/6kV	1		
		Oil	1600kVA/6kV	1	Material Concrete Co	
15	Chile	Oil	3150kVA/23kV	1	Chile Powder Grinding	2006
15	Chile	Oil	31500kVA/110kV	1	Station	2006
		Oil	1250kVA/33KV	1		
		Oil	1500kVA/33kV	1		
16	Nigeria	Oil	2000kVA/33	1	Nigeria Northern Ishan	2006
10	ivigeria	Oil	7500kVA/33	1	Water Factory	2000
		Oil	300kVA/11kV	2		
		Oil	1000kVA/11kV	2		
		Oil	1600kVA/11kV	2	Shenzhen Rongcai	2006
17	Konyo	Oil	2500kVA/11kV	1	Electron and Technology	
''	Kenya	Oil	1250kVA/11kV	1	Development Company	
		Oil	25000kVA/132	2	Ltd.	



18	Dominica	Oil	1250kVA/11kV	4	Former Dominica Palaestra	2006
19	Tanzania	Oil	800kVA/11kV	2	China Trading Company	2006
00	Fu: ·	Oil	1600kVA/6kV	1	Hefei Cement Research	0007
20	Ethiopia	Oil	630kVA/6kV	1	Institute	2007
21	Nepal	Oil	630kVA/11kV	2	China TIESIJIU Civil Engineering Co	2007
22	Costa Rica	Oil	5000kVA/34.5kV	1	SAI MEI S.A	2007
23	Japan	Oil	1630kVA/6kV	5	TOSHIBA Co. Ltd	2007
24	Bangladesh	Oil	1000kVA/11kV	3	China National Heavy Machinery CO.	2007
25	Angola	Oil	630kVA/15kV	5	China National Electronics CO	2007
26	Angola	Dry	630kVA/15kV dry type	5	Beijing Shougang Construction Group CO.	2007
27	Angola	Dry	630kVA/15kV dry type	2	Beijing Fushunxiang Jianzu CO.	2007
		Oil	2500kVA/34.5kV	2		2007
00	140 4	Oil	3150kvA/34.5kV	2	Shanghai Pony	
28	KSA	Oil	1250kVA/34.5kV	2	Technology Co.	
		Oil	800kVA/34.5kV	2		
		Oil	2500kvA/13.8kV	4		
		Oil	800kVA/13.8kV	1		
		Oil	1600kVA/13.8kV	2	Hefei Cement Research	
29	KSA	Oil	1250kVA/13.8kV	1	Institute	2007
		Dry	100kVA/13.8kV dry	12		
		Dry	200kVA/13.8kV dry type	12		
30	Bangladesh	Oil	1250kVA/6.3kV	3	China Trading Co.	2007
31	Indonesia	Dry	1250kVA//10.5kV dry	3	Shandong machinery Equipment Group Co.	2007
		Dry	1000kVA/10kV dry type	2	T: " 0 (1 1 1	
32	Uruguay	Dry	400kVA/10kV dry type	1	Tianjin Cement Industry Institute	2007
	J ,	Dry	1600kVA/10kV dry type	2	เมอแนเษ	
33	Sudan	Oil	20000kVA/33kV	2	Hefei Cement Research Institute	2007



34	Ireland	Oil	1600kVA/11	1	Melton Power Services	2007
		Oil	2000kVA/6.6kV	1		
		Dry	160kVA/6.6kV dry type	1	China National Building	
35	Russia	Dry	30kVA/6.6kV dry type	1	Material Equipment	2007
		Dry	30kVA/6.6kV dry type	1	Corporation	
		Dry	1600kVA/10kV dry	9		
00	Б.	Dry	1000kVA/10kV dry	1	\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\	0007
36	Russia	Dry	2000kVA/10kV dry	12	WISDRI Engineering Co.	2007
		Dry	1250kVA/10kV dry	2		
		Dry	1000kVA/11kV dry	1		
37	South Africa	Dry	2000kVA/11kV dry	5	Beijing General Research	2007
		Dry	2500kVA/11kV dry	2	Institute	
38	North Korea	Oil	1500kVA/11kV	2	Elcore electrical Contractors	2007
00	Δ (!'	Dry	1250kVA/6.6kV, dry	4	Duth and Davies Dtv. Ltd	2007
39	Australia	Oil	12500kVA/33kV	1	Rutherford Power Pty Ltd	
40	Ghana	Oil	500kvA/11kV	2	Western Omega Electric Ltd.	2007
41	South Africa	Dry	1250kVA/6.6kV dry	4	Afrikaans Generator Co	2007
		Dry	1000kVA/10kV dry	3		
42	Ukraine	Dry	630kvA/6kV dry	2	Energobud-Komplict	2008
42	Ukraine	Dry	630kVA/10kV, dry	1		2006
		Dry	1250kVA/10kV dry	1		
43	UAE	Dry	1500kVA/11kV dry	2	KFB Group	2008
4.4	North Koroo	Oil	1600kVA/3.3kV	1	China trading as	2000
44	North Korea	Oil	100kVA/3.3kV	1	China trading co.	2008
4.5	Δ (!'	Oil	12500kVA/33kV	2	D (1 (1 D D) 1 (1	0000
45	Australia	Oil	3000kvA/25kV	1	Rutherford Power Pty Ltd	2008
		Dry	250kVA/6kV dry type	3		
		Dry	400kvA/6kV dry	2		
46	Russia	Dry	1000kVA/6kV dry	2	China trading Company	2008
		Dry	1500kVA/6kV dry	1	Crima trading Company	
		Dry	2000kVa/6kV dry	1		
47	Vietnam	Oil	12500kVA/2kV	2	China Trading Company	2008



		Oil	500kVA/5.5kV	3	Shangli Datra Engineering	
48	Algeria	Oil	800kVA/5.5kV,	5	Shengli Petro Engineering Com.	2008
		Oil	3150kVA/33kV	3	Com.	
49	Duccio	Oil	3500kVA/10kV	11	Danieli Officine	2000
49	Russia	Oil	2500kVA/11kV	9	Meccaniche S.P.A	2008
		Dry	160kVA/11kV dry type	2	Maputo Trading Company	
50	Mozambique	Dry	200kvA/11kV dry type	3	(Maputo International	2008
		Dry	400kVA/11kV dry	4	Airport)	
		Dry	1600kVA/11kV dry	2		
		Dry	630kVA/11.5 dry type	10		
		Dry	800kVA/11.5kV dry 4			
51	India	Dry	1600kVA/11.5kV dry	2	SEPCO III Electric Power	2009
		Dry	2000kVA/11.5kV dry	4	construction Corporation	2000
		Dry	2500kVA/11.5kV, dry	4		
52	Pakistan	Oil	60000kVA/132kV	8	Kunye Co., Ltd	2009
	Algeria	Oil	10000kVA/33kV	2	Groupment Sonatrach	2009
53		Oil	13000kVA//66	2	Project	
	South Africa	Dry	1000kVA/11kV dry type	1		2009
- 4		Dry	2000kVA/11kV dry	6	MITTAL Desvidine Dusie et	
54		Dry	1600kVA/11kV dry	2	MITTAL Deoxidize Project	
		Oil	2500kVA/11	2		
55	Afghanistan	Dry	630kVA/15kV dry type	2	Kabul Hospital Project	2009
56	Egypt	Oil	800kVA/11kV	4	- 1250MTPD Vitriol Project	2009
5	Едурі	Oil	630kVA/11kV	6	1230WII D VILIOIT IOJECL	2009
57	Angola	Dry	630kVA/15kV, dry	3	Capital Palestra Project	2009
	1	Dry	1000kVA/22kV dry	2	Capital International	0000
58	Laos	Dry	800kVA/22kV dry	2	Cabaret Project	2009
		Oil	10000kVA/15.75kV	1		
59	Bangladesh	Oil	75000kVA/132kV	4	West Bengal Burn Station	2009
		Oil	2500kvA/6.6kV	2		
60	Burma	Oil	4000kVA/33kV	3	Burma Auto Factory	2009
61	Iraq	Oil	45000kVA/33kV	2	As-Sulaymaniyah Project	2009
62	Cambodia	Oil	25000kVA/115kV	1	Ratanakiri Water Power Plant	2009
63	Bangladesh	Oil	23000kVA/33kV	2	Adex Corporation Ltd	2009



		<u> </u>				<u> </u>
64	Russia	Oil	100 kVA/10kV	1	Tianjin Cement Industry Design & Research Institute	2010
65	Albania	Oil	121kVA/37.5kV/6.3 kV, 12/15MVA	1	NDREKAJ Sh.p.k	2010
		Oil	242kVA/10.5kV, 60MVA	1		
66	Peru	Oil	2.3/66kV,12/15MVA	1	Electrica Yanapampa SAC	2010
67	Hong Kong		800kVA 11/0.4kV Silicone	1	Gason Electrical Contracting Ltd	2010
		Dry	SCR-250/1/0.415	3		
		Oil	0.415/6.6kV,750kVA	1		
		Oil	0.415/6.6kV,1000kVA	1		
		Oil	0.415/6.6kV,1500kVA	1		
70	Singapore	Dry	500kVA,11-10/0.44kV Cast Resin Transformer	1	Rutherford Power Asia Pte Ltd	2010
		Parts	BWDK-S3207A Dry Type Transformer Temperature Controller	6		
		Dry	Dry	SC-500KVA 6.6(11)0.415 KV	1	
71	Hong kong	Dry	ZSCRB10-556kVA 11kV Dry Type Rectifier Transformer	2	First-Tech Engineering Limited	2010
72	Iran	Substation	20/0.4kV,315kVA RMU type pad-mounted transformer	1	ASIA BEHIN BARQ CO.	2010
73	New Zealand	Oil	6.3/33kV, 2700kVA	1	Talla Burn Generation Limited	2010
		Oil	ZTS-1600kVA/13.5kV/2×72 0V	1		
7.		Oil	ZTS-800kVA/13.5kV/2×720 V	1	Nanjing Shengze	0040
74	Saudi Arabia	Oil	ZTS-1000kVA/13.5kV/2×72	,	Technology Co., Ltd	2010
		Oil	0V	1		
		Oil	ZTS-630kVA/13.5kV/2×720 V	1		



75	Russia	Dry	SCB10-1000kVA/6kV	2	China National Machinery IMP. & EXP. Co. , Ltd	2010
76	Kazakhstan	Parts	Transformer Spare Parts		Tianjin Shiming Machinery & Electrical Spare Parts Co., Ltd	2010
		Oil	13MVA/66kV	1	SINOPEC International	
77	Algeria	Parts	4TS Monitor	1	Petroleum Service Corporation	2010
78	Jordan	Dry	SCB	9	SEPCOIII Electrical Power Construction Corporation	2010
79	Indonesia	Switchgear	High Voltage On-load Switcher HXGN-12	1	China National Machinery IMP. & EXP. Co. , Ltd	2010
80	North Korea	Oil	SZ9-1000kVA/3.3kV/0.38k V	1	Dandong Ji Li Trading Co., Ltd.	2010
81	Nepal	Dry	SCB10-500KVA/11kV	1	China Jiangxi Corporation for International Economic and Technical Corporation	2010
		Dry	SCB10-800kVA/10kV	2	- Dalian East New Energy Development	2010
		Dry	SCB10-1250kVA/10.5kV/0.4 KV	3		
82	Philippine	Dry	SCB10-1000kVA/10.5kV/0.4 KV	1		
		Dry	SCB10-800kVA/10.5kV/0.4K V	1		
83	Uganda	Dry	SGZ(B)-1250kVA	2	Yan Jian Group	2010
	Oganda	Switchgear	Low Voltage Switch Box	22	ran dan Group	2010
84	India	Dry	SCB9-1600kVA-6kV/0.4kV	1	Anhui Masteel K.Wah New Building Materials Co., Ltd	2010
85	Haanda	Oil	SRN11-1000kVA	3	Peak International Trading	2010
	Uganda	Oil	SRN11-500kVA	5	Co., Ltd	2010
86	Peru	Dry	SCB9-500kVA	1	Yan Jian Group	2010
07	Congo	Switchgear	Low Voltage Incoming Cabinet AA1	1	Weihai International	2040
87		Switchgear	Capacitor Box	1	Economic & Technical Cooperative CO., Ltd	2010
		Switchgear	Low Voltage Outgoing	2	Ocoporative CO., Liu	



		Switchgear	Cabinet AA3/AA4	2		
		Dry	SCB10/20kV/500kVA	1		
		Parts	Seal Bus Duct	1		
00	D .	Dry	SC(B)9-400kVA/11kV/0.20 8kV	2		
88	Bahamas	Dry	SC(B)9-800kVA/11kV/0.20 8kV	2	Shandong Hi-speed Qi Lu	2010
89	Peru	Oil	2.3/66KV, 12/15MVA step-up	1	Group CO., Ltd	2011
		Oil	S11-800/6.6	4		
		Oil	S11-1000/6.6	3		
	90 India	Oil	S11-1600/6.6	8		
		Oil	S11-2000/6.6	2	Tianjin Cement Industry Design & Research Institute	
		Oil	S11-1600/6.9	1		2011
90		Oil	ZTS11-1000/6.6	1		
90		Oil	ZTS11-1600/6.6	1		2011
		Dry	SC10-20/415	7		
		Dry	SC10-30/415	6		
		Dry	SC10-50/415	1		
		Dry	SC10-100/6.6KV	1		
		Dry	SC10-200/415	1		
		Dry	SCB10-315/6.3	2		
		Dry	SCB10-800/6.3	2		
91	Indonesia	Dry	SCB10-1000/6.3	6	Qingdao Jieneng Power	2011
		Dry	SCB10-1250/6.3	8	Engineering Co., Ltd	
		Substation	YB-800KVA/20/0.4	1		
		Switchgear	LV Incoming Cabinet	1	Weihai International	
92	Congo	Switchgear	LV Outgoing Cabinet	2	Economic and Technical	2011
		Parts	Capacitor	1	Cooperative Co., Ltd	
		Oil	S11-630/6.6	4		
		Oil	S11-1600/6.6	3	Tianjin Cement Industry Design & Research	
93	Malaysia	Oil	S11-1250/6.6	8		2011
		Oil	S11-2000/6.6	2	Institute	
		Oil	S11-1000/6.6	1		



		Oil	S11-800/6.6	1		
		Switchgear	Load Break Switch	1		
94	Albania	Oil	242/13.8KV,150MVA	1	China Electric Equipment Group Hong Kong Co., Ltd	2011
		Dry	SC10-5000/10 10±2X2.5%/3.3 Dyn11 UK=7%	5		
		Dry	SCB10-2000/10 10±2X2.5%/0.4 Dyn11 UK=6%	20		
		Dry	SCB10-1600/10 10±2X2.5%/0.4 Dyn11 UK=6%	4		
		Dry	SCB10-1600/10 10±2X2.5%/0.4 Dyn11 UK=4%	4		
		Dry	SCB10-1250/10 10±2X2.5%/0.4 Dyn11 UK=6%	3		
95	Korea	Dry	SCB10-1000/10 10±2X2.5%/0.4 Dyn11 UK=6%	1	LS Group	2011
		Dry	SCB10-630/10 10±2X2.5%/0.4KV Dyn11 UK=6%	2		
		Dry	SCB10-800/10 10±2X2.5%/0.44KV Dyn11 UK=6%	1		
		Dry	SC10-3000/10.5 10.5±2X2.5%/3.3KV Dyn11 UK=6%	1		
		Dry	SCB10-2500/10 10.5±2X2.5%/0.4KV Dyn11 UK=6%	1		
		Dry	SCB10-1000/10.5 10.5±2X2.5%/0.4KV Dyn11 UK=6%	1		



			SCR40 900/40 F			
		Dry	SCB10-800/10.5 10.5±2X2.5%/0.4KV Dyn11 UK=6%	2		
		Dry	SCB10-2000/10 10±2X2.5%/0.4 Dyn11 UK=6%	2		
96	Russia	Parts	Circuit Breaker	2	Zhejiang CHINT Group	2011
		Oil	0.44/0.11kv, 10kva	2		
07	T b = 3 = d	Oil	0.44/0.24kv, 15kva	8	China Electric Equipment	0044
97	97 Thailand	Oil	0.44/0.24kv, 80kva	2	Group Hong Kong Co., Ltd	2011
		Oil	0.44/0.24kv, 100kva	4		
		Dry	SCB10-2000KVA6.3/0.4KV	9		
	Russia	Dry	SCB10-1600KVA 6.3/0.4KV	8	- Tianlangxing Power Plant Equipment Co., Ltd	
		Dry	SCB10-1250KVA 6.3/0.4KV	2		
98		Dry	SCB10-1000KVA 6.3/0.4KV	4		2011
		Dry	SCB10-800KVA 6.3/0.4KV	2		
		Dry	SCB10-630KVA 6.3/0.4KV	2		
		Dry	DKSC-200KVA6.3/0.4	2		
99	Albania	Oil	121/6.3KV, 12/15MVA	1	China Electric Equipment Group Hong Kong Co., Ltd	2011
		Oil	0.44/0.11kv, 10kva	2		
400	Th - 2	Oil	0.44/0.24kv, 15kva	8	China Electric Equipment	2011
100	Thailand	Oil	0.44/0.24kv, 80kva	2	Group Hong Kong Co., Ltd	
		Oil	0.44/0.24kv, 100kva	4		
101	Malaysia	Oil	S11-630/6.6	1	Tianjin Cement Industry	2011



		Oil	S11-1600/6.6	2	Design & Research	
		Oil	S11-1250/6.6	4	Institute	
		Oil	S11-2000/6.6	2		
		Oil	S11-1000/6.6	1		
		Oil	S11-800/6.6	1		
102	Australia	Oil	S11-2000KVA-11/0.42KV	2	China Electric Equipment	2011
		Oil	S11-1500KVA-11/0.42KV	2		
		Oil	S11-1000KVA-11/0.42KV	1	Group Hong Kong Co., Ltd	
		Oil	S11-1000KVA-11/0.725KV	3		
103	Hong Kong	Dry	1500KVA 11/0.38KV	2	China Electric Equipment Group Hong Kong Co., Ltd	2011
104	Peru	Parts	2.3KV bushings	3	China Electric Equipment Group Hong Kong Co., Ltd	2011
105	Taiwan	Parts	Amorphous Alloy Iron Core	44	China Electric Equipment Group Hong Kong Co., Ltd	2011
106	Laos	Oil	S-4000KVA-11/0.69KV	1	China Electric Equipment Group Hong Kong Co., Ltd	2011
107	Australia	Oil	SFZ-25000KVA-66/11KV	1	China Electric Equipment Group Hong Kong Co., Ltd	2011
		Substation	Substation 30KVA	6		
		Substation	Substation 50KVA	21		
		Substation	Substation 160KVA	1		
		Substation	Substation 250KVA	1		
		Substation	Substation 315KVA	4		
		Substation	Substation 400KVA	5		
		Substation	Substation 500KVA	7		
		Substation	Substation 630KVA	2		
108	Venezuela	Switchgear	Outdoor High Voltage Vacuum Circuit Breaker ZW()-15(D)/630-25	3	China CAMC Engineering Co., Ltd	2011
		Parts	Lightning Arrester YH5WS-17/50	3		
		Oil	S11-M-800/13.8	2		
		Oil	S11-M-1250/13.8	1		
		Parts	Copper Busbar TMY-80×10	90		



		Parts	Copper Busbar TMY-63×10	30		
109	Hong Kong	Oil	S-2000KVA-11/0.38KV	6	China Electric Equipment Group Hong Kong Co., Ltd	2011
110	Hong Kong	Oil	600KVA 11/0.412KV Silicone	1	China Electric Equipment Group Hong Kong Co., Ltd	2011
111	Hong Kong	Oil	550KVA 380/420V	1	China Electric Equipment Group Hong Kong Co., Ltd	2011
112	Hong Kong	Oil	SFZ-25000KVA-66/11KV	1	China Electric Equipment Group Hong Kong Co., Ltd	2011
		Oil	S11-1250/11	1	Dailing HANCOM Trading	
113	Nigeria	Oil	S11-2500/33	1	Beijing HANSOM Trading Co., Ltd	2011
444	11 1	Oil	S9-2500/10	9	Danieli&C.Officine	0044
114	Italy	Oil	S9-3500/10	11	Meccaniche S.p.A	2011
		Oil	S10-800/5.5	1		2011
		Oil	S10-900/5.5	1		
115	Algeria	Oil	S10-10000/30	2	GROUPEMENT	
113		Oil	S10-13000/66	2	SONATRACH-SINOPEC	
		Oil	S10-400/30	1		
		Oil	S10-50/30	1		
		Dry	SCB-160KVA	2		
		Dry	SCB-250KVA	1		
		Dry	SCB-1600KVA	1	01: 0440 5 : :	
116	Venezuela	Dry	SCB-1250KVA	1	Co. Ltd.	2012
		Dry	SCB-1250KVA	1	Co., Ltd	
		Substation	Substation 400KVA	1		
		Substation	Substation 800KVA	1		
		Dry	1000KVA 13.8/0.48KV, Dyn5	2		
117	Columbia	Dry	2000KVA 13.8/0.48KV, Dyn5	2	China Electric Equipment Group(HK)Ltd	2012
		Dry	2500KVA 13.8/0.48KV, Dyn5	4		



		1				
		Dry	2500KVA13.8/0.69KV, Dyn5	2		
		Oil	100000/12500KVA 34.5/13.8KV, Dyn 5	2		
118	Russia	Substation	Complete transformer substation 35/6 kV	2	China Electric Equipment Group (HK) Ltd	2012
119	Tanzania	Dry	SCB10-3150/10/0.45	1	The ABB Group	2012
		Dry	SG10-2000-25 13.2/0.6kv	1		
		Dry	SG10-5000-25/4.16KV	5		
		Dry	SG10-3000-25/4.16KV	13		
120	Australia	Dry	SG10-3000-25/0.6KV	20	Rio Tinto Group	2012
		Dry	SG10-3000-13.2/0.6KV	4		
		Dry	SG10-5000-25/13.2KV	2		
		Dry	SG10-2000-25/0.6kv	7		
	Equatorial Guinea	Oil	S11-M-400/20/0.4	1	OOOO First Hards are	2012
121		Oil	S11-M-1250/20/0.4	2	CCCC First Harbor	
		Oil	S11-M-800/20/0.4	2	Engineering Company Ltd	
122	Indonesia	Oil	S11-1600kva/10kv	1	SINOMA International Engineering Co., Ltd	2012
		Dry	CSD-2000/0.69	2	The ABB Group	
123	Hongkong	Dry	CSD-225/0.48	2	The ABB Group	2012
		Dry	CSD-125/0.48	1	The ABB Group	
124	Canada	Dry	SGB10-3000/25	6	The ABB Group	2012
		Dry	CSD-2000/0.69	2	The ABB Group	
		Dry	CSD-1200/0.69	2	The ABB Group	
		Dry	CSD-500/0.69	2	The ABB Group	
125	Hongkong	Dry	CSD-450/0.44	2	The ABB Group	2013
		Dry	CSD-150/0.44	1	The ABB Group	
		Dry	CSD-80/0.69	2	The ABB Group	
		Dry	CSD-30/0.44	4	The ABB Group	
		Dry	CLSD-100/0.44	16	The ABB Group	
126	Hongkong	Dry	CLSD-75/0.44	8	The ABB Group	2013
		Dry	CLSD-270/0.44	8	The ABB Group	
127	Azerbaijan	Oil	S11-M-1250/10	3	China non-ferrous	2013
121	nzo Daljali	Oil	S11-M-1600/10	1	Construction	2013



		Oil	ZS11-900/10	1		
		Oil	ZSS11-900/10 ZSS11-M-1800/10	2		
		Oil	ZSS11-M-6200/10	1		
		Dry	SCB11-1250/10	4		
		Dry	SCB11-1600/10	2		
		Dry	ZSCB10-1800/10	1		
128	Yemen	Oil	33/0.4KV,400kVA	5	Yemen Utilities	2013
		Oil	S11-M-630/10/0.4 Dyn11±2x2.5%4.5%	2		
400		Oil	S11-M-1250/10/0.4 Dyn11±2x2.5%4.5%	2	Tianjin Cement Industry	0040
129	Indonesia	Oil	S11-M-1600/10/0.4 Dyn11±2x2.5%4.5%	2	Design & Research Institute	2013
		Switchgear	FN3-10/400 On-load Switch	6		
130	Russia	Substation	Complete transformer Substation 4000kva/35/6	2	Russia Petroleum	2013
131	Iran	Oil	S11-1600/6KV	2	Sinoma	2013
132	Congo	Oil	S11-M-1250/10	1	Sinoma-Heidelberg Congo	2013
		Oil	S11-M-1000/10	2		
133	Indonesia	Oil	S11-M-1250/10	2	Sinoma	2013
		Switchgear	On- load switch	2		
134	Indonesia	Substation	YB-2500/6.6/0.4 Substation	1	Heidelberg	2013
135	Malaysia	Dry	SCB10-1250/6.6/0.433	6	Sinoma	2013
		Dry	CSD-2000/0.69/0.44	4		
		Dry	CSD-1500/0.69/0.44	4		
		Dry	CSD-500/0.69/0.44	4		
136	Hongkong	Dry	CSD-450/0.69/0.44	4	ABB	2013
		Dry	CSD-150/0.44/0.23	4		
		Dry	CSD-112.5/0.44/0.23	2		
		Dry	CSD-100/0.44/0.23	4		



			000 00/0 44/0 00	_		
		Dry	CSD-30/0.44/0.23	8		
		Dry	ZSS-6200/13.8/0.75/0.75	1		
407	Venezuela	Dry	ZSS-1800/13.8/0.66/0.66	1	China Nonferrous Metals	22.42
137		Dry	ZSCB10-1800/13.8/2x0.66	1	Processing Technology	2013
		Dry	ZSCB10-900/13.8/0.66	1		
		Dry	SCB10-1600/13.8/0.48	1		
138	Azerbaijan	Oil	SZ9-16000/110	1	DEL.AL ALUMINIUM LLS	2013
		Oil	S11-M-1600/10	2		
139	Burkina Faso	Oil	S11-M-630/10	1	Sinoma-Heidelberg	2013
		Oil	SFZ11-8000/33	1		
140	Ghana	Oil	S11-M-2000/10	1	Tianjin Cement Industry Design & Research	2013
					Institute-Heidelberg	
141	Russia	Substation	YB-2x6300KVA/35/6	1	Russia Petroleum	2013
		Oil	ZTS-700/11	2		
142	Nigeria	Oil	ZTS-1300/11	5	Nanjing Shengze Science	
		Oil	ZTS-2500/11	2		
112	Zambia	Oil	ZTS-700/11	2	and Technology	2013
143		Oil	ZTS-1300/11	2	und reenhology	
111	Comoroun	Oil	ZTS-2500/11	2		
144	Cameroun	Oil	ZTS-700/11	1		
145	Saudi Arabia	Oil	ZTS-1300/11	3	Nanjing Shengze Science	2012
145	Sauui Arabia	Oil	ZTS-2500/11	1	and Technology	2013
		Dry	SCB-1000,Dyn11,6.0±2x2. 5/0.4	2		
		Dry	SCB-200,Dyn11,6.0±2x2.5/ 0.4	5	Tion Louis Visus Double	
146	Russia	Dry	SCB-2500,Dyn11,6.0±2x2. 5/0.4	2	Tian Lang Xing Power Station Equipment	2014
		Dry	SCB-800,Dyn11,6.0±2x2.5/ 0.4	3	- CO,LTD	
		Dry	SCB-630,Dyn11,6.0±2x2.5/ 0.4	4		
117		Oil	11kV/0.38kV,2.5MVA Transformer+6/-2x2.5%	2	CHEVALIER(ENVIROME	2044
147	Hong Kong	Oil	11kV/0.38kV,2MVA Transformer+6/-2x2.5%	2	NT)LIMITED	2014
		•				



			T			
		Oil	11kV/0.38kV,1.5MVA Transformer+6/-2x2.5%	6		
			11kV/0.38kV,1.5MVA			
		Oil	Transformer+6/-2x2.5%	2		
148	Burkina Faso	Oil	S11-8000KVA/33/10KVA	1	Heidelberg	2014
149	Canada	Dry	SG10-3000-25/13.2/0.6kV	1	KMP	2014
		Oil	Transformer 500KVA 0.4/0.48KV	1		
		Dry	CSD-1000KVA/0.69/0.44KV	2		
		Dry	CSD-400KVA/0.69/0.44KV	2		
150	Sweden	Dry	CSD-2000KVA/0.69/0.482K V	2	ABB	2014
		Dry	CSD-225KVA/0.69/0.44KV	2		
		Dry	CSD-125KVA/0.69/0.44KV	1		
		Dry	CSD-99KVA/0.69/0.44KV	2		
		Dry	CSD-22.5KVA/0.69/0.44KV	1		
		Dry	CSD-10KVA/0.69/0.44KV	1		
		Dry	CSD=2500KVA/0.44/0.22KV	4	АВВ	2014
		Dry	CSD-160KVA/0.44/0.22KV	2		
151	Sweden	Dry	CSD-100KVA/0.44/0.22KV	2		
		Dry	CSD-120KVA/0.44/0.22KV	1		
		Dry	CSD-80KVA/0.44/0.22KV	1		
152	Albania	Oil	220/115/37.6KV,120MVA Autotransformer	1	EnBi Power Sh.p.k	2014
153	Ghana	Dry	SCB10-11/0.44KV-1000KV A	1	Jiang Xi International	2014
		Dry	SCB-11/0.44KV-800KVA	1	CO.,LTD	
154	Peru	Dry	KBSGZY2-T-50KVA/4.16/0 .46KV	1	Genera,LLC.	2014
155	Philippine	Oil	S11-2000KVA/4.16KV	1	Libo International Mechanical & Electrical Engineering Co.,LTD	2014
156	Philippine	Oil	S11-1000KVA/4.16KV	1	Libo International Mechanical & Electrical Engineering Co.,LTD	2014



		0:1	C44 250012/1/2012/	4		
157	Philippine	Oil	S11-3500KVA/33KV	1	LAFARGE	2014
450	DL:::'	Oil	S11-M-400/10	1	LAFADOF	0044
158	Philippine	Oil	ZTS-850KVA/2.3	1	LAFARGE	2014
159	Philippine	Oil	S11-M750KVA	1	LAFARGE	2014
160	Philippine	Oil	S11-1000/10	1	SINOMA	2014
		Oil	S11-2000/11KV	1		
161	Indonesia	Oil	S11-1600/11KV	1	Heidelberg	2014
		Oil	S11-1250KV/11KV	1		
		Oil	S11-1000KVA/11KV	1		
		Oil	S11-2000/11KV	1		
		Oil	S11-1600/11KV	2		
162	Kazakhstan	Oil	S11-1250/11KV	3	SINOMA	2014
		Oil	S11-1000/11KV	1		
		Oil	S11-800/11KV	2		
163	Malaysia	Oil	S11-1250KVA/6.6KV	1	SINOMA	2014
164	Malaysia	Oil	ZSS-1000KVA/6.6KV	1	SINOMA	2014
		Oil	S11-2500/6		Kazakhmys Aktogay	2014
165	Kazakhstan			1	LLC-Branch office of	
					Kazakhmys Projects B.V.	
166	Congo	Oil	ZTS-1300	2	Nanjing Shengze Science	2014
	55.1g5	Oil	ZTS-600	2	and Technology Co.Ltd,.	
167	Mozambique	zambique Oil ZTS-1500	ZTS-1500	1	Nanjing Shengze Science	2014
107	MOZambique	Oii	210-1000	ı	and Technology Co.Ltd,.	2014
166	Malaysia	Oil	ZSS-1000/6.6	1	SINOMA	2014
167	Hong Kong	Dry	CSD-50/0.69/0.69	4	ABB (Hong Kong) Limited	2015
		Oil	S11-1600KVA/13.8KV/0.46	1		
169	Saudi Arabia	Oii	KV	<u>'</u>	Nanjing Shengze Science	2015
103	Saudi Alabia	Oil	ZTS-1300KVA/13.5KV/2*7	1	and Technology Co.Ltd,.	2010
		J II	20V	'		
		Oil	ZTS-1600/11/2×2.2Dy11d0	1		
170	Saudi Arabia		±3×2.5%6%		Nanjing Shengze Science	2015
		Oil	ZTS-2500/11/2×2.2Dy11d0	2	and Technology Co.Ltd,.	2010
			±3×2.5%6%			
171	Saudi Arabia	Oil	ZTS-1600KVA/13.8KV/2*7	1	Beijing Datuo technology	2015
			20V	_	development Co.Ltd,.	
172	'2 Hong Kong	CSD-1000KVA	2	Shanghai ABB	2015	
	,	Dry	CSD-80KVA	2	engineering Co.Ltd,.	



		1			
	Dry	CSD-250KVA	2		
	Dry	CSD-100KVA	1		
	Oil	S11-2000kVA/6.6kV	3		
	Oil	S11-1500kVA/6.6kV	9		
Malaysia	Oil	S11-1000kVA/6.6kV	1	SINOMA	2015
	Oil	S11-800kVA/6.6kV	1		
	Oil	S11-630kVA/6.6kV	1		
UAE	Oil	S11-M-1250/10	1	Sinoma energy conservation Co., LTD	2015
	Dry	SCH15-30/10 (245kg)	8	NANYA/ELLEL	
Taiwan	Dry	SCH15-30/10 (215kg)	8		2015
	Dry	SCH15-30/10 (644kg)	10	CO.,LIQ	
Malaysia	Oil	S11-M-1000/10	1	LAFARGE ILIGAN, INC.	2015
Taiwan	Dry	SC(R)BH15-2000/10	1	Frank & Associates Plastic Co.,Tld	2015
	Dry	CSD-800	2	ADD (III IX)	
Hong Kong	Dry	CSD-400	4	\ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \	2015
	Dry	CSD-300	1	Limited-No97	
Norway	Oil	SZ11-10500/70	1	SCANCEM INTERNATIONAL DA	2015
Albania	Oil	115/37/10.5KV, 31.5MVA	1	NDREKAJ Sh.p.k	2016
Hong Kong	Oil	CS(W/F)D-4000/6.6/0.45	2	ABB (Hong Kong) Limited	2016
Nicerogue	Oil	S11-1600	1	Schneider Electric (China)	2016
inicaragua	Oil	S11-630	1	Co.,Ltd.	2016
Indonesia	Oil	S11-M-2000/10	1	1	2016
Malaysia	Oil	S11-M-2000/10	1	1	2016
Albania	Oil	110/37.5/10.5KV, 15MVA	1	EnDi Dowar Shin k	2016
Albania	Oil	110/20.8KV, 40/50MVA	1	Elibi Power Sii.p.k.	2010
	Parts	BWY802	1		2016
Togo	Parts	BWY804	1	SCANCEM	2016
	Parts	AVR	1		2016
Dhilipping	Dry	SCB10-1000/4.16/0.44	1	Holeim Philippines Inc	2016
ı milphine	Dry	SCB10-2000/4.16/0.44	1	Holoiti Hillippines, IIIC	2010
Irap	Oil	S11-1000/6	1	1	2016
Saudi Arabia	Dry	SGBH15-800/13.8/0.4	4	1	2016
Malaysia	Dry	SCB10-1000/11/0.433	4	EWT Transformer Sdn Bhd	2016
	UAE Taiwan Malaysia Taiwan Hong Kong Norway Albania Hong Kong Nicaragua Indonesia Malaysia Albania Togo Philippine Irap Saudi Arabia	Dry Oil Oil	Dry CSD-100KVA	Dry CSD-100KVA 1	Dry CSD-100KVA



464	DI III I	Dry	SCB10-1250/11/0.48	2	/	0040
191	Philippine	Dry	SCB10-2500/11/0.48	2	1	2016
		Dry	SCB10-2000/10/0.4	4		
		Dry	SCB10-1600/10/0.4	1		
192	Burma	Dry	SCB10-1250/10/0.4	1	/	2016
		Dry	ZSCB10-1400/10/0.6	1		
		Dry	SCB10-1000/10/0.4	1		
193	Vietnam	Oil	S11-1250/22	1	1	2016
194	Philippine	Dry	ZSCB10-1800/4.16/0.72*2	1	New Sporot Enterprises (H.K) Company Limited	2016
195	Philippine	Dry	ZSCB10-650/4.16/0.72	2	1	2016
400	Б.	Oil	S11-M-1500/6.3	1	/	2016
196	Russia	Oil	S11-M-2000/6.3	1	1	2016
107	Dhilinnin	Dry	SCB10-1600/11/0.48	2	1	2017
197	Philippine	Dry	SCB10-2500/11/0.48	2	1	2017
198	America	Dry	SGB10-1000/13.8/0.48	1	Australasian Power Equipment Pty Ltd	2017
400	D	Dry	SCB10-630/10/0.4	1		2017
199	Burma	Dry	SCB10-800/10/0.4	1	/	2017
200	Namibia	Oil	SZ11-8000/66	1	1	2017
		Oil	SZ11-16000/66	1		2017
201	Hong kong	Dry	CSD-50/6.6/0.45	2	ABB (Hong Kong) Limited	2017
202	Tanzania	Oil	S11-2500kVA/3.3kV	1	1	2017
203	Namibia	Oil	SZ11-10000/66	1	1	2017
		Oil	S11-M-630/10	1	(WHALE ROCK	2017
204	Namibia	Oil	S11-M-1250/10	1	CEMENT(PROPRIETARY) LTD.	2017
205	Albania	Oil	220/115/37.6KV, 120MVA	1	EnBi Power Sh.p.k.	2017
206	Lucky	Oil	S11-800/6	1	PT LUCKY AL-SHUMOOKH HOLDING LIMITED	2017
207	Kyrgyzstan	Substation	YB-1250	1		2017
208	Hong Kong	Dry	SCB10-1500/11/0.38	2	SE Electric (HK) Limited	2017
200	Hann War	Dry	CSD-50	1	CSUN-SOLAR	2017
209	Hong Kong	Dry	CSD-30	1	INTERNATIONAL	2017



		Dry	CSD-25	2	LIMITED-N596	2017
		Dry	CSD-10	1		2017
210	UAE	Oil	S11-M-1600/6.3	1	1	2017
211	Brunei	Oil	SZ11-5500/11	1	BUTRA HEIDELBERGCEMENT SDN BHD	2017
		Dry	CSD-50	1		2017
242	lang kang	Dry	CSD-30	1	CSUN-SOLAR	2017
212 F	Hong kong	Dry	CSD-25	2	INTERNATIONAL LIMITED-N706	2017
		Dry	CSD-10	1		2017
213	Lucky	Oil	S11-2000/6.6	1	1	2017
		Oil	S11-2000/33/0.55	3		2017
214	Namibia	Oil	S11-2000/33/6.6	2	Swakop Uranium (Pty) Ltd	2017
		Oil	S11-5000/33/6.6	1		2017
215	Pakistan	Dry	ZGS11-Z.G-11/0.48-1250	10	Adhikot District Khushab Pakistan 12M Grid connected photovoltaic power generation project	2017
216	Pakistan	Switchgear	Low voltage cabinet	1	Adhikot District Khushab Pakistan 13M Grid connected photovoltaic power generation project	2017
217 I	Philippine	Dry	SCB10-1500/3.3	1	Holcim Philippines, Inc.	2017
218	Cameroon	Dry	DKSC-125/6	1	CIMENCAM Cameroon	2017
219	Uganda	Dry	DKSC-250/11	1	Uganda grinding station project	2017
220 C	ote d'Ivoire	Oil	SZ11-5000/33	2	Total drop transformer for Cote d'Ivoire grinding station	2017
		Oil	S11-1000/10	2	Total drop transformer for	2017
221 C	ote d'Ivoire	Oil	S11-1600/10	1	Cote d'Ivoire grinding station Total drop transformer for	2017
					Cote d'Ivoire grinding station	
222	Philippine	Dry	SC10-250kva/4.16/0.44kv	1		2017



		Dry	DC10-50/0.44/0.22	5		2017
223	Namibia	Oil	SZ11-16000/66	1	1	2018
004	Papua New	Oil	S11-1000/11	1	ADEO	0040
224	Guinea	Oil	S11-500/11	1	APEQ	2018
		Oil	S11-1000/10	1		
225	Namibia	Oil	S11-1250/10	1	/	2018
		Oil	S11-1600/10	1		
226	Iraq	Oil	S11-100/33/0.415	10	1	2018
227	Australia	Oil	S11-1500/11	1	APEQ	2018
228	Namibia	Oil	S11-2000/33	2	SWAKOP	2018
229	Vietnam	Oil	S11-M-1000/6.3	1	VCM WHG PROJRECT	2018
230	Vietnam	Oil	S11-M-800/6.3	2	SG WHG PROJRECT	2018
231	Indonesia	Oil	S11-500/6.3	1	Sinoma,Tianjin Cement Industry Design and Research Institute Co.,Ltd.	2018
		Oil	ZTS-600	3	Nauiiaa Obaaaaa Oaiaaa	2018
232	Nigeria	Oil	ZTS-700	1	Nanjing Shengze Science and	
232		Oil	ZTS-1300	1	Technology Co.Ltd,.	
		Oil	ZTS-2500	1	recombined y co.Eta,.	
233	Donus Now	Switchgear	8DJH -RRLL 12KV	2	OK TEDI MINING	
234	Papua New Guinea	Switchgear	8DJH -RRLL 24KV	2	(APEQ)	2018
235	Guirlea	Switchgear	8DJH -RRLL 24KV+DC	2	(ALQ)	
236	Bangladesh	Oil	SZ11-9500KVA/33KV	1	CNBM	2018
237	Bangladesh	Oil	S11-M-1000/6.3	1	China Heavy Machinery Co., Ltd	2018
238	Philippines	Substation	YB-1500/13.8	1	1	2018
239	Burkina Faso	Oil	S11-M-1600-10/0.4KV	1	CIMBURKINA S.A	2018
240	Massiaa	Dry	SCB10-500-13.2/0.4	2	Duion Nove France	2040
240	Mexico	Switchgear	GGD	2	Ruian New Energy	2018
241	Papua New Guinea	Parts	HV isolators	13	OK TEDI MINING (APEQ)	2018
		Dry	SCB10-250/0.44/0.22	1		
242	Philippines	Dry	SC10-50/0.44/0.22	2	Holcim Philippines, Inc.	2018
		Dry	DC10-50/0.44/0.22	1		



243	Zambia	Oil	ZTS-1300/11	1	Nanjing Shengze Science and Technology Co.Ltd,.	2019
		Oil	S11-630/6	1	Sinoma, Tianjin Cement	
0.14	5	Oil	S11-800/6	1	Industry Design and	0040
244	Pakistan	Oil	S11-1250/6	1	Research Institute	2019
		Oil	S11-1600/6	4	Co.,Ltd.	
		Oil	S11-M-800/11/0.4KV	1		
		Oil	S11-M-1250/11/0.4KV	1	1 I	
245	Bangladesh	Oil	S11-M-1600/11/0.4KV	1	China Heavy Machinery	2019
		Oil	S11-M-1600/11/0.4KV	2	Co., Ltd	
		Oil	S11-M-2000/11/0.4KV	1		
0.40		Oil	20.8/0.4KV, 250KVA	2	5 B: B OL I	0040
246	Albania	Oil	110/20.8KV, 40/50MVA	2	EnBi Power Sh.p.k.	2019
247	Swiss	Dry	SC-80KVA-0.315/0.4	1	MATTDAMON	2019
248	Canada	Dry	SG-24.94/13.2/0.6KV 1MVA	2	Rio Tinto Alcan	2019
249	Chile	Dry	SCB10-500KVA-4.16/0.4 (Outdoor Type)	1	Albemarle Corporation	2019
250	Saudi Arabia	Oil	S11-1250kVA-13.8/0.5kV	1	CNBM KIVAY International Engineering Co., Ltd	2019
251	Hong Kong	Dry	SCB10-1500/11/0.38	2	ATAL	2019
252	Libya	Oil	S11-M-2000/6.6	1	Sinoma,Tianjin Cement Industry Design and Research Institute Co.,Ltd.	2019
		Oil	SFZ11-16000/110	2		
050		Oil	S13-M-100/10.5	1],,	0040
253	Tajikistan	Oil	S13-M-50/35	1	Yanjian Group Co., Ltd.	2019
		Oil	S13-M-100/6	1		
254	Mozambique	Dry	SGB10-2000/22/0.433 Substation	1	APEQ	2019
		Oil	ZTS-1200	1		
055	la de u	Oil	ZTS-600	1	Nanjing Shengze Science	2019
255	Indonesia	Oil	ZTS-800	2	and Technology	
		Oil	ZTS-900	1		



		Oil	ZTS-2000	1		
256	Philippines	Oil	SFZ-12000/69	1	CRH	2019
257	Philippines	Oil	S11-300/3.3/0.22	1	CRH	2019
258	Trinidad & Tobago	Dry	SCB10-1500/3.3/0.48	2	CEMEX	2019
259	Mexico	Switchgear	Electrical Power Outlets	47	CEMEX	2019
260	Canada	Dry	SGB-3000/25-13.2/0.6	1	Rio Tinto Alcan Inc	2019
261	Dubai	Oil	S11-M-1600/11/0.4KV	2	China Heavy Machinery Co., Ltd	2019
262	Bangladesh	Oil	S11-1250	1	China Heavy Machinery Co., Ltd	2019
263	UAE	Oil	SFZ11-25000/33	1	Sinoma Energy	2019
203	UAL	Oil	S11-M-2000/6.6	2	Conservation Limited	2019
264	Papua New Guinea	Switchgear	8DJH -DC+RLLL 12KV -013	1	OK TEDI MINING (APEQ)	2019
265	Brunei	Parts	SZ11-5500/11 Transformer Fans	2	BUTRA HEIDELBERGCEMENT SDN BHD	2019
266	Togo	Oil	4MVA 20KV/10.5KV	1	CIMTOGO S.A.	2019
267	Malaysia	Dry	SCB10-3150-33/0.415	2	Intco Malayia Sdn.Bhd	2019
268	India	Dry	ZPSG-488/6.6	2	ABB India Limited	2019
269	India	Dry	ZPSGL-888/11	2	ABB India Limited	2019
270	India	Dry	ZPSG-563/11	3	ABB India Limited	2019
271	India	Dry	ZPSGL-625/6.6	1	ABB India Limited	2019
272	Papua New Guinea	Switchgear	8DJH -DC+RLLL 12KV -014	1	OK TEDI MINING (APEQ)	2019
273	Philippines	Dry	SCB10-2000/13.8	1	CH Asia World of Electric Inc	2019
274	Brunei	Oil	S11-1000-6/0.4KV	2	BUTRA HEIDELBERGCEMENT	2019
	Didilo	Oil	S11-500-6/0.4KV	1	SDN BHD	
275	Pakistan	Dry	SCB11-2500/11/0.42KV	2	China BOQI	2019
		Dry	SCB11-2000/6KV	2		
276	Bolivia	Dry	SCB11-10000/24.9/6	1	CMEC	2019
		Dry	SCB11-2500/6	3		



277	England Ireland Finland Turkey Columbia Greece	Dry	SGB10-335/6.6/0.4KV (Batch Basis)	16	Rainbow-Cargotec Industries Co.,Ltd	2019
278	Philippines	Oil	S11-1000KVA, 4160/440V	1	REPUBLIC CEMENT MINDANAO, INC	2019
279	Tanzania	Parts	SPARES FOR LV TRANSFORMERS PL4	4	Tanzania Portland Cement Public Limited Company	2019
280	Hong Kong	Dry	SCB10-1500/11/0.38	1	ATAL	2020
281	Uzbekistan	Oil	S11-1250KVA/6±2×2.5%/0. 4kV,DYn11	1	CNBM KIVAY International Engineering Co., Ltd	2020
282	Liberia	Oil	S11-1600/6.3/0.4KV	1	CNBM KIVAY International Engineering Co., Ltd	2020
283	Brunei	Service	6KV 500KVA&1000KVA Transformer Service	1	BUTRA HEIDELBERGCEMENT SDN BHD	2020
		Oil	S11-400KVA/6.6KV	2		
284	Philippines	Dry	SC10-150/0.44	1	CEMEX	2020
		Oil	S11-500KVA/6.3KV	1		
285	Brunei	Service	SZ11-5500/11 Transformer Refurbishment	1	BUTRA HEIDELBERGCEMENT SDN BHD	2020
286	Papua New Guinea	Parts	RMU Remote Control Upgrade Kits	4	OK TEDI MINING (APEQ)	2020
287	Philippines	Dry	SCB10-1500-PH	2	CH Asia World of Electric Inc	2020
288	Singapore	Dry	CSD-100,CSD-200	4	ABB PTE. LTD.	2020
289	Hong Kong	Dry	CS(WF)D-1500/0.69/0.44	4	Sunergy (Hong Kong) Trading Co.,Limited	2020
200	Tojjkiston	Oil	KS11-400,10kV/0.4kV,10±5 %,Dyn11	2	Closed Joint Stock	2020
290	Tajikistan	Oil	KS11-500,10kV/0.4kV,10±5 %,Dyn11	1	Company"TALCO GOLD"	2020



		Oil	KS11-250,10kV/0.4kV,10±5 %,Dyn11	1		
		Oil	KS11-160,10kV/1kV,10±5%, Dyn11	2		
		Oil	KS11-315,10kV/0.4kv,10±5 %,Dyn11	4		
		Oil	Lighting Transformer 5kVA 380V/220V	4		
		Dry	SG1-5/1.0F 5kVA 380/220V	4		
		Oil	S11-630KVA(10/0.4KV)	7		
		Oil	S11-160KVA(10/0.4KV)	3		
		Dry	SCB11-500,10kV/0.4kV,10± 2x2.5%,D.n11	1		
		Dry	SCB11-2000,10kV/0.4kV,10 ±2x2.5%,Dyn11	2		
		Dry	SCB11-1250,10kV/0.69kV,1 0±2x2.5%,Dyn11	1		
		Dry	SCB11-1250,10kV/0.4kV, 0±2x2.5%,Dyn11	1		
		Oil	S11M-125/10,10/0.4kV, 10±2x2.5%,Dyn11	1		
		Oil	S11M-315/10,10/0.4kV,10±2 x2.5%,Dyn11	1		
		Dry	SC11-315,10kV/0.4kV,10±2 x2.5%,Dyn11	1		
		Dry	SC11-400,10kV/0.4kV,10±2 x2.5%,Dyn11	1		
291	Philippines	Oil	S11-630KVA/6.6kV	1	CEMEX	2020
292	Philippines	Dry	SZGB10-550KVA/13.8KV (K=20)	1	CEMEX	2020
		Oil	SFZ11-40000/22	2		
		Oil	SF11-9000/10.5	2	SOMA CFSPP	
293	Indonesia	Dry	SCB13-800/10/0.4	1	2 x 31MW	2020
		Dry	SCB10-800/6.3/0.4	1	(RUHN POWER)	
		Dry	SCB10-1000/6.3/0.4	5		
294	Philippines	Oil	S11-2000KVA/6.6kV	1	CEMEX	2020



295	New Zealand	Switchgear	8DJH-PT+LL+LLL & LLL+LL+PT (12KV RMUs)	1	OCEANA GOLD	2020
296	Honduras	Oil	SFZ11-31500/138 31.5MVA 138±8X1.25%/6.6kV	1	EMCO 1*25MW (NOVA)	2020
		Dry	SCB11-1250/6.6	3		
297	New Zealand	Switchgear	8DJH-PT+LL+LLL (Grey Street RMU)	1	OCEANA GOLD(APEQ)	2020
200	Philippines	Oil	S11-1000KVA, 4160V	2	REPUBLIC CEMENT	2020
298		Oil	S11-2000KVA, 4160V	1	MINDANAO, INC	2020

		Zero Sequence Current Transformer 50/1 2.5VA	1			
		Phase Current Transformer 800/1 0.5/5P20 10/10VA	3		2020	
		Phase Current Transformer 200/1 0.5/5P20 10/10VA	3			
New Zealand	Critical Spares	Voltage Transformer 11kV/110V	1	OCEANA GOLD (APEQ)		
		Three Position Switch Motor Actuator for Remote Switching	1			
		Shunt Trip Coil	1			
		Undervoltage Release Coil	2			
Congo	Oil	S11-7000/10/3.3	1	CNMC International Trading Co.,Ltd	2020	
Namibia	Oil	SFZ11-16000/33KV	1	SWAKOP	2020	
	Dry	SCB11-2000/6.6KV	1	Uranium(Pty)Ltd		
Middle East	Oil	SFZ11-125000/230	3	JP	2020	
Laos	Dry	SCZB-1250/11/0.4	3	China Heavy Machinery	2020	
	Congo Namibia Middle East	New Zealand Spares Congo Oil Namibia Oil Dry Middle East Oil	New Zealand Critical Spares Critical Voltage Transformer 11kV/110V Three Position Switch Motor Actuator for Remote Switching Shunt Trip Coil Undervoltage Release Coil Congo Oil S11-7000/10/3.3 Namibia Oil SFZ11-16000/33KV SCB11-2000/6.6KV Middle East Oil SFZ11-125000/230	Transformer 1 50/1 2.5VA	New Zealand Phase Current Transformer 3 Phase Current Transformer 3 Phase Current Transformer 3 Phase Current Transformer 3 Phase Current Transformer 200/1 0.5/5P20 10/10VA 3 Voltage Transformer 11kV/110V 1 Three Position Switch Motor Actuator for 1 Remote Switching Shunt Trip Coil 1 Undervoltage Release Coil 2 Congo Oil S11-7000/10/3.3 1 CNMC International Trading Co.,Ltd Dry SCB11-2000/6.6KV 1 SWAKOP Uranium(Pty)Ltd Middle East Oil SFZ11-125000/230 3 JP JP JP JP JP JP JP JP JP	



		1	ı			
			SCZB-1250/22/0.4	1	Co., Ltd	
			SCB-400/22/0.4	1		
			SCZB-400/22/0.4	2		
234	UAE	Spares	Silicone Gel	1	Sinoma Energy Conservation Limited	2020
			SCB10-650/6.6/0.38	1	NEVICE (ND Floatric	
235	Japan	Dry	SC10-20/0.38/0.2	1	NEXTES (NR Electric Power Electronics	2020
			DC10-20/0.38/0.2-0.1	1	Co.,Ltd)	
236	Philippines	Spares	Transformer Spare Parts	20	Phil Gold Processing & Refining Corp	2020
237	Philippines	Oil	S11-500/0.525	1	REPUBLIC CEMENT MINDANAO, INC	2020
238	Vietnam	Oil	ZTS-1600/6	1	CAPITAL INVESTMENT COMMERCE AND SERVICES JOINT STOCK COMPANY	2021
239	Philippines	Oil	S11-2000	1	REPUBLIC CEMENT ILIGAN, INC	2021
			HV bushing	1		
			LV bushing	1		
240	UAE	Spares	OLTC	1	Sinoma Energy Conservation Limited	2021
			Gaskets for 2000KVA Txf	1	Conservation Limited	
			Gaskets for 2500KVA Txf	1		
		Oil	S11-50KVA-33KV	1		
241	Republic of	Dry	SCB10-250KVA-33KV	1	Selingue	2021
	Mali	Switchgear	Outdoor Vacuum Circuit Breaker ZW32-40.5/630A	1	(SAC)	
040	Co	Dry	SG(L)B-2000/6/0.69	1	CEMEY	2024
242	Germany	Dry	SG(L)B-1600/6/0.69*2	1	CEMEX	2021



243	Middle Africa	Dry	SCB11-2500kVA/15kV	2	CEEC (NR Electric Power Electronics Co.,Ltd)	2021
244	Middle East	Oil	SFZ11-20/22MVA-33KV	4	JP	2021
245	Uzbekistan	Dry Mine Type	KBSG ZY2-T-1000/6/1.2/0.693	2	ENERGOMAX LLX	2021
246	Philippines	Dry	SCB10-2000/34.5	2	CH Asia World of Electric Inc	2021
247	Republic of	Dmi	SCB11-250/15	1	Markala (SAC)	2021
241	Mali	Dry	SCB11-250/15	1	Bougouni(SAC)	2021
248	Papua New Guinea	Switchgear	Remote Control Panel	1	OK TEDI MINING (APEQ)	2021
249	Cameroon	on Oil	ZTS11-700	1	DANGOTE CEMENT CAMEROON S.A	2021
249			S11-2500	1		2021
		Dry	SCB10-1600/11/0.415	4	ZUNGERU Hydro (CNEEC)	2021
			SCB10-800/11/0.415	2		
250	Federal Republic of		SC10-250/11/0.415	2		
	Nigeria		SC10-315/11/0.415	4		
			SCB10-100/11/0.415	2		
			SCB11-2000/10.5/0.4	4		
054	Th 11	D	SCB11-1250/10.5/0.4	2	Bangkok Waste to	0004
251	Thailand	Dry	SCB11-1250/24/0.4	2	Energy Project (New Sky)	2021
			Reactor	2		
050	Th = 00	D	SCB11-2000/10.5/0.4	4	Bangkok Andrew Waste	2024
252	ı naıland	Thailand Dry	SCB11-1000/10.5/0.4	2	to Energy Project (New Sky)	2021



			SCB11-1250/24/0.4	1		
253	Canada	Dry	SGB10-1000/24.94-13.2/0.	2	Anderson Creek Sub X (Rio Tinto Alcan Inc)	2021
		Oil	S11-12000/22	2		
		Dry	CSD-700/11/0.4	2		
254	Singapore	Dry	CSD-700/0.435	2	ABB PTE. LTD.	2021
		Dry	CSD-700/11/0.525	2		
		Dry	SG-200/11/0.4	2		
		Kiosk	ZGS-1500/0.4/10	5		
255	Republic of Guinea	Kiosk	ZGS-1250/10/0.4	5	Kindia Tunnel (China Railway 18th Bureau Group Co.,Ltd)	2021
255		Kiosk	ZGS-160/10/0.4	13		
		Switchgear	XGW-12/CCC	13		
256	Tajikistan	Dry	ZSGB10-800/10	1	Parut gold mine (China Nonferrous Metal Mining (Group) Co., Ltd.)	2021
257	Myanmar	Dry	SCB10-1600/10	1	Mount Dagong (China Nonferrous Metal Mining (Group) Co., Ltd.)	2021
050	\	Oil	S11-1000/10	2	Hefei Rongju Iron	0004
258	Vietnam	Oil	S11-1600/10	2	(WISDRI-MCC)	2021
259	Vietnam	Dry	SCB10-800/11	1	VINASPARE COMPANY Limited	2021
		Oil	S11-M-1600/10	1	OCC4 Clinker Line	
260	Uzbekistan	Oil	S11-M-2000/10	1	QCC4 Clinker Line Project (Sino-Cemtech)	2021
		Oil	S11-M-2500/10	2		
261	Saudi Arab	Dry	SGB10-2000/13.8	1	AJCC	2021



					(Jiangsu Pengsheng Photovoltaic Technology Co., Ltd)	
262	Malayaia	C s	SCB10-100/11	1	Seagate (Nanjing) Power	0004
262	Malaysia	Dry	SCB10-300/33	1	Electronics Technology Co., Ltd	2021
		Oil	S11-250/11/0.415	1	Berth 1-3, Port Lamu, Kenya	
263	Kenya	Oil	SZ11-10000/33/11	1	COMPLANT (ZCTS Shenzhen Co.,Ltd)	2021
264	Zimbabwe	Ehouse	Ehouse	1	SINOMA	2021
265	Barbados	Oil	S11-1000/11	1	CEMEX	2021
266	Ethiopia	Oil	S11-200/15	1	Green River Banks (Jiangsu Nantong Sanjian Construction Group Co., Ltd.)	2021
267	Honduras	Dry	SCB11-1250/13.8	1	Caracol Knits S.A (NOVA)	2021
207		Dry	SCB11-2500/13.8	1		
268	Outer Mongolia	Dry	ZSCB10-660	1	NGK (NR Electric Power Electronics Co.,Ltd)	2021
269	Iraq	Spare	Spare Parts	1	Schneider Electric (China) Co.,Ltd.	2021
270	Pakistan	Dry	SCB10-1250	1	F2021E003-WHR PROJECT FOR LUCKY CEMENT LTD. PEZU PLANT LINE (Sinoma Energy Conservation Limited)	2021
271	Iraq	Spare	Spare Parts	1	Nanjing Zhongji Import and export Co. LTD	2021
272	Philippines	Dry	SCB-2500/13.8	1	CH Asia World of Electric	2021
273	Myanmar	Dry	ZSSCB10-630	1	Myanmar International Terminals Thilawa Limited	2021



07.4	5.1.1		ZSCB10-1100	2	Nanjing Shengze	2021
274	Poland	Dry	ZSCB10-2250	1	Technology Co., LTD	2021
275	Philippines	Dry	SCB10-1500/34.5	2	CH Asia World of Electric Inc	2021
276	Outer Mongolia	Dry	SCB11-500KVA	1	3MWh Lead carbon Energy Storage (Shuangdeng Group)	2021
277	Saudi Arab	Spare	Current Transformer	5	Sinoma Energy Conservation Limited	2021
278	Dominican Republic	Oil	SF11-40000/138	1	CEMEX	2021
279	Australia	Dry	SGB10-1333KVA/22KV Outdoor Type	1	MT Atlas MMU (APEQ)	2021
280	Bangladesh	Oil	S11-1250/6.3	1	HEIDELBERGCEMENT BANGLADESH LTD	2021
281	Ethiopian	Dry	SGB10-2000/15	2	Ethiopian Bank (Beijing New union International Engineering Technology Co., LTD)	2021
			SZ11-25000/132	2		
			S13-1000/6.3	3		
			S13-1600/6.3	5		
			S13-2000/6.3	1		
200	Dakiston	Oil	S13-M-1000/6.3	3	Hefei Cement	2024
282	Pakistan	Oil	S13-M-1000/6.3	1	Research&Design Institute Corporation Ltd	2021
			S13-M-1250/6.3	2		
			S13-M-1600/6.3	1		
			S13-M-2000/6.3	2		
			S13-M-2500/6.3	3		



		T T			
		S13-1000/6.3	1		
		S13-2000/6.3	1		
Philippines	Dry	SCB10-2000/34.5	1	CH Asia World of Electric Inc	2021
Philippines	Dry	SCB10-2000/13.8	1	CH Asia World of Electric Inc	2021
Philippines	Spares	Breather Capsules	5	Phil Gold Processing & Refining Corp	2021
Pakistan	Oil	S13-1000	1	Tianjin Cement Industry Research&Design Institute Corporation Ltd	2021
Togo	Oil	S11-M-2000	1	SCANTOGO	2021
		CSD-12	1		
Singapore	pore Dry	CSD-250	2	NC-256 CDL Cable Laying Vessel(ABB PTE. LTD)	2021
		CSD-50	1		
		CSD-700	2		
		CSD-1750	1		
		CSD-630	1		
		CSCBFD-4500	2	CDD CVDDIIS ESDII	
Cyprus	Dry	CSD-50	2	PROJECT	2021
		CSCBFD-25/6.6/0.46	2	(ABB (Hongkong) Limited)	
Philippines	Spares	OTI; Multi-Function Meter; WTI	4	Phil Gold Processing & Refining Corp	2021
Australia	Dry	SGB10-1333KVA/11KV Outdoor Type	1	MT Mindarie MMU (APEQ)	2022
Namibia	Dry	SCB11-2000/6.6	1	SWAKOP URANIUM (PTY) LTD	2022
Japan	Dry	SCB10-300	1	KitaKink 200kW (NR Electric Power	2022
	Philippines Philippines Pakistan Togo Singapore Cyprus Philippines Australia Namibia	Philippines Dry Philippines Spares Pakistan Oil Togo Oil Singapore Dry Cyprus Dry Philippines Spares Australia Dry Namibia Dry	Philippines Dry SCB10-2000/34.5 Philippines Dry SCB10-2000/13.8 Philippines Spares Breather Capsules Pakistan Oil S13-1000 Togo Oil S11-M-2000 CSD-12 CSD-12 CSD-250 CSD-50 CSD-700 CSD-700 CSD-1750 CSD-630 CSCBFD-4500 CSCBFD-4500 CSCBFD-25/6.6/0.46 OTI; Multi-Function Meter; WTI Australia Dry SGB10-1333KVA/11KV Outdoor Type Namibia Dry SCB11-2000/6.6	S13-2000/6.3 1	Philippines Dry SCB10-2000/34.5 1 CH Asia World of Electric Inc



					Electronics Co.,Ltd)	
00.4			SCB10-540	1	Anritsu	0000
294	Japan	Dry	SC-70	1	(NR Electric Power Electronics Co.,Ltd)	2022
		Oil	63/30KV 15MVA	1	COMILOG (Eramet)	
		Oil	2MVA 30/5.5KV	1		
295	Gabon	Oil	2MVA 30/0.4KV	9	COMILOG	2022
		Dry	200KVA 0.4KV	6	(Hatch)	
		Dry	50KVA 0.4KV	5		
296	Iraq	Oil	DKS- 2000/33/0.4	1	Mass Iraq Company For Cement Industry	2022
007	Guatemala	Oil	S11-1500 13.8KV	1	CEMEY	2022
297		Oil	S11-1500 13.8KV	1	CEMEX	
298	Philippines	Dry	SCB10-1500 13.8/0.4kV	1	CH Asia World of Electric Inc	2022
			CSD-400	2		
			CSD-160	2		
299	Canada	Dry	CSD-45	4	McRAE Marine Electrical & Electronics LTD.	2022
			CSD-45	1		
			CDGD-10	2		
			ZSG10-1250/6.3	2	LUDELAMEROON	
300	Pakistan	Dry	ZPSG-700/6	1	AUTOMATION SYSEM	2022
			ZPSG-550/6	1	ENGINEERING CO.,LTD	
301	Ethiopia	Oil	S11-630/15	1	HUAWEI DATA CENTER (Beijing Deere United	2022



					Engineering Technology Co., LTD)	
			SCB13-2750/11	2		2022
000		<u></u>	SCB13-2500/11	1	Solar Power	
302	Naura	Dry	SCB13-2000/11	2	Development Project (HNAC)	
			SCB13-630/11	2		
			ZSS-M-2000/11	1		
			ZSS-M-2700/11	1		2022
			S13-M-1000/11	1		
303	Nigeria	Oil	S13-M-1250/11	1	HEFEI ChunYan	
303	Nigona	Oii	S13-M-1600/11	2		
			S13-M-2000/11	3		
			ZTS-M-550/11	1		
			ZTS-M-700/11	2		
304	India	Oil	SFZ11-25000/132	2	LANJIGARH 130MW (RUHN POWER)	2022
		Dry	SGB10-750-11KV	2	Mindarie Mineral Sand	
305	Australia	Dry	SGB10-1500-11KV	3	Plant	2022
		SWG	Siemens 8DJH RMU 12KV+DC+RCP	4	(APEQ)	
		Dry	SGB10-1250 5.5KV	1		
206	Cohon	Dry	SG10-30	1	COMILOG	2022
306	Gabon	Dry	DG10-30	1	(Hatch)	2022
		SWG	NGR 300A 10S	1		



307	America	Oil	SSF11-2500 4.16/0.48/0.6kV	1	CEMEX	2022
200	E4l-ii-	Dry	SCB13-1250	2	MIE	2022
308	Ethiopia	Dry	SCB13-1000	2	YHF	2022
309	Trinidad and Tobago	Dry	SCB10-1500 3.3	1	CEMEX	2022
310	Australia	Dry	SGB10-600/22	1	MT Atlas Pump Skid (APEQ)	2022
311	Mexico	Dry	ZSCB-1500 6+/-2*2.5%/0.44kV	1	CEMEX	2022
312	Papua New	Spares	Buchholz Relay	1	APEQ	2022
312	Guinea	Spares	Pressure Relief Valve	1	AFEQ	2022
313	lanan	Dry	SCB10-750	1	Ando-Hazama 600kW (NR Electric Power Electronics Co.,Ltd)	2022
313	Japan	Dry	SCB10-110	1		
314	Malaysia	Oil	\$13-630 6.6+-2*2.5%/0.433kV	1	SINOMA Tianjin Control and Engineering Co.,Ltd	2022
			S11-1000/4.16/0.5	2		
			S11-1600/4.16/0.5	1		
245	Dominican	O:I	S11-2500/4.16/0.5	4	LIFEEL Observation	2022
315	Republic	Oil	ZSS-1000/4.16/2×0.72	1	HEFEI ChunYan	2022
			ZSS-1250/4.16/2×0.72	1		
			ZSS-510/4.16/2×0.72	1		
316	Philippines	Dry	SCB10-2000/34.5/0.23	1	ZHZQ ARCHITECT	2022
317	Philippines	Dry	SCB10-3000/34.5/0.38	1	ZHZQ ARCHITECT	2022
318	Philippines	Dry	SCB10-2000/13.8/0.46	1	CH Asia World of Electric Inc	2022



					T	
					(Tanzania Ceramics	
319	Tanzania	Oil	S11-4000/33/0.415	1	factory)	2022
					GUANGZHOU Sunda	
					(Senegal Ceramics	
320	Senegal	Oil	S11-2500/11/0.4	1	factory)	2022
					GUANGZHOU Sunda	
					(INFINITYSQUARE)	
321	Philippines	Oil	S11-2000	1	CH Asia World of Electric	2022
					Inc	
					COMPAGNIE MINIERE	
322	Gabon	Oil	S11-1250/5.5	2	DE L'OGOOUE	2022
	C 0.5 C 1.	.	011 1200/010	-	(COMILOG)	
				+	, ,	
		Dry	ZSC10-70	1	Omron Yachiyo 400KW (NR Electric Power	
323	Japan		700040 540	1		2022
		Dry	ZSCB10-540	1	Electronics Co.,Ltd)	
324	Mexico	Oil	S11-1000/4.16	1	CEMEX	2022
024	WICKIGO	Oli	011 1000/4.10	 '		2022
					(REPUBLIC CEMENT	
325	Philippines	Oil	ZTS-2500	1	BUILDING MATERIALS	2022
020	Fillippines		210-2000	'	' INC.)	2022
					CRH	
					China Energy Engineering	
326	Thailand	Dry	SCB11-200	2	Group Jiangsu Power	2022
					Design Institute Co.,Ltd	
					(SPCC2000kVA)	
327	Saudi Arab	Oil	S11-2000	1	Nanjing Zhongji	2022
					Import&Export Co.,Ltd	
			CCD40 20E	1	Fuji 285KW BESS	
328	lanan	Dny	SCB10-285	1	(NR Electric Power	2022
320	Japan	Dry	SCB10-60	1	Electronics Co.,Ltd)	2022
			00010-00		Electionics Co.,Ltd)	
	Bangladesh	h Oil	S11-1600	1		2022
329			2.1.1000	+	China National Heavy	
			SZ11-15000/33/11	1	Machinery Corporation	
330	America	Oil	S11-1400/4.16	2	CEMEX	2022
					Sinoma Energy	
331	Malaysia	Oil	S11-2000	2	Conservation Limited	2022
					Conservation Limited	



					SWAKOP		
332	Namibia	Dry	SCB11-3150	2	URANIUM(PTY) LTD	2022	
333	Philippines	Spare	Spare Parts	1	Phil Gold Processing & Refining Corp	2022	
334	Pakistan	Oil	SZ11-35000/132	1	LUCKY CEMENT LIMITED	2022	
335	Philippines	Oil	S11-1500	1	REPUBLIC CEMENT BUILDING MATERIALS INC.	2022	
000	Dominican Republic	Oil	SF-25000/34000/42000-138	4	Siba Energy Corporation	0000	
336			SF-39000/52000/65000-138	1		2022	
		Oil	S11-M-1000/22/0.4	1			
227	Laos		Oil	S11-M-3150/22/10	1	SINO IZCI	2022
337		Dry	SCB14-3150/10/0.4	1	SINO-KCL	2022	
		POS	YBW-12/0.4-2000	3			
338	Zambia	Oil	S11-4000/33/0.4	1	GUANGZHOU Sunda	2022	
339	America	Oil	S11-1000/4.16	1	CEMEX	2022	
340	Philippines	Oil	S11-1500	1	REPUBLIC CEMENT BUILDING MATERIALS INC.	2022	
341	Philippines	Oil	S11-8000	1	Phil Gold Processing & Refining Corp	2022	
342	Philippines	Spares	Spare Parts	1	Phil Gold Processing & Refining Corp	2022	
343	South Africa	Oil	ZTS-1300	1	Sephaku (Shanghai Ehkyu Internatrional Trading Co., Ltd.)	2022	
344	Poland	Dry	ZPSGL-500/6/4× 1.85Yd6-9%/Q/(16418)	4	ABB Sp. z o.o.	2022	
345	India	Dry	ZPSG-7296/11/0.73× 27Yd8-11%/G/(16420)	1	ABB india Limited	2022	



					,	
	Germany	Dry	CS(W/F)D-2100/0.69/0.45D			
			y11±5%6%/Q/(20160)	1		
240			CSCBFD-3200/0.71/0.46Dy		Wärtsilä Deutschland	2022
346			11±2.5%6%/T/(20227)	2	GmbH	
			CSCBFD-3200/0.71/0.46Dy			
			11±2.5%6%/T/(20227)	2		
0.47	1 12	_	ZPSGT-625/6.6/0.73×18	4	ADD in die Liesite d	0000
347	India	Dry	Yd8-10%/T/(16422)	1	ABB india Limited	2022
0.40		_	ZPSGL-938/6.6/0.73×18	_	ADD: 1: 1: '()	0000
348	India	Dry	Yd8-10%/Q/(16432)	2	ABB india Limited	2022
		Oil	115/10KV 25/31.5MVA	1		
349	Thailand	Oil	113/10RV 23/31.3WVA		HCE(Pinggao)	2023
043	THAIIAHU		115/10KV 40/50MVA	2	rioe(ringgao)	2023
		_			0550	
250	Republic of	Drv	00/0)44 045013/4/4513/		CEEC	0000
350	Chad		SC(B)11-3450kVA/15kV	3	(NR Electric Power	2023
					Electronics Co.,Ltd)	
351	Philippines	Dry	SC10-150KVA	1	CEMEX	2023
0.50		0''	0.44.0000440.040.44404		051457	
352	Philippines	Oil	S11-2000/13.8/0.44KV	1	CEMEX	2023
353	America	Oil	S11-1150KVA/4.16KV	1	CEMEX	2023
					ı-	
354	Honduras	Spares	138KV Bushings	1	IE (NO)(A)	2023
					(NOVA)	
355	Myanmar	Dry	SCB10-1600	1	SINOMA	2023
		_				
356	Malaysia	Spares	Bushing	1	SINOMA	2023
	India	India Dry	ZPSGL-563/6.6/0.73×18	0		
257			Yd8-10%/Q/(16435)	8	ADD in dia Limita d	2023
357			ZPSGT-938/6.6/0.73×18	3	ABB india Limited	
			Yd8-10%/T/(16466)			
	Hongkong	kong Dry	CSD-100/0.415/0.415Dyn1	2	ABB (Hong Kong) Limited	
250			1±2×2.5%3.5%/Q/(20144)			2022
358			CSD-35/0.415/0.415Dyn11	2		2023
			±2×2.5%3.5%/Q/(20143)			
250	Switzerland	itzerland Dry	CS(W/F)D-1650/0.66/0.45	2	Winterthur Gas & Diesel	2023
359			Dy11/6%/Q/(20256)			



360	Finland	Dry	CSCBFD-2400/0.71/0.467 Dy11±2.5%6%/Q/(20259)	11	Wärtsilä Deutschland GmbH	2023
361	Saudi Arab	Dry	SCB10-2000/11/0.38	1	Shenglong Electric	2023
362	Venezuela	Dry	SCB11-2000/13.8/0.4	7	Shenzhen Renfuyingrui Import&Export Co., Itd	2023
	Nigeria	Oil	S13-M-1600/11/0.4	1	HEFEI ChunYan	
363			S11-800/10 10±2*2.5%/0.48KV	1		2023
			S13-M-2000/11/0.4	1		
364	Malaysia	Dry	SCB10-300/11/0.433	1	Xijie(Nanjing) Power electronics technology	2023
365	Pakistan	Dry	SCB10-1250/6.3/0.4		Hefei Cement Research&Design Institute Corporation Ltd	2023



QUALITY MANAGEMENT SYSTEM CERTIFICATE

Certificate No. 00120Q311194R0M/1100

We hereby certify that

China Electric Equipment (Jiangsu) Transformer Manufacture Co., Ltd. (This main certificate contains 1 attachment and 5 sub-certificates)

Unified Social Credit Code: 9132118233888785XM

No.188 Ganglong Road, Yangzhong Economic Development Zone, Zhenjiang City, Jiangsu Province, China (Subsidiary's information refers to the attachment and sub-certificate)

by reason of its

Quality Management System

has been awarded this certificate for compliance with the standard

GB/T 19001-2016 / ISO 9001:2015

The Quality Management System Applies in the following area:

1,The Design, Manufacturing, Sales and After Service of 35kV Grade and Below Voltage Dry Type Transformer, Rectifier Frequency Transformer and Marine Transformer, Rectifier Transformer and Transformer Supporting Accessories

2,The Design, Manufacturing, Sales and After Service of 220kV Grade and Below Voltage Oil-immersed Power Transformer, Railway Traction Transformer, Auto-transformer, Amorphous Alloy Oil-immersed Transformer and Transformer Supporting Accessories; The Design, Manufacturing, Sales and After Service of 35kV Grade and Below Voltage Wind Power Generation Modular Transformers, PV Power Transformer and Transformer Supporting Accessories; The Design, Manufacturing, Sales and After Service of 35kV Grade and Below Substation, Complete Switch Equipment 3, The Design, Manufacturing, Sales and After Service of 35kV Grade and Below Voltage Amorphous Alloy Oil-immersed Power Transformer, Amorphous Alloy Core (Subsidiary's information refers to the attachment and sub-certificate)

Certified since: December 29, 2020 Valid from: January 6, 2022 Valid until: December 28, 2023

After a surveillance cycle, the certificate is valid only when used together with an Acceptance Notice of Surveillance Audit issued by CQC.

Please access www.cqc.com.cn for checking validity of the certificate.

This certificate and its relevant information can query in the website of Certification and Accreditation Administration of the People's Republic of China (www.cnca.gov.cn).











CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan(the South Fourth Ring Road) Xilu(West Road), Beijing 100070, China http://www.cqc.com.cn

A 0039175

2021年版

Business License

No.: 320121000202004200426

Uniform Social Credit Code 913201150802804862

Name: CEEG Nangjing Transmission & Distribution Equipment Co., Ltd.

Character of Economy: Company with limited liability

Address: No. 6 Shuige Road, Jiangning, Nanjing

Legal representative: Wang Chengbing

Registered Capital: RMB 30,000,000 Yuan

Date of Foundation: November 31, 2013

Term of Business: From November 31, 2013 to ****

Business scope: Research & development, manufacturing, sale, design and related technical service of power transmission and distribution equipment, self-operate and agent import and export business of various kinds of commodities and technologies. (with exception of state limited and banned import and export goods or technologies) (Any project that needs to be approved by law can only be carried out after getting approval by relevant authorities.)

Registration Authority:

Market Supervision Administration of Jiangning, Nanjing

April 4, 2020



号 320121000202004200426

统一社会信用代码

913201150802804862

(1/1)

(副 本)



中电电气输配电设备南京有限公司

类

有限责任公司(自然人投资或控股)

法定代表人 王成兵

经营范围

输配电设备的研发、生产、销售、设计及其他相关技术服务; 自营和代理各类商品及技术的进出口服务(国家限定公司经营 或禁止进出口的商品和技术除外)。(依法须经批准的项目, 经相关部门批准后方可开展经营活动)

注册资本 3000万元整

成立日期 2013年10月31日

2013年10月31日至*****

住 南京市江宁经济技术开发区水阁路6号

登记机关



2020



ENVIRONMENTAL MANAGEMENT SYSTEM CERTIFICATE

Certificate No. 00120E34741R0M/1100

We hereby certify that

China Electric Equipment (Jiangsu) Transformer Manufacture Co., Ltd.

(This main certificate contains 1 attachment and 5 sub-certificates)

No.188 Ganglong Road, Yangzhong Economic Development Zone, Zhenjiang City, Jiangsu Province, China (Subsidiary's information refers to the attachment and sub-certificate)

by reason of its

Environmental Management System

has been awarded this certificate for compliance with the standard

GB/T 24001-2016 / ISO 14001:2015

The Environmental Management System Applies in the following area:

Transformer, Auto-transformer, Amorphous Alloy Oil-immersed Transformer and Transformer and Transformer and Transformer and Transformer and Transformer Supporting Accessories and Related Management Activities

2, The Design, Manufacturing, Sales and After Service of 220kV Grade and Below Voltage Oil-immersed Power Transformer, Railway Traction

Transformer, Auto-transformer, Amorphous Alloy Oil-immersed Transformer and Transformer Supporting Accessories; The Design, Manufacturing,

Sales and After Service of 35kV Grade and Below Voltage Wind Power Generation Modular Transformers, PV Power Transformer and Transformer Supporting Accessories; The Design, Manufacturing, Sales and After Service of 35kV Grade and Below Substation, Complete Switch Equipment and Related Management Activities

3,The Design, Manufacturing, Sales and After Service of 35kV Grade and Below Voltage Amorphous Alloy Oil-immersed Power Transformer, Amorphous Alloy Core and Related Management Activities

(Subsidiary's information refers to the attachment and sub-certificate)

Certified since: December 28, 2020 Valid from: January 5, 2022 Valid until: December 27, 2023

After a surveillance cycle, the certificate is valid only when used together with an Acceptance Notice of Surveillance Audit issued by CQC.

Please access www.cqc.com.cn for checking validity of the certificate.

This certificate and its relevant information can query in the website of Certification and Accreditation Administration of the People's Republic of China (www.cnca.gov.cn).











CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan(the South Fourth Ring Road) Xilu(West Road), Beijing 100070, China http://www.cqc.com.cn

A 0039070

2021年版



OCCUPATIONAL HEALTH AND SAFETY MANAGEMENT SYSTEM CERTIFICATE

Certificate No. 00120S33609R0M/1100

We hereby certify that

China Electric Equipment (Jiangsu) Transformer Manufacture Co., Ltd. (This main certificate contains 1 attachment and 5 sub-certificates)

No.188 Ganglong Road, Yangzhong Economic Development Zone, Zhenjiang City, Jiangsu Province, China (Subsidiary's information refers to the attachment and sub-certificate)

has been awarded this certificate for compliance with the standard

GB/T 45001-2020 / ISO45001:2018

The Occupational Health and Safety Management applies in the following area:

1,The Design, Manufacturing, Sales and After Service of 35kV Grade and Below Voltage Dry Type Transformer, Rectifier Frequency Transformer and

Marine Transformer, Rectifier Transformer and Transformer Supporting Accessories and Related Management Activities

2,The Design, Manufacturing, Sales and After Service of 220kV Grade and Below Voltage Oil-immersed Power Transformer, Railway Traction
Transformer, Auto-transformer, Amorphous Alloy Oil-immersed Transformer and Transformer Supporting Accessories; The Design, Manufacturing,
Sales and After Service of 35kV Grade and Below Voltage Wind Power Generation Modular Transformers, PV Power Transformer and Transformer
Supporting Accessories; The Design, Manufacturing, Sales and After Service of 35kV Grade and Below Substation, Complete Switch Equipment and
Related Management Activities

3,The Design, Manufacturing, Sales and After Service of 35kV Grade and Below Voltage Amorphous Alloy Oil-immersed Power Transformer, Amorphous Alloy Core and Related Management Activities

(Subsidiary's information refers to the attachment and sub-certificate)

Certified since: December 28, 2020 Valid from: January 6, 2022 Valid until: December 27, 2023

After a surveillance cycle, the certificate is valid only when used together with an Acceptance Notice of Surveillance Audit issued by CQC.

Please access www.cqc.com.cn for checking validity of the certificate.

This certificate and its relevant information can query in the website of Certification and Accreditation Administration of the People's Republic of China (www.cnca.gov.cn).











CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan(the South Fourth Ring Road) Xilu(West Road), Beijing 100070, China http://www.cqc.com.cn

A 0039413

2021年版



Vendor Information

1) Company Information Required:

Name: CEEG Nanjing Transmission & Distribution Equipment Co.,Ltd

Registration NO: 913201150802804862(1/1)

2) Payment Details required:

2.1

- ※ Bank Name: Bank of China, Jiangsu Branch
- Bank Address: 148 Zhongshan Nanlu, Nanjing, China
- Account Name: CEEG Nanjing Transmission & Distribution Equipment Co., Ltd.
- Swift Code: BKCHCNBJ940
- ※ Bank Account Number: 480664572368
- ※ Currency: USD
- 3) Accounts Receivable contact Name: Hang Xu (Lisa)
- 4) Phone No. for Remittance: 86-25-84207888
- 5) Email and/or Fax No. for Accounts Receivable: xh@ceeg.cn
- 6) Company information provided by: Jin Qian (Hardy)

中电电气输配电设备南京有限公司 CEEG Nanjing Transmission&Distribution Equipment Co., Ltd.



CERTIFICATE

ATTESTATION CERTIFICATE OF ELECTROMAGNETIC COMPATIBILITY AND LOW VOLTAGE DIRECTIV

Technical file of the company mentioned below has been observed and audit has been completed successfully.

2014/30/EU Electromagnetic Compatibility Directive and

2014/35/EU Low Voltage Directives have been taken as references for these processes

Company Name : China Electric Equipment (Jiangsu) Transformer Manufacture

Co., Ltd.

Company Address : No. 188 Ganglong Road, Yangzhong, Zhenjiang, Jiangsu,

Related Directives and Annex : 2014/35/EU Low Voltage Directive

2014/30/EU Electromagnetic Compatibility Directive

Related Standards : EN 60076-1:2011. IEC 60076-1:2011

Product Name : Oil Immersed Transformer

Report No and Date : TCF-ZD220413LE

Product Brand/Model/Type : S,S-M,SL,SL-M,S(F)Z,S(F)Z-M,S(F)SZ,S(FP)SZ-M,OS(PF)SZ,

OS(PF)SZ-M,QYS,ZTSF,ZHSF,YS,ZPSF(Capacity 240000kva and below,

voltage grade 220kV and below)

Certificate Number : M.2022.206.C72761

Initial Assessment Date : 13.04.2022

Registration Date : 14.04.2022 Reissue Date/No **Auditing Training Centre Industry**

Expiry Date : 13.04.2027 and Trade Inc. Co.

The validity of the certificate can be checked through www.udem.com.tr. The CE mark shown on the right can only be used under the responsibility of the manufacturer with the completion of EC Declaration of Conformity for all the relevant Directives. This certificate remains the property of UDEM International Certification Auditing Training Centre Industry and Trade Inc. Co. to whom it must be returned upon request. The above named firm must keep a copy of this certificate for 15 years from the registration of certificate. This certificate only covers the product(s) stated above and UDEM must be noticed in case of any changes on the product(s)

Address: Mutlukent Mahallesi 2073 Sokak (Eski 93 Sokak) No:10 Çankaya - Ankara - TURKEY

Phone: +90 0312 443 03 90 Fax: +90 0312 443 03 76 E-mail: info@udemltd.com.tr www.udem.com.tr





Certification





China National Accreditation Service for Conformity Assessment LABORATORY ACCREDITATION CERTIFICATE

(Registration No. CNAS L18260)

Testing Center of China Electric Equipment (Jiangsu) Transformer Manufacture Co., Ltd.

(Legal Entity: China Electric Equipment (Jiangsu) Transformer Manufacture Co., Ltd.)

Building 8, No.188, Ganglong Road, Economic Development Zone,

Yangzhong, Zhenjiang, Jiangsu, China

is accredited in accordance with ISO/IEC 17025: 2017 General Requirements for the Competence of Testing and Calibration Laboratories(CNAS-CL01 Accreditation Criteria for the Competence of Testing and Calibration Laboratories) for the competence to undertake the service described in the schedule attached to this certificate.

The scope of accreditation is detailed in the attached schedule bearing the same registration number as above. The schedule forms an integral part of this certificate.

Effective Date: 2023-05-16

Expiry Date: 2029-05-15

Signed on behalf of China National Accreditation Service for Conformity Assessment

传纳华

China National Accreditation Service for Conformity Assessment (CNAS) is authorized by Certification and Accreditation Administration of the People's Republic of China (CNCA) to operate the national accreditation schemes for conformity assessment. CNAS is a signatory of the International Laboratory Accreditation Cooperation Mutual Recognition Arrangement (ILAC MRA) and the Asia Pacific Accreditation Cooperation Mutual Recognition Arrangement (APAC MRA).

The validity of the certificate can be checked on CNAS website at http://www.cnas.org.cn/english/findanaccreditedbody/index.shtml.





China National Accreditation Service for Conformity Assessment LABORATORY ACCREDITATION CERTIFICATE

(Registration No. CNAS L18260)

Testing Center of China Electric Equipment (Jiangsu) Transformer Manufacture Co., Ltd.

(Legal Entity: China Electric Equipment (Jiangsu) Transformer Manufacture Co., Ltd.)

Building 8, No.188, Ganglong Road, Economic Development Zone,

Yangzhong, Zhenjiang, Jiangsu, China

is accredited in accordance with ISO/IEC 17025: 2017 General Requirements for the Competence of Testing and Calibration Laboratories(CNAS-CL01 Accreditation Criteria for the Competence of Testing and Calibration Laboratories) for the competence to undertake the service described in the schedule attached to this certificate.

The scope of accreditation is detailed in the attached schedule bearing the same registration number as above. The schedule forms an integral part of this certificate.

Effective Date: 2023-05-16

Expiry Date: 2029-05-15

Signed on behalf of China National Accreditation Service for Conformity Assessment

传纳华

China National Accreditation Service for Conformity Assessment (CNAS) is authorized by Certification and Accreditation Administration of the People's Republic of China (CNCA) to operate the national accreditation schemes for conformity assessment. CNAS is a signatory of the International Laboratory Accreditation Cooperation Mutual Recognition Arrangement (ILAC MRA) and the Asia Pacific Accreditation Cooperation Mutual Recognition Arrangement (APAC MRA).

The validity of the certificate can be checked on CNAS website at http://www.cnas.org.cn/english/findanaccreditedbody/index.shtml.













实验室名称: 国家电器产品质量监督检验中心

Lab Name: China National Center for Quality Supervision

and Test of Electrical Apparatus Products

№ 20M0561-S

型式试验报告 Type Test Report

委托单位: China Electric Equipment (Jiangsu) Transformer Manufacturing Co., Ltd

Client:

产品名称: Power transformer

Name of Product:

产品型号: SZ11-63000/110

Product Type:

检验类别: Commission test

Test Category:

本实验室对出具的检验(试验)结果负责, 未经实验室书面同意, 不得部分地复制本报告.

The laboratory is responsible for the inspection (Test) results. The report shall not be reproduced except in full, written approval of the laboratory.



China National Center for Quality Supervision and Test of Electrical Apparatus Products Test Report

№: 20M0561-S

Total 68 Page 01

Client	China Electric Equipment (Jiangsu) Transformer Manufacturing Co., Ltd	Test category	Commission test
Manufacturer	China Electric Equipment (Jiangsu) Transformer Manufacturing Co., Ltd	Date of sample receiving	Mar. 21, 2020
Name of sample	Power transformer	Type of sample	SZ11-63000/110
Address of manufacturer	No.188 Zhongdian Road, Yangzhong, Zhenjiang City, Jiangsu Prov ince, China	Original number or date of production	ZD202003856
Date of test	From Apr. 09, 2020 to Apr. 22, 2020	Number of sample	1 set
Test items	Type test (including calculation of the winding hot-spot temperature-rise) Measurement of bushing capacitances and dielectric dissipation factor (tanδ) Measurement of zero-sequence impedances on three-phase transformers Measurement of the harmonics of the no-load current Measurement of frequency response Measurement of no-load excitation characteristics Long-duration no-load test Measurement of short-circuit impedance on LV Short-circuit withstand test	Test standards	GB/T 1094.1—2013 GB/T 1094.2—2013 GB/T 1094.3—2017 GB/T 1094.5—2008 GB/T 1094.10—2003 GB/T 6451—2015 GB/T 7595—2017 JB/T 10088—2016 IEC 60076-1:2011 IEC 60076-2:2011 IEC 60076-3:2013+AMD1:2013 IEC 60076-10:2016 Commission requirements
Test conclusion	The test results of routine test, hot-spot temperature-rise), measured dissipation factor (tanδ), measurement transformers, measurement of the hof frequency response, measured long-duration no-load test, measure short-circuit withstand test of powaccordance with test standards and passed the above tests.	ement of bus ent of zero-sequarmonics of to ment of no- ement of sho er transformed d commission	puence impedances on three-phase the no-load current, measurement load excitation characteristics ort-circuit impedance on LV and or (type: SZI1-63000/110) are in
	Note: the conclusion is valid only for the		10000000000000000000000000000000000000

Compiled by: 表小男Proofread by: 分子Checked by: 分為,Approved by: Approved by:

China National Center for Quality Supervision and Test of Electrical Apparatus Products

№: 20M0561-S Total 68 Page 02

1. Sample parameters

Rated power: 63000kVA Rated voltage: 110/10.5kV Rated current: 330.7/3464.2A Rated frequency: 50Hz

Tapping ranges: (110±8×1.25%)/10.5kV

Connection symbol: YNd11 Cooling method: ONAN

Number of phases: 3

Class of insulation and heat-resistant: /

Insulation level: HV Um/LI/LIC/AC 126/480/530/200kV HVN Um/LI/AC 72.5/325/140kV

HVN Um/LI/AC 72.5/325/140kV LV Um/LI/LIC/AC 12/75/85/35kV

2. Test standards

GB/T 1094.1-2013 Power transformers-Part 1: General

GB/T 1094.2—2013 Power transformers—Part 2: Temperature rise for liquid-immersed transformers

GB/T 1094.3—2017 Power transformers—Part 3: Insulation levels, dielectric tests and external clearances in air

GB/T 1094.5—2008 Power transformers—Part 5: Ability to withstand short circuit

GB/T 1094.10-2003 Power transformers-Part 10: Determination of sound levels

GB/T 6451—2015 Technical parameters and requirements of oil-immersed power transformer

GB/T 7595-2017 Quality of transformer oils in service

JB/T 10088—2016 Sound level for 6kV~1000kV power transformers

IEC 60076-1:2011 Power transformers - Part 1: General

IEC 60076-2:2011 Power transformers - Part 2: Temperature rise for liquid - immersed transformers

IEC 60076-3:2013+AMD1:2018 Power transformers - Part 3: Insulation levels, dielectric tests and

external clearances in air

IEC 60076-5:2006 Power transformers - Part 5: Ability to withstand short circuit

IEC 60076-10:2016 Power transformers - Part 10: Determination of sound levels

Commission requirements

3. Sample description

The power transformer is for outdoor use, and the structure of the coil is rotundate concentric type coil. The type used in this report meets the requirements of JB/T 3837—2016 *Identification method of transformer's product type* and external photos of the sample have been attached.

SJJJ-YB002 (11)

Test Report

China National Center for Quality Supervision and Test of Electrical Apparatus Products

№: 20M0561-S Total 68 Page 03

Photos of the sample







SJJJ-YB003 (11)

China National Center for Quality Supervision and №: 20M0561-S Report Test Test of Electrical Apparatus Products Total 68 Page 04 Summary of test results Specified value Measured value Concl-No Test items Standards Before After usion (commission requirements) short-circuit test short-circuit test Measurement of d.c. Providing value of insulation insulation resistance resistance windings-to-earth and 1 See 4.1 See 4.19.4.1 1 Providing absorption ratio between windings Providing polarity index (routine test) Check of core and frame insulation for Providing value of insulation liquid-immersed 2 resistance See 4.2 See 4.19.4.2 PASS transformers with core or 20°C(MΩ): ≥500 frame insulation (routine test) Measurement of dissipation factor (tanδ) Providing value of capacitance 3 of the insulation system Providing dielectric dissipation See 4.3 See 4.19.4.3 1 capacitances factor tano (routine test) Determination of capacitances 4 windings-to-earth and Providing value of capacitance See 4.4 See 4.19.4.4 1 between windings (routine test) Measurement of bushing capacitances and Providing value of capacitance 5 dielectric dissipation Providing dielectric dissipation See 4.5 See 4.19.4.5 factor (tanδ) factor tano (commission test) Check the ratio and polarity of built-in Providing the value of ratio and 6 See 4.6 See 4.19.4.6 1 current transformers polarity relation (routine test) Wring for auxiliary power and Insulation test of control circuit: 2.0kV 2.0kV 60s 2.0kV 60s 7 auxiliary wiring Wring for secondary winding PASS (routine test) of current transformer: 2.5kV 2.5kV 60s 60s 2.5kV 60s Voltage ratio tolerance of principal tapping: obtaining the Measurement of voltage lower of the following values ratio and check of phase 8 between ±0.5% of declared See 4.8 See 4.19.4.8 PASS displacement ratio and ±1/10 of the actual (routine test) percentage impedance Connection symbol: YNd11 Maximum resistance unbalance Measurement of winding rate 9 resistance PASS Phase resistance: ≤2% HV (phase):0.33% HV (phase): 0.31% (routine test) Line resistance: ≤1% LV (line):0.36% LV (line):0.39%

5	Test Report		National Center for Q Test of Electrical App				ıd	№: 2 Total 6	0M0561 8 Page	
			Specified value			Measu	red value	;		Conc
N <u>o</u>	Test items	(com	Standards mission requirements)	sho	Before rt-circui		sho	After rt-circui	t test	usior
		100% Ur	I ₀ (%): 0.2 +0% P ₀ (kW): 44.800 +0%	0.15 43.691			0.15 43.695	5		PASS
10	Measurement of no-load loss and current (routine test)	90% Ur	I ₀ (%): measured P ₀ (kW): measured	0.12 35.394			0.12 35.390)		,
current (routine test)		110% Ur	I ₀ (%): measured P ₀ (kW): measured	0.50 69,367	,		0.50 69.343			1
11	Measurement of short-circuit impedance and load loss (routine test)	1000	17.0 ±5% 0: 232.000 +0% W): 276.800 +0%	16.92 215.380 259.071		16.94 215.330 259.025			PASS	
12	Tests on on-load tap-changers (routine test)	GB/T1	ling to clause 11.7 of 094.1-2013 and 076-1:2011	Meet the requirements		Meet the requirements			PASS	
13	Lightning impulse test		ed wave (kV): 480 ±3% ed wave (kV):530±3% point (kV):325 ±3%		1		478.02~ 530.72~ 324.47~	-533.28		PASS
	(routine test, type test)		ve (kV): 75 ±3% ed wave (kV):85 ±3%		ſ	A	74.96~7 84.36~8			
14	Separate-source AC withstand voltage test (routine test)		HV neutral point:140kV 60s LV: 35kV 60s		V	60s 60s	140.0k 35.0kV		60s 60s	PASS
		Phase to	o earth test							
	Line terminal AC withstand test	Applied	l voltage (kV):	ac: 21.0	ab: 21.0	bc: 21.0	ac: 21.0	ab: 21.0	bc: 21.0	
15	(routine test)	Induced	l voltage (kV): 200	A: 200.0	B: 200.0	C: 200.0	A: 200.0	B: 200.0	C: 200.0	PASS
			n (s): 120(f _n /f) ncy (Hz): >50	30 200			30 200			

China National Center for Quality Supervision and

	L	Specified value	Measu	red value	Concl
N <u>o</u>	Test items	Standards (commission requirements)	Before short-circuit test	After short-circuit test	usion
		Three-phase applied voltage			
		$0.4 \text{Ur} / \sqrt{3} \text{ (kV)}$	25.4	25.4	
		Discharge magnitude≤50pC	A:<14;B:<15;C:<17	A:<16;B:<17;C:<18	
		$1.2 \text{Ur} / \sqrt{3} \text{ (kV)}$	76.2	76.2	1
		Duration (min): 1	1	1	
		Discharge magnitude≤100pC	A:<45;B:<50;C:<50	A:<47;B:<40;C:<45	
	Induced AC	1.58Ur/√3 (kV)	100.3	100.3	1
	withstand voltage	Duration (min): 5	5	5	
	test and induced AC	Discharge magnitude≤250pC	A:<87;B:<92;C:<85	3000	
16	withstand voltage	$2.0 \text{Ur} / \sqrt{3} \text{ (kV)}$	127.1	127.1	-
16	test with partial	Duration (min): 0.5	0.5	0.5	PASS
	discharge	1.58Ur/√3 (kV)	100.3	100.3	
	measurement (routine test)	Duration (min): 60	60	60	
		Discharge magnitude≤250pC	A:<90;B:<97;C:<92	A:<85;B:<87;C:<88	
		$1.2\mathrm{Ur}/\sqrt{3}$ (kV)	76.2	76.2	1
		Duration (min): 1	1	1	
		Discharge magnitude≤100pC	A:<44;B:<48;C:<50	A:<45;B:<42;C:<42	
		$0.4 \text{Ur} / \sqrt{3} \text{ (kV)}$	25.4	25.4	7
		Discharge magnitude≤50pC	A:<15;B:<17;C:<16	A:<15;B:<15;C:<17	
		Frequency (Hz): >50	200		
	Insulating liquid test,	Breakdown voltage (kV): ≥45	61.0	58.1	
	measurement of	tanδ(90°C): ≤1.0%	0.23%	0.36%	
	dissolved gasses in	Water content (mg/L): ≤20	8.9	9.8	
17	dielectric liquid from each separate oil	Providing gas chromatograph			PASS
	compartment except	analysis: Hydrogen: <30µL/L		San Harvis	
	diverter switch	Acetylene: 0	See 4.17	See 4.19.4.17	
	compartment	Total hydrocarbon: <20µL/L			
	(routine test)	Total Hydrocaroon: 420µ272			
	Measurement of	20.10.22			
18	frequency response	Providing frequency response	See 4.18	See 4.19.4.18	PASS
	(special test)	characteristics curve		Total Salvana	

SJJJ-YB004 (11)

		Specified value	44	Concl-	
No	Test items	Standards (commission requirements)	Measured value	usion	
19	Short-circuit withstand test (special test)	Test times of each phase: 3 times Duration (s): 0.25±10% The test oscillogram shall be normal. The reactance tolerance of phase before and after the test is not more than 2% The out-of-tank inspection does not reveal any obvious defects. Routine retests shall be passed after short-circuit test.	3 times 0.257~0.257 Without abnormity The maximum reactance tolerance of phase is 0.67% Without obvious abnormity Routine retests are passed.	PASS	
20	Measurement of no-load excitation characteristics (commission test)	Providing no-load excitation characteristic curve	See 4.20	1	
21	Long-duration no-load test (commission test)	Applied voltage (kV): 1.1Ur Duration (h): 12 Oil without acetylene	1.1Ur 12 For gas chromatograph analysis, see 4.19.4.17	PASS	
22	Measurement of short-circuit impedance on LV (commission test)	Measurement of short-circuit impedance at 380V voltage	See 4.22	1	
23	Measurement of zero-sequence impedances on three-phase transformers (special test)	Providing zero-sequence impedances values (Ω)	See 4.23	j	
24	Measurement of the harmonics of the no-load current (commission test)	Providing harmonics of the no-load current of each phase	Harmonics of the no-load current of I ₁ -I ₁₉	1	
25	Temperature-rise test (including calculation of the winding hot-spot temperature-rise) (type test)	Top oil temperature-rise limits (K): 53 Winding temperature-rise limits (K): 60 Winding hot-spot temperature-rise limits (K): 78 Hot-spot temperature-rise limits of tank and metal structural parts (K): 75	Top oil temperature-rise:48.8 HV winding temperature-rise: 54.9 LV winding temperature-rise: 55.9 HV winding hot-spot temperature-rise: 69.8 LV winding hot-spot temperature-rise: 71.0 39.3	PASS	

Test Report China National Center for Quality Supervision and Test of Electrical Apparatus Products Total 68 Page 08

		Specified value		Concl-	
N <u>o</u>	Test items	Standards (commission requirements)	Measured value	usion	
26	Leak testing with pressure for liquid-immersed	Body: Applied pressure (kPa): 30 Duration (h): 24 No oil leakage or damage	30.0 24 No oil leakage or damage	PASS	
	transformers (routine test)	On-load tap-changer tank: Applied pressure (kPa): 30 Duration (h): 24 No oil leakage or damage	30.0 24 No oil leakage or damage	TASS	
27	Determination of sound levels (type test)	Sound pressure level $\overline{L_{pA}}$ dB (A): Sound power level L_{WA} dB(A): \leq 80	54 74	PASS	
28	Mechanical strength test of tank (type test)	Applied degree of vacuum (kPa): 0.133 Applied positive pressure (kPa): 100 Elastic deformation of tank wall (strengthen) (mm): \(\leq 32\) Elastic deformation of tank wall (mm): \(\leq 40\) Elastic deformation of tank cover (mm): \(\leq 18\) Permanent deformation of tank wall (strengthen) (mm): \(\leq 16\) Permanent deformation of tank wall (mm): \(\leq 20\) Permanent deformation of tank cover (mm): \(\leq 10\) No damage	See 4.28	PASS	

Blank below

Test Report China National Center for Quality Supervision and
Test of Electrical Apparatus Products Total 68 Page 09

China National Center for Quality Supervision and
Test of Electrical Apparatus Products Total 68 Page 09

4. Test items and results

4.1 Measurement of d.c. insulation resistance windings-to-earth and between windings (routine test)

Test date: Apr. 09, 2020
Relative humidity: 46%: Oil temperature: 18.9°C

		Г	ciative nui	maity: 46%; On ter	ilperature. 18.9
Measured parts	R ₁₅ (GΩ)	R_{so} $(G\Omega)$	R_{600} $(G\Omega)$	Absorption ratio (R ₆₀ /R ₁₅)	Polarity index (R ₆₀₀ /R ₆₀)
HV-LV and earth	30.6	40.1	55.9	1.31	1.39
LV—HV and earth	25.3	35.9	53.8	1.42	1.50
HV, LV—earth	15.8	21.6	30.6	1.37	1.42
HV—LV	39.6	51.8	78.8	1.31	1.52

4.2 Check of core and frame insulation for liquid-immersed transformers with core or frame insulation (routine test)
Test date: Apr. 09, 2020

Relative humidity: 46%; Oil temperature: 18.9°C

Measured parts	Measured insulation resistance (GΩ)	Insulation resistance corrected to $20^{\circ}C(G\Omega)$
Core—earth	12.5	12.0
Frame—earth	14.3	13.7
Core—frame	11.3	10.8

4.3 Measurement of dissipation factor (tanδ) of the insulation system capacitances (routine test)

Test date: Apr. 09, 2020

Relative humidity: 46%; Oil temperature: 18.9°C

Measured parts	Dielectric dissipation factor tanδ(%)	Capacitance (pF)
HV-LV and earth	0.35	11000
LV—HV and earth	0.33	17750
HV, LV-earth	0.38	19330
HV—LV	0.34	14520

4.4 Determination of capacitances windings-to-earth and between windings (routine test) Test date: Apr. 09, 2020 See 4.3

4.5 Measurement of bushing capacitances and dielectric dissipation factor (tanδ)(commission test)

Test date: Apr. 09, 2020

Relative humidity: 46%; Oil temperature: 18.9°C

Measured contents	Applied	Measured parts				
	voltage	A	В	С	0	
tanδ(%)	10kV	0.36	0.35	0.33	0.34	
Measured capacitance (pF)		298.5	298.5	297.6	349.3	

4.6 Check the ratio and polarity of built-in current transformers (routine test)

Test date: Apr. 09, 2020

Relative humidity: 46%; Oil temperature: 18.9°C

Management winding	A	В	С	0
Measured winding	P1-P2	P1-P2	P1-P2	P1-P2
Ratio	40.12	40.06	39.95	39.98
polarity	-	-	-	-

4.7 Insulation test of auxiliary wiring (routine test)

Test date: Apr. 09, 2020

Relative humidity: 46%; Ambient temperature: 19.3°C; Oil temperature: 18.9°C; Air pressure: 102kPa

Parts of applied voltage		Test voltage (kV)	Test duration (s)	Result	
Wring for auxiliary power and control circuit	On-load tapping power	2.0	60	PASS	
	A	2.5	60		
Wring for secondary winding of	В	2.5	60	D. 00	
current transformer	С	2.5	60	PASS	
	0	2.5	60	1	

Test	Report			enter for Quali			№: 20N	40561-S
1001	report		Test of Ele	Total 68	Page 11			
4.8 Mea	surement of	voltage ratio	and check	of phase displace	ment (routin	e test)	Test date: A	pr. 09, 202
HV w	HV winding LV wind			Transformer	Measured	voltage rati (%)	o tolerance	Connect
Tapping position	Voltage (kV)	Tapping position	Voltage (kV)	ratio by calculation	AB/ab	BC/bc	CA/ca	symbo
1	121.000			11.524	0.08	0.11	0.12	
2	119.625			11.393	0.14	0.07	0.03	
3	118.250			11.262	0.10	-0.03	0.16	
4	116.875			11.131	0.01	-0.05	-0.13	
5	115.500			11.000	-0.10	-0.11	-0.10	
6	114.125			10.869	-0.04	-0.06	-0.02	
7	112.750			10.738	0.10	0.05	0.06	
8	111.375			10.607	0.08	0.09	-0.03	
9b	110.000	1	10.5	10.476	0.12	0.10	0.07	YNd11
10	108.625			10.345	0.06	0.09	0.08	
11	107.250			10.214	0.03	0.04	0.14	
12	105.875			10.083	-0.10	0.14	0.08	
13	104.500			9.952	-0.08	-0.10	-0.11	
. 14	103.125			9.821	-0.08	-0.11	-0.08	
15	101.750			9.690	0.07	0.10	0.11	
16	100.375			9.560	0.12	0.12	0.12	
17	99.000			9.429	0.06	-0.11	0.08	

SJJJ-YB005 (11)

DOJC

Test Report China National Center for Quality Supervision and
Test of Electrical Apparatus Products Total 68 Page 12

China National Center for Quality Supervision and
Test of Electrical Apparatus Products Total 68 Page 12

4.9 Measurement of winding resistance (routine test)

Test date: Apr. 10, 2020 Oil temperature: 18.8℃

			Measured values (9	2)	Resistance
Winding	Tapping position	A~O a~b	B~O b~c	C~O c~a	unbalance rate (%)
	1	0.32172	0.32157	0.32201	0.28
	2	0.31617	0.31672	0.31721	0.33
	3	0.31178	0.31201	0.31255	0.25
	4	0.30663	0.30690	0.30721	0.19
	5	0.30214	0.30256	0.30284	0.23
	6	0.29841	0.29869	0.29901	0.20
	7	0.29261	0.29302	0.29317	0.19
	8	0.28989	0.29007	0.29068	0.27
HV	9b	0.28131	0.28163	0.28195	0.23
	10	0.28793	0.28827	0.28856	0.22
	11	0.29283	0.29310	0.29337	0.18
	12	0.29782	0.29805	0.29832	0.17
	13	0.30276	0.30290	0.30331	0.18
	14	0.30697	0.30724	0.30757	0.20
	15	0.31127	0.31152	0.31178	0.16
	16	0.31558	0.31582	0.31609	0.16
	17	0.32049	0.32070	0.32112	0.20
LV	/	3.5195×10 ⁻³	3.5227×10 ⁻³	3.5324×10 ⁻³	0.36

Test date: Apr. 10, 2020

Test Report	China National Center for Quality Supervision and Test of Electrical Apparatus Products	№: 20M0561-S Total 68 Page 13
-------------	--	----------------------------------

4.10 Measurement of no-load loss and current (routine test)

Applied	r.m.s. vol	No-load	current	No-load loss (kW)		
voltage	Average voltmeter reading	r.m.s. voltmeter reading	(A)	(%)	Measured values	Corrected value
100%Ur	10.506	10.513	5.14	0.15	43.719	43.691
90%Ur	9.456	9.459	4.03	0.12	35.408	35.394
110%Ur	11.552	11.564	17.16	0.50	69.440	69.367

Remarks: the difference between r.m.s voltmeter reading and average voltmeter reading is within 3%.

4.11 Measurement of short-circuit impedance and load loss (routine test)

Test date: Apr. 10, 2020

Oil temperature: 18.8°C

Test date: Apr. 10, 2020

		Applied	current		Short-circuit i		Load loss (kW)	Total loss (kW)
Winding	Tapping position		I/Ir	Measured voltage (kV)	HV impedance (Ω)	(%) Corrected value		Corrected value
		(A)	(%)		t=75°C I=Ir	t=75℃ I=Ir	t=75°C I=Ir	t=75°C I=Ir
HV	1	163.60	54.42	11.276	39.80	17.12	208.019	251.710
	9ь	191.36	57.87	10.768	32.49	16.92	215.380	259.071
LV	17	206.41	56.18	9.255	25.89	16.64	248.905	292.596

4.12 Tests on on-load tap-changers (routine test)

Operation tests:

- a. with the transformer de-energized, eight complete cycles of operation (a cycle of operation goes from one end of the tapping range to the other, and back again);
- with the transformer de-energized, and with the auxiliary voltage reduced to 85 % of its rated value, one complete cycle of operation;
- c. with the transformer energized at rated voltage and frequency at no load, one complete cycle of operation;
- d. with one winding short-circuited and, as far as practicable, rated current in the tapped winding, 10 cycles of tap-change operations across the range of two steps on each side from where a coarse or reversing changeover selector operates, or otherwise from the middle tapping (the tapchanger will pass 20 times through the changeover position).

Test result: PASS

4.13 Lightning impulse test (routine test)

The test is not applied before the short-circuit withstand test.

4.14 Separate-source AC withstand voltage test (routine test)

Test date: Apr. 10, 2020

Relative humidity: 54%; Ambient temperature: 19.1°C; Oil temperature: 18.8°C; Air pressure: 102kPa

Parts of applied voltage	Test voltage (kV)	Test duration (s)	Result
HV neutral point—LV and earth	140.0	60	D. CC
LV—HV and earth	35.0	60	PASS

4.15 Line terminal AC withstand test (routine test)

Test date: Apr. 10, 2020

Relative humidity: 54%; Ambient temperature: 19.1°C; Oil temperature: 18.8°C; Air pressure: 102kPa

Phase to earth test

Parts of applied	Tapping	Applied voltage (kV)		d voltage kV)	Frequency	Test duration	Result
voltage	position	LV	1	IV	(Hz)	(s)	Result
а-с	1	21.0	A	200.0	11/3		
a-b	5	21.0	В	200.0	200	30	PASS
b-c	Y 1	21.0	С	200.0			

4.16 Induced AC withstand voltage test and induced AC withstand voltage test with partial discharge measurement (routine test)
Test date: Apr. 10, 2020

Relative humidity: 54%; Ambient temperature: 19.1°C; Oil temperature: 18.8°C; Air pressure: 102kPa

HV tapping position is 9b, frequency is 200Hz.

Applie	d voltage	Duration	Part	ial discharge magnitude	(pC)
Multiple	Phase to earth voltage (kV)	(min)	A	В	С
$0.4 \text{Ur}/\sqrt{3}$	25.4	1	<14	<15	<17
$1.2 Ur/\sqrt{3}$	76.2	1	<45	<50	<50
1.58Ur/√3	100.3	5	<87	<92	<85
2.0Ur/√3	127.1	0.5	1	1	1
		5	<89	<95	<88
		10	<85	<95	<88
		15	<88	<93	<90
		20	<90	<95	<90
		25	<90	<90	<92
		30	<88	<90	<90
1.58Ur/√3	100.3	35	<85	<95	<88
		40	<85	<97	<85
		45	<88	<97	<87
		50	<90	<95	<87
		55	<87	<95	<85
		60	<90	<90	<85
1.2Ur/√3	76.2	1	<44	<48	<50
0.4Ur/√3	25.4	1	<15	<17	<16

Remarks: Ur=110kV.

		compartment				Test d	e oil compartment ate: Apr. 09, 202 apperature: 18.5
Dielectric d	issipation facto	or(90°C)	Breakdown	voltage (kV)		Water conte	nt (mg/L)
	0.23%		6	1.0		8.9)
Gas chrom	atograph analy	sis (before all t	ests)			Test da	te: Apr. 09, 202 μL
H ₂	СО	CO ₂	CH ₄	C ₂ H ₆	C ₂ H ₄	C ₂ H ₂	Total hydrocarbo
1.65	10.53	46.78	1.14	0.00	0.00	0.00	1.14
Gas chrom	atograph analy	sis (after dielec	tric test, before	short-circuit t	est)	Test da	te: Apr. 11, 202 μL/.
H_2	со	CO ₂	CH ₄	C ₂ H ₆	C ₂ H ₄	C_2H_2	Total hydrocarbo
1.97	12.75	63.29	1.31	0,00	0.00	0.00	1.31
Gas chrom	atograph analy	sis (after short-	circuit test, bef	ore dielectric r	retest)	Test dat	e: Apr. 19, 2020 μL/
H_2	со	CO ₂	CH ₄	C ₂ H ₆	C ₂ H ₄	C ₂ H ₂	Total hydrocarbo
3.56	18.54	113.15	2.46	0.00	0.00	0.00	2.46
Gas chrom	atograph analy	sis (after dielec	tric retest, befo	ore long-duration	on no-load tes	t) Test da	te: Apr. 20, 202 μL
H_2	со	CO ₂	CH ₄	C ₂ H ₆	C ₂ H ₄	C_2H_2	Total hydrocarbo
3.83	20.37	132.65	2.83	0.00	0.00	0.00	2.83
Gas chrom	atograph analy	sis (after long-c	luration no-loa	d test, before to	emperature-ris	e test)Test da	te: Apr. 21, 202 μL/
H ₂	СО	CO ₂	CH ₄	C ₂ H ₆	C ₂ H ₄	C ₂ H ₂	Total hydrocarbor
3.91	21.48	135.77	2.90	0.00	0.00	0.00	2.90
Gas chrom	atograph analy	sis (after tempe	rature-rise test))		Test da	te: Apr. 22, 202 μL/
H_2	со	CO ₂	CH ₄	C ₂ H ₆	C ₂ H ₄	C ₂ H ₂	Total hydrocarbor
4.26	23.29	139.46	3.12	0.00	0.00	0.00	3.12

China National Center for Quality Supervision and №: 20M0561-S Test Report Test of Electrical Apparatus Products Total 68 Page 17 4.18 Measurement of frequency response (special test) Test date: Apr. 17, 2020 HV winding frequency response curves before short-circuit test AO BO co

SJJJ-YB015 (11)

China National Center for Quality Supervision and №: 20M0561-S Test Report Test of Electrical Apparatus Products Total 68 Page 18 LV winding frequency response curves before short-circuit test ab bc ca

Test date: Apr. 17, 2020

Test Report	China National Center for Quality Supervision and	№: 20M0561-S
Test Report	Test of Electrical Apparatus Products	Total 68 Page 19

4.19 Short-circuit withstand test (special test)

Single-phase supply should be used, and test voltage shall be supplied between HV line terminal and the other two line terminals connected together. HV neutral point is earthed, LV is connected by short-circuit and earthed and the test bushing tap is earthed. The test oscillogram shall be normal. For the test oscillogram, see

P₂₂₋₃₀. The percentages of peak current and symmetrical current are the ratio of applied current to calculated current

4.19.1 Current calculation of short-circuit test (reference temperature 75°C)

Tapping position	Symmetrical current value of phase (A)	Peak current value of phase (A)	Peak coefficient (K√2)
1	1699	4332	2.550
9b	1877	4786	2.550
17	2099	5352	2.550

4.19.2 Current injection of short-circuit test

	Phase of				Measi	urement of c	current			
Tapping position cur	peak current injection	Times	1.7 333434	Symmetrical current Peak current value of value of phase phase		Duration	Ossi	Ossilla serve Ma		
		injection		Measured values (A)	(%)	Measured values (A)	(%)	(s)	Oscillogram No	
		The first test	1622	95.47	4239	97.85	0.257	20M0	0561-S-T001	
		The second test	1668	98.18	4347	100.35	0.257	20M0	20M0561-S-T002	
		The third test	1650	97.12	4315	99.61	0.257	20M0)561-S-T003	
		Times			Measur	rement of re	actance			
1	A DC		Reacta	nce values	of phase (Ω)	R	Reactance var	iation of	phase (%)	
1	A-BC		A	В	С		A	В	С	
		Before tests	38.012	38.48	3 39.2	71	1	1	1	
		The first test	38.051	38.48	6 39.20	67 0	.10	0.01	-0.01	
		The second test	38.107	38.49	1 39.2	71 0	.25	0.02	0.00	
		The third test	38.151	38.49	6 39.2	76 0	.37	0.03	0.01	

The maximum reactance variation of phase is 0.37%.

	Dhasaas				Mea	surement o	f current		
Tapping pe position cur	Phase of peak current	Times	Symmetrical current Peak current value of value of phase phase		Duration	Ossill	0 "		
	injection		Measured values (A)	(%)	Measured values (A)	(%)	(s)	Oscii	logram No
		The first test	1818	96.86	4713	98.47	0.257	20M05	561-S-T004
		The second test	1829	97.44	4752	99.29	0.257	20M05	561-S-T005
		The third test	1844	98.24	4813	100.56	0.257	20M05	561-S-T006
			- 3		Meas	urement of	reactance		
9b	D.CA	Times	React	ance value	s of phase (s	2)	Reactance va	ariation of	phase (%)
90	B-CA	10	A	В		С	Α	В	С
		Before tests	31.212	31.84	43 31.	661	1	1	1
		The first test	31.332	31.8	86 31	667	0.38	0.14	0.02
		The second test	31.335	31.94	41 31.	672	0.39	0.31	0.04
		The third test	31.340	32.00	03 31.	677	0.41	0.50	0.05

The maximum reactance variation of phase is 0.50%.

	Phase of				Measi	urement of c	urrent			
Tapping position		ak Times	Symmetrical current value of phase		Peak curre	nt value of ase	Duration			
			Measured values (A)	(%)	Measured values (A)	(%)	(s)	Oscillogram No		
		The first test	2043	97.33	5328	99.55	0.257	20M05	61-S-T007	
		The second test	2019	2019 96.19 5267 98.41	0.257	20M05	61-S-T008			
		The third test	2087	99.43	5414	101.16	0.257	20M05	61-S-T009	
		Times	Measurement of reactance							
17			Reacta	Reactance values of phase (Ω)			Reactance var	ariation of phase (%)		
17			A	В	C		A	В	С	
			Before tests	24.362	25.36	4 25.2	70	1	1	/
		The first test	24.468	25.49	4 25.3	49 0	.44	0.51	0.31	
		The second test	24.472	25.49	8 25.3	99 0	.45	0.53	0.51	
		The third test	24.477	25.50	1 25.4	40 0	.47	0.54	0.67	


The maximum reactance variation of phase is 0.67%.

4.19.3 The out-of-tank inspection


Test date: Apr. 16, 2020 and Apr. 19, 2020

The out-of-tank inspection does not reveal any obvious distortion and displacement of coil, lead and supporting structures after the short-circuit test and no traces of discharge are found. For the pictures before and after the short-circuit test, see P₅₉₋₆₀.

China National Center for Quality Supervision and Test of Electrical Apparatus Products №: 20M0561-S Total 68 Page 22




China National Center for Quality Supervision and Test of Electrical Apparatus Products №: 20M0561-S Total 68 Page 23




China National Center for Quality Supervision and Test of Electrical Apparatus Products

№: 20M0561-S Total 68 Page 24




China National Center for Quality Supervision and Test of Electrical Apparatus Products

№: 20M0561-S Total 68 Page 25




China National Center for Quality Supervision and Test of Electrical Apparatus Products

№: 20M0561-S Total 68 Page 26




China National Center for Quality Supervision and Test of Electrical Apparatus Products

№: 20M0561-S Total 68 Page 27




China National Center for Quality Supervision and Test of Electrical Apparatus Products

№: 20M0561-S Total 68 Page 28




China National Center for Quality Supervision and Test of Electrical Apparatus Products №: 20M0561-S Total 68 Page 29



China National Center for Quality Supervision and Test of Electrical Apparatus Products

№: 20M0561-S Total 68 Page 30



4.19.4 Routine retests

4.19.4.1 Measurement of d.c. insulation resistance windings-to-earth and between windings (routine test)

Test date: Apr. 19, 2020

			Relative h	umidity: 49%; Oil ter	mperature: 21.3°C
Measured parts	R ₁₅ (GΩ)	R ₆₀ (GΩ)	R_{600} $(G\Omega)$	Absorption ratio (R ₆₀ /R ₁₃)	Polarity index (R ₆₀₀ /R ₆₀)
HV—LV and earth	28.6	38.9	53.2	1.36	1.37
LV—HV and earth	23.4	37.1	55.1	1.58	1.48
HV, LV—earth	13.2	20.5	32.2	1.55	1.57
HV—LV	36.2	48.8	79.5	1.55	1.63

4.19.4.2 Check of core and frame insulation for liquid-immersed transformers with core or frame insulation (routine test)

Test date: Apr. 19, 2020

Relative humidity: 49%; Oil temperature: 21.3°C

Measured parts	Measured insulation resistance (GΩ)	Insulation resistance corrected to $20^{\circ}\mathrm{C}(\mathrm{G}\Omega)$
Core—earth	10.9	11.5
Frame—earth	13.5	14.2
Core—frame	10.3	10.9

4.19.4.3 Measurement of dissipation factor (tanδ) of the insulation system capacitances (routine test)

Test date: Apr. 19, 2020

Relative humidity: 49%; Oil temperature: 21.3°C

Measured parts	Dielectric dissipation factor tanδ(%)	Capacitance (pF)
HV—LV and earth	0.35	11080
LV—HV and earth	0.33	17730
HV, LV—earth	0.38	19340
HV—LV	0.34	14530

4. 19.4.4 Determination of capacitances windings-to-earth and between windings (routine test)

Test date: Apr. 19, 2020

See 4.19.4.3

4.19.4.5 Measurement of bushing capacitances and dielectric dissipation factor (tanδ) (commission test)

Test date: Apr. 19, 2020

Relative humidity: 49%; Oil temperature: 21.1°C

Measured contents	Applied	Measured parts				
Weasured contents	voltage	A	В	С	0	
tanδ(%)		0.34	0.33	0.34	0.34	
Measured capacitance (pF)	10kV	298.2	298.4	297.3	350.1	

4.19.4.6 Check the ratio and polarity of built-in current transformers (routine test)

Relative humidity: 49%; Oil temperature: 21.1°C

Managed winding	A	В	С	0
Measured winding	P1-P2	P1-P2	P1-P2	P1-P2
Ratio	40.17	40.03	39.97	39.96
polarity	-	- 17	- 1	-

4.19.4.7 Insulation test of auxiliary wiring (routine test)

Relative humidity: 48%; Ambient temperature: 20.0°C; Oil temperature: 20.2°C; Air pressure: 102kPa

Parts of applied v	oltage/	Test voltage (kV)	Test duration (s)	Result
Wring for auxiliary power and control circuit	On-load tapping power	2.0	60	PASS
	A	2.5	60	PASS
Wring for secondary winding	В	2.5	60	PASS
of current transformer	С	2.5	60	PASS
	О	2.5	60	PASS

China National Center for Quality Supervision and №: 20M0561-S Test Report Test of Electrical Apparatus Products Total 68 Page 33 4.19.4.8 Measurement of voltage ratio and check of phase displacement (routine test) Test date: Apr. 19, 2020 Measured voltage ratio tolerance LV winding HV winding Transformer (%) Connection ratio by Voltage Voltage Tapping Tapping symbol calculation AB/ab BC/bc CA/ca position (kV) position (kV) 121.000 11.524 0.18 0.11 0.10 2 119.625 11.393 0.07 0.13 0.05 3 118.250 11.262 0.14 0.06 0.12 4 116.875 11.131 0.07 0.04 -0.155 115.500 11.000 -0.02-0.05 -0.10 6 114.125 10.869 0.05 0.13 -0.027 112.750 10.738 0.06 0.03 0.08 8 111.375 10.607 0.10 -0.06-0.039b 110.000 10.5 0.03 0.10 10.476 0.07 YNd11 10 108.625 0.06 10.345 -0.100.08 107.250 11 10.214 0.01 0.13 0.05 12 105.875 10.083 -0.10-0.120.12 13 104.500 9.952 -0.08-0.10-0.1014 103.125 9.821 -0.06 -0.11-0.10101.750 15 9.690 0.07 0.15 0.11 16 100.375 9.560 0.17 0.15 0.13 17 99.000 9.429 0.09 -0.040.10

SJJJ-YB012 (11)

4.19.4.9 Measurement of winding resistance (routine test)

Test date: Apr. 19, 2020 Oil temperature: 19.7°C

			Measured values (Ω)				
Winding	Tapping position	A~O a~b	B~O b~c	C~O c~a	unbalance rate (%)		
	1	0.32250	0.32284	0.32328	0.24		
Winding	2	0.31752	0.31797	0.31846	0.30		
	3	0.31301	0.31324	0.31378	0.25		
	4	0.30784	0.30811	0.30842	0.19		
	5	0.30344	0.30375	0.30403	0.20		
	6	0.29966	0.29987	0.30019	0.18		
	7	0.29383	0.29417	0.29433	0.17		
	8	0.29093	0.29121	0.29183	0.31		
HV	9b	0.28247	0.28274	0.28306	0.21		
	10	0.28913	0.28941	0.28970	0.20		
	11	0.29403	0.29425	0.29453	0.17		
	12	0.29907	0.29922	0.29950	0.14		
	13	0.30376	0.30409	0.30451	0.24		
	14	0.30822	0.30845	0.30878	0.18		
	15	0.31249	0.31275	0.31301	0.17		
	16	0.31688	0.31706	0.31734	0.14		
	17	0.32173	0.32196	0.32239	0.20		
LV	1	3.5325×10 ⁻³	3.5366×10 ⁻³	3.5463×10 ⁻³	0.39		

Test Report	China National Center for Quality Supervision and Test of Electrical Apparatus Products	№: 20M0561-S Total 68 Page 35
-------------	--	----------------------------------

4.19.4.10 Measurement of no-load loss and current (routine test)

Test date: Apr. 19, 2020

Applied	r.m.s. vol	No-load current		No-load loss (kW)		
voltage	The state of the s	(A)	(%)	Measured values	Corrected value	
100%Ur	10.508	10.515	5.11	0.15	43.724	43.695
90%Ur	9.456	9.461	4.02	0.12	35,409	35.390
110%Ur	11.552	11.564	17.23	0.50	69.411	69.343

Remarks: the difference between r.m.s voltmeter reading and average voltmeter reading is within 3%.

4.19.4.11 Measurement of short-circuit impedance and load loss (routine test)

Test date: Apr. 19, 2020

Oil temperature: 19.7°C

Test date: Apr. 19, 2020

Winding Tapping position	Appi		current		Short-circuit impedance (for each phase)		Load loss (kW)	Total loss (kW)
		I/Ir	Measured voltage (kV)	HV impedance (Ω)	(%)	Corrected value	Corrected value	
		(4	(A) (%)			t=75°C I=Ir	t=75°C I=Ir	t=75°C I=Ir
HV	1	165.37	55.01	11.415	39.86	17.15	207.982	251.677
	9b	189.73	57.38	10.693	32.54	16.94	215.330	259.025
LV	17	202.44	55.10	9.088	25.92	16.66	248.866	292.561

4.19.4.12 Tests on on-load tap-changers (routine test)

Operation tests:

- a. with the transformer de-energized, eight complete cycles of operation (a cycle of operation goes from one end of the tapping range to the other, and back again);
- b. with the transformer de-energized, and with the auxiliary voltage reduced to 85 % of its rated value, one complete cycle of operation;
- c. with the transformer energized at rated voltage and frequency at no load, one complete cycle of operation;
- d. with one winding short-circuited and, as far as practicable, rated current in the tapped winding, 10 cycles of tap-change operations across the range of two steps on each side from where a coarse or reversing changeover selector operates, or otherwise from the middle tapping (the tapchanger will pass 20 times through the changeover position).

Test result: PASS

Test Report China National Center for Quality Supervision and Test of Electrical Apparatus Products	№: 20M0561-S Total 68 Page 36
---	----------------------------------

4.19.4.13 Lightning impulse test (routine test, type test)

Test date: Apr. 20, 2020

Atmospheric conditions of test:

Relative humidity: 59%; Ambient temperature: 18.9°C; Oil temperature: 18.8°C; Air pressure: 102kPa.

Test items and voltage

Withstand terminals	Rated withsta	Tinin-		
withstalid terililiais	Lightning full wave	Lightning chopped wave	Tapping position A:1; B:9b; C:17	
A, B, C	480	530		
0	325	1	1	
a, b, c	75	85	1	

Test sequence:

Line terminal

One negative reduced level full impulse;

One negative rated level full impulse;

One negative reduced level chopped impulse;

Two negative rated level chopped impulse;

Two negative rated level full impulse.

Neutral point:

One negative reduced level full impulse;

Three negative rated level full impulse.

Test records:

T1: wave front time, T2: time to half peak value, Tc: chopped wave time, Up: peak voltage.

For waveform diagram, see P37~P43.

Voltage ranges of oscillograms are as below:

Withstand terminals	Full wave (kV)	Chopped wave (kV)
A, B, C	478.02~4882.82	530.72~533.28
0	324.47~325.93	/
a, b, c	74.96~76.12	84.36~86.82


SJJJ-YB014 (11)

China National Center for Quality Supervision and Test of Electrical Apparatus Products

№: 20M0561-S Total 68 Page 37

Channel 2: current wave


Tested terminal: A Test polarity: negative Channel 1: voltage wave



Test Report Tested terminal: B Test polarity: negative 258 MY 100.0 CH +100.0--200.0 M .00 CH2 0.00--1.00-法品 MA 100 0 CRI 0.0--100.0--300 D--400.0-

China National Center for Quality Supervision and Test of Electrical Apparatus Products

№: 20M0561-S Total 68 Page 38




China National Center for Quality Supervision and №: 20M0561-S Test Report Test of Electrical Apparatus Products Total 68 Page 39 Tested terminal: C Test polarity: negative Channel 1: voltage wave Channel 2: current wave 1835 50%国电全波 100%電車全流 .. SAM .. AF 100 0 CH -100.0--200.0-25.0 50.0 75.0 100.0 125.0 150.0 25'0 50'0 75'0 100'0 125'0 150'0 M .00_ CH2 MA .00 CH2 0.00 No. -- 1. 1-GA n. =-2. 186A; -0.50--1.00-25'0 50'0 75'0 100'0 125'0 150'0 25'0 50'0 75'0 100'0 125'0 150'0 it. 50%雷电影波 战局 100%智电载波 PA 500 0 CHI 0.0 -100 0--200 0--500 O--400 0--5.0 -600.0--5.0 M .00 - CH2 North Marian Any Mymm Min. =-1. 2764; in. ==2.17kA -3.00-5.0 10'0 15.0 50 100 15.0 试品 100%雷电载波 法品 100%冒电全流 FA 500 0 CMI FA 100 D CHI Uple-532 124V, f1=1 224s, fc=3 24ss; 0==0 00; 0.0-Vphc-479 166V; 51=1,17es; 52=53 45es. -200.0--400.0--500 0-, -5 0 0.0 5.0 10.0 15.0 20.0 25.0 50.0 75.0 100.0 125.0 150.0 Ary Marine 0.00laz #1 836A: er =1, 10kA -1.00--2.00-Rin. 2-2. 1684. a ==2.17ka -3.00-15.0 75'0 100.0 125.0 150.0 it. 100%雷电全流 .. LV 100.0 CHI -100.0--200.0--300.0--600.0--500.0--10.0 25.0 50.0 75.0 100.0 125.0 150.0 95 MA .00 CH2 -2.00--10.0 25.0 50.0 15.0 100.0 125.0 150.0

China National Center for Quality Supervision and №: 20M0561-S Test Report Test of Electrical Apparatus Products Total 68 Page 40 Test polarity: negative Tested terminal: O Channel 1: voltage wave Channel 2: current wave 战品 56%當电主法 zsio solo zsio solo szio ssio 15.7-9 tibs. -0.23 क्षी को पर्व को वार्क को 100%雷电全流 ist.8% zio solo 15'o 100'o 125'o 126'o" ar =0.005A Sin. +-0. 92hA zace solo race noto nzie nebe ita. 1004雷电空流 MF 100 9_CH1 -300.0-25'8 50'0 75'8 100'0 124'0 150'0** 0.50--1 00asie selo reio sedo sasie asie 甜品 1004国电量表 MF 100.0 CH -100.0--200.0--900 d zin mio wio mio nzio mio" 0.00 No. 4-1 0784 -0.53 zsio soio mio mio mio miso mio

China National Center for Quality Supervision and Test of Electrical Apparatus Products

№: 20M0561-S Total 68 Page 41



China National Center for Quality Supervision and Test of Electrical Apparatus Products №: 20M0561-S Total 68 Page 42

Tested terminal: b Test polarity: negative Channel 1: voltage wave Channel 2: current wave 50%国电全流 toow雷电全流 H.H at B .. . NF 10.0 CHI MV 20.0-0.0--30.0--60.0-25'0 50'0 75'0 100'0 125'0 150'0" 25'0 50'0 15'0 100.0 125.0 150.0 MA 20 TO M . 40_ CH2 0.10es. 40. 16kA 0.20-0.00lin. 110.36sA -0.10--0.20-25'0 50'0 75'0 100'0 125'0 150'0 25'0 50'0 TS'0 100'0 125'0 150'0 法品 50%間由能決 .. 试品 100%雷电截波 0.0 CEI D 0 - CHI -20 0 --40 0 --60 0 --80 0 --10.0-1940-42 51-1.29us: 7c=3.10us: 0ur0.19: 8A .75 CH2 14 .40 CHZ MM.... in. ==0.34kA lin. =-0.71kA -0.50--0.75--5.0 00 50 进品 itB .. MY 20.0 - CHI M 20 0 CM1 -20.0--40.0--60.0-Uple-75, 61kV, 7141, 19es; 7248, 57cs; -20.0--40.0--80.0--10.0 25'0 50'0 75'0 100'0 125 0 150'0" 10'0 15'0 20'0 0.0 5.0 0.50ar. 20.656A 0.20-Ber. 40, 3156 fin =-0.66kA 0.00 Nin. =-0. 33kA -0 25 --0 50 --0 75 --5 0 -0.20--0.40-过品 100%雷电全波 M 20.0 CHI 0.0--40.0--ca.o--60.0--10.0 25 0 50 0 75 0 100 0 125 0 150 0 48 M . 40 CH2 0.20--0.20 25.0 50.0 75.0 100.0 125.0 150.0

China National Center for Quality Supervision and №: 20M0561-S Test Report Test of Electrical Apparatus Products Total 68 Page 43 Tested terminal: c Test polarity: negative Channel 1: voltage wave Channel 2: current wave 扰品 sor雷电全波 id 2h 100%雷电全流 M 50.0 CH -10.0--20 0--20.0--30.0--40.0--60.0--50 0--10 0 -60 D--10 D 25'0 50'0 75'0 100'0 125'0 150'0" 25 0 50 0 75 0 100 0 125 0 150 0 WS 0. 20-0. 10-0. 50--0. 10--0. 20--0. 30--10. 0 No. 110.223A No. 4-0.34ka -0.20--0. 40 --10.0 25.0 50.0 75.0 100.0 125.0 150.0 itB 100%雷电截波 . FA 10 0 - CMI M 20.0 CM -10 0--20 0--30 0--40 0--40. -50.0--5.0 -100.0--5.0 50 10'0 15'0 20'0 5.0 10.0 15.0 20.0 ex. =0.655A Sin. =-0.31%A Nin. ==0. 655A -0.25 -0.50 -0.75 -5.0 -0.20 -0.40-5.0 15.0 战船 100%當电影波 .. int. 100%智能全流 .. M 20 0_CH1 MY 20 0 CRI 0.0--20.0--40.0--50.0--40.0--60.0--80.0--900.0--5.0 10'0 15'0 20'0" 25'0 50'0 75'0 100'0 125'0 150'0" MA 40 CH2 0.20-0.00--0 20-5.0 25.0 50.0 75.0 100.0 125.0 150.0 机品 100%雷电全波 M 20.0 CHI 0.0--20:0--60:0--00.0-25.0 50.0 75.0 100.0 125.0 150.0° M . 47 - CH2 0.20sr =0.31kA Win. =-0.330A -0.29zsio solo Tsio 100.0 125.0 150.0

SJJJ-YB015 (11)

Test Report China National Center for Quality Supervision and
Test of Electrical Apparatus Products

Total 68 Page 44

4.19.4.14 Separate-source AC withstand voltage test (routine test)

Test date: Apr. 20, 2020

Relative humidity: 59%; Ambient temperature: 18.9°C; Oil temperature: 18.8°C; Air pressure: 102kPa

Parts of applied voltage	Test voltage (kV)	Test duration (s)	Result
HV neutral point—LV and earth	140.0	60	DACC
LV—HV and earth	35.0	60	PASS

4.19.4.15 Line terminal AC withstand test (routine test)

Test date: Apr. 20, 2020

Relative humidity: 59%; Ambient temperature: 18.9°C; Oil temperature: 18.8°C; Air pressure: 102kPa

Phase to earth test

Parts of applied	Tapping	Applied voltage (kV)		d voltage kV)	Frequency	Test duration	Danult
voltage p	position	LV	HV		(Hz)	(s)	Result
a-c	AST	21.0	A	200.0			
a-b	5	21.0	В	200.0	200	30	PASS
b-c	E.	21.0	С	200.0			

Test Report China National Center for Quality Supervision and
Test of Electrical Apparatus Products

Total 68 Page 45

4.19.4.16 Induced AC withstand voltage test and induced AC withstand voltage test with partial discharge measurement (routine test)

Test date: Apr. 20, 2020

Relative humidity: 59%; Ambient temperature: 18.9°C; Oil temperature: 18.8°C; Air pressure: 102kPa

HV tapping position is 9b, frequency is 200Hz.

Applie	d voltage	Duration	Parti	al discharge magnitude	(pC)
Multiple	Phase to earth voltage (kV)	(min)	A	В	С
$0.4 Ur/\sqrt{3}$	25.4	I	<16	<17	<18
1.2Ur/√3	76.2	1	<47	<40	<45
1.58Ur/√3	100.3	5	<85	<87	<89
$2.0 Ur/\sqrt{3}$	127.1	0.5	1	1	/
	- 4	5	<84	<87	<87
	///	10	<84	<87	<87
	47	15	<84	<87	<87
		20	<84	<87	<87
		25	<85	<86	<87
		30	<85	<86	<87
1.58Ur/√3	100.3	35	<85	<86	<88
	10.	40	<85	<86	<88
		45	<85	<86	<88
		50	<84	<86	<88
		55	<84	<86	<88
		60	<84	<86	<88
1.2Ur/√3	76.2	1	<45	<42	<42
0.4Ur/√3	25.4	1	<15	<15	<17

Remarks: Ur=110kV.

SJJJ-YB013 (11)

Test Report China National Center for Quality Supervision and
Test of Electrical Apparatus Products

Total 68 Page 46

Total 68 Page 46

4.19.4.17 Insulating liquid test, measurement of dissolved gasses in dielectric liquid from each separate oil compartment except diverter switch compartment (routine test)

Test date: Apr. 19, 2020


Relative humidity: 61%; Ambient temperature: 20.0°C

Dielectric dissipation factor(90°C)	Breakdown voltage (kV)	Water content (mg/L)
0.36%	58.1	9.8

Remarks: for measurement of dissolved gasses in dielectric liquid, see 4.17.



China National Center for Quality Supervision and №: 20M0561-S Test Report Test of Electrical Apparatus Products Total 68 Page 47 4.19.4.18 Measurement of frequency response (special test) Test date: Apr. 18, 2020 HV winding frequency response curves after short-circuit test AO BO co



SJJJ-YB015 (11)

3.520

4.025

4.515

5.104

8.614

17.231

35.145

China National Center for Quality Supervision and №: 20M0561-S Test Report Test of Electrical Apparatus Products Total 68 Page 49 4.20 Measurement of no-load excitation characteristics (commission test) Test date: Apr. 21, 2020 Voltage Measured voltage (kV) Measured current (A) $0.50U_r$ 5.253 2.114 0.60Ur 6.304 2.588 $0.70U_r$ 7.352 3.045

8.398

9.452

9.973

10.506

11.029

11.552

12.056

1.15U_r

Remarks: U_r=10.5kV.

 $0.80U_r$

0.90Ur


0.95Ur

1.00U_r

1.05U_r

1.10U_r

No-load excitation characteristic curve



Test Report	China National Center for Quality Supervision and Test of Electrical Apparatus Products	№: 20M0561-S Total 68 Page 50
-------------	--	----------------------------------

4.21 Long-duration no-load test (special test)

Test date: Apr. 21, 2020

Test with 1.1 times rated voltage applied on LV side for 12h. No C_2H_2 is found in oil and the content of total hydrocarbon has no obvious variation before and after the test. For gas chromatograph analysis data, see 4.17.

Duration (h)	Voltage (kV)	Current (A)	No-load loss (kW)
1	11.553	17.228	69.453
2	11.554	17.230	69.448
3	11.552	17.232	69.457
4	11.551	17.234	69.505
5	11.553	17.231	69.512
6	11.552	17.228	69.517
7	11.552	17.228	69.505
8	11.551	17.229	69.512
9	11.553	17.228	69.522
10	11.558	17.230	69.523
11	11.557	17.234	69.528
12	11.559	17.232	69.530

4.22 Measurement of short-circuit impedance on LV (commission test)

Test date: Apr. 19, 2020 Oil temperature: 19.7°C

					Short-circuit (for each	
	Tapping position	Applied currentI		Measured voltage (kV)	HV impedance (Ω) t=75°C I=Ir	(%) t=75°C I=Ir
	(A) I/Ir(%)	I/Ir(%)				
HV	1	5.53	1.84	0.3821	39.88	17.16
	9Ь	6.79	2.05	0.3816	32.44	16.89
LV	17	8.46	2.30	0.3810	26.01	16.72

4.23 Measurement of zero-sequence impedances on three-phase transformers (special test)

Test date: Apr. 19, 2020

Connection symbol	Power supply terminal	Open-circuit terminal	Short-circuit terminal	Tapping position	Applied current (A)	Measured voltage (V)	Impedance (Ω)
YNd11	ABC-O	abc	1	9b	105.7	957.2	27.167

Tes	t Report			uality Supervision a paratus Products		: 20M0561-S al 68 Page 51
4.24]	Measurement of	the harmonics of the	e no-load current	(commission test)	Test d	ate: Apr. 19, 2020
	CH-A TI	HD =13.53	CH-B TI	HD =14.44	CH-C TI	HD =12.21
No -	In(A)	In/I1(%)	In(A)	In/I1(%)	In(A)	In/I1(%)
01	5.05	100.00	4.69	100.00	5.58	100.00
02	0.02	0.35	0.03	0.70	0.03	0.60
03	0.11	2.24	0.10	2.22	0.10	1.85
04	0.07	1.45	0.07	1.41	0.10	1.86
05	0.59	11.60	0.57	12.25	0.61	10.95
06	0.14	2.73	0.14	2.93	0.12	2.16
07	0.18	3.55	0.20	4.17	0.05	0.87
08	0.04	0.78	0.04	0.85	0.04	0.70
09	0.01	0.25	0.03	0.54	0.02	0.36
10	0.01	0.11	0.01	0.18	0.01	0.22
11	0.13	2.56	0.11	2.44	0.10	1.84
12	0.03	0.52	0.04	0.88	0.07	1.25
13	0.19	3.67	0.19	4.15	0.18	3.27
14	0.01	0.22	0.02	0.32	0.01	0.17
15	0.01	0.25	0.01	0.18	0.01	0.20
16	0.01	0.11	0.00	0.08	0.01	0.14
17	0.00	0.00	0.00	0.00	0.00	0.00
18	0.00	0.00	0.00	0.00	0.00	0.00
19	0.00	0.00	0.00	0.00	0.00	0.00

SJJJ-YB010

Test Report	China National Center for Quality Supervision and	№; 20M0561-S
Test Report	Test of Electrical Apparatus Products	Total 68 Page 52

4.25 Temperature-rise test (including calculation of the winding hot-spot temperature-rise) (type test)

Test date: Apr. 22, 2020

Measurement of top oil temperature rise: The method of temperature rise is the equivalent test in short-circuit connection. The HV (tapping position 17) is supplying power. Test duration is 12h and of which the stabilization time is 3h. it is required to apply 292.561kW of total loss and 292.918kW is actually applied during testing.

Measurement of winding temperature rise: 367.42A current is required and 367.55A is actually applied during testing.

					Measure	d data					
	emperature oil tempera		Measu	Measurement of average temperature-rise windings to oil							
Top oil oil tempera-		Total loss injection/ specified total loss (%)	Current injection/ rated current (%)	Cold	resistance (Ω)	Average oil temperature (°C)		Average winding temperature (°C)		Total loss	Measurement of cold resistance
70.6	59.2	100.12	100.04	HV	0.6488	At the instant of power off	58.9	HV	76.5	21.0	10.7
70.0	39.2	100.12	100.04	LV	3.5325 ×10 ⁻³	At the end of cooling curve	58.4	LV	77.5	21.8	19.7
				Calcul	ations of te	emperature-rise					
Торо	il temperat	ure-rise (K)					48.8			
Windi	ng tempera	ture-rise (k	HV			54.9					
77 1141	Winding temperature-rise (K)			LV		55.9					
Winding hot-spot temperature-rise				HV		69.8					
	(K)			LV			71.0				
and m	etal structu	f tank surfa ral parts (K	3)			landa a land		39.3		1	

Remarks: the calculated of temperature-rise are the corrected value under specified total loss and rated current. HV winding hot-spot coefficient is 1.2 and LV winding hot-spot coefficient is 1.2.


China National Center for Quality Supervision and Test of Electrical Apparatus Products №: 20M0561-S Total 68 Page 53

Winding temperature curve

Average winding temperature data

Average HV winding temperature

76.5℃



China National Center for Quality Supervision and Test of Electrical Apparatus Products


№: 20M0561-S Total 68 Page 54

Winding temperature curve

Average UV winding


Average LV winding temperature

77.5℃



China National Center for Quality Supervision and Test of Electrical Apparatus Products №: 20M0561-S Total 68 Page 55

Thermograph of tank and metal structural parts



Test Report China National Center for Quality Supervision and
Test of Electrical Apparatus Products

No: 20M0561-S
Total 68 Page 56

4.26 Leak testing with pressure for liquid-immersed transformers (routine test)

Test date: from Apr. 11, 2020 to Apr. 13, 2020

Test method	Parts of applied voltage	Applied pressure (kPa)	Duration (h)	Residual pressure (kPa)	Result
Static pressure	Body	30.0	24	29.5	No oil leakage or damage
method	On-load tap-changer tank	30.0	24	29.6	No oil leakage or damage

Remarks: the product is a general structure tank.



China National Center for Quality Supervision and Test of Electrical Apparatus Products

№: 20M0561-S Total 68 Page 57

4.27 Determination of sound levels (type test)

Test date: Apr. 19, 2020

4.27.1 Rough estimation of the load current sound power level

Equation:

$$L_{WA,IN} \approx 39 + 181g \frac{Sr}{Sp} = 71.4dB(A)$$

where: Sr-the rated power is 63MVA;

Sp-the reference power is 1MVA.

Because L_{WA,IN} is less 8.6dB (A) than limit value 80dB (A) of assured sound power level, according to standard requirement, it need not to measure load current sound level.

4.27.2Measurement of sound pressure level and calculation of sound power level

The transformer is rated excitation; the prescribed contour shall be spaced 0.3m away from the principal radiating surface, the distance between measured points is 0.96m, the number of measured points is 24, the height of measured point 1 is 1.07m and point 2 is 2.15m.

Test environment

The total area of the surface of the test room Sv (m ²)	The average acoustic absorption coefficient α	The amount of acoustic absorption A (m²)	Distance from the principal radiating surface (m)	The area of the measurement surface S (m ²)	Environmetal correction K (dB)
3293.2	0.1	329.3	0.3	93.8	3.3

Managered values

(dB)

Status		age of und noise	Average noise value	A weighted sound pressure level	A weighted sound power level
of cooling device	Before the test	After the test	$\frac{\text{of transformer}}{L_{\text{pA0}}}$	$\overline{L_{pA}} = 10 \lg (10^{0.1\overline{L_{pA0}}} - 10^{0.1\overline{L_{bgA}}}) - K$	10.444
1	31.7	31.8	57.2	54	74

Remarks: $\overline{L_{pA0}}$: the uncorrected average A-weighted sound pressure level; $\overline{L_{pA0}} = 10 \lg (\frac{1}{N} \sum_{i=1}^{N} 10^{0.1 L_{pAi}})$

 $L_{\mbox{\scriptsize bgA}}$: the lower of the two calculated average A weighted background noise pressure level.

Test Report	vision and №: 20M0561-S ucts Total 68 Page 58	
4.28 Mechanical stren	gth test of tank (type test)	Test date: Apr. 13, 202
Test method	Applied pressure (kPa)	Duration (min)
rest method	rippined pressure (kt a)	Daration (mm)
Degree of vacua	- Production (cally)	5

			Measured point													
		Tank wall										Ta	Tank cover			
М	Measured items		HV	side			LV side				Left side	Right side		Middle of length		
		strengthen		Left Middle Right		strengthen	strengthen	Middle	Middle	strengthen	strengthen	strengthen	Middle	Left	Middle	Right
	Initial distance (mm)	400	400	400	400	400	400	400	400	350	350	350	350	300	300	300
Degree of vacuum	Distance after pressure injection (mm)	412	415	414	413	412	414	415	417	363	367	364	365	311	312	310
	Distance without pressure (mm)	406	408	407	407	405	407	407	408	356	359	357	358	305	306	304
	Elastic deformation (mm)	12	15	14	13	12	14	15	17	13	17	14	15	11	12	10
	Permanent deformation (mm)	6	8	7	7	5	7	7	8	6	9	7	8	5	6	4
	Initial distance (mm)	406	408	407	407	405	407	407	408	356	359	357	358	305	306	304
ure	Distance after pressure injection (mm)	395	393	393	392	394	396	395	393	346	343	342	345	293	295	295
Positive pressure	Distance without pressure (mm)	401	399	400	401	400	401	399	401	350	351	350	351	299	301	301
Positi	Elastic deformation (mm)	11	15	14	15	11	11	12	15	10	16	15	13	12	11	9
	Permanent deformation (mm)	5	9	7	6	5	6	8	7	6	8	7	7	6	5	3
	Remarks	No da	amage													

Remarks: 1. the product is a general structure tank.

the described left and right sides of test point are viewed from HV side.
 the left, middle and right test points of HV and LV side are obtained from the 1/2 height in vertical direction, 1/4,1/2 and 3/4 position respectively in horizontal direction.

China National Center for Quality Supervision and Test of Electrical Apparatus Products №: 20M0561-S Total 68 Page 59

HV side before short-circuit:



LV side before short-circuit:



SJJJ-YB016 (11)


China National Center for Quality Supervision and Test of Electrical Apparatus Products №: 20M0561-S Total 68 Page 60

HV side after short-circuit:




LV side after short-circuit:






China National Center for Quality Supervision and №: 20M0561-S Test Report Test of Electrical Apparatus Products Total 68 Page 62 Power analyzer Schematic of load test Н Ç es

	lest
	hstand voltage t
	Schematic of separate-source AC withstand voltage test
	natic of separate
	Schen
<u>></u>	



DQJC



	Test Report	China National Center for Quali	ty Supervision and	№: 20M0561-S		
	Test Report	Test of Electrical Apparat	us Products	Total 68 Page 66		
		Instruments used in th				
No	Test items					
i	Measurement of d.c. insul resistance windings-to-e and between winding	Digital maga alum mater	ER17-017	200k~5/10/20/50/		
2	Check of core and fran insulation for liquid-imme transformers with core or insulation	rsed F1550C	2020-06-17	100GΩ class 5, others class 20		
3	Measurement of dissipat factor (tanδ) of the insula system capacitances	tion		Capacitance:		
4	Determination of capacita windings-to-earth and betwindings	ween and analysis system MIDAS2880	ER19-002 2021-03-19	±0.3%rdg±0.3pF Inductance: ±0.5%rdg±0.5mH		
5	Measurement of bushir capacitances and dielect dissipation factor (tank	ric)		±0.5%dg±0.5mH		
6	Check the ratio and pola of built-in current transformers	ratio tester YTB	RI15-012 2021-02-28	Ratio±0.2% Phase position 0.2°		
7	wiring	Insulation test of auxiliary Power-frequency withstand voltage tester PFT6-5 2020-1		1		
8	ratio and check of phas displacement	Measurement of voltage ratio and check of phase displacement Full-automatic three-phase transformer ratio tester 2796 2020-0		±0.1mA, ±0.05°		
9	Measurement of windir resistance	DC resistance tester JYR(50C)	ER16-056 2020-10-09	0.2%±0.2μΩ		
10 11	Measurement of short-cir impedance and load los Measurement of no-load	cuit s OSS Transformer power loss test		Voltage range: 100V~200kV, accuracy; 0.12% curren		
12	and current Tests on on-load tap-chan	systemTMS580-200-4000	2020-08-25	range: 1A~4000A, accuracy; 0.15%		
13	Separate-source AC	Power-frequency partial discharge-free test transforme YDTCW-1000kVA/1000kV	745-034 2021-09-24	/		
	withstand voltage test	Capacitance voltage divider TRF1000-0.0005	745-034-1 2021-09-24	1		
14	Line terminal AC withsta test		749-1237	Voltage range: 100V~200kV, accuracy; 0.12% curren range: 1A~4000A, accuracy; 0.15%		
		Transformer power loss test system TMS580-200-4000	749-1237 2020-08-25	Voltage range: 100V~200kV, accuracy; 0.12% curren range: 1A~4000A, accuracy; 0.15%		
15	Induced AC withstand voltage test and induced A withstand voltage test with partial discharge measurement		RU10-013 2020-12-04	Discharge magnitude: 10,50,100,500pC; 5,10,20,50,100p Pulse rise time <60ns Frequency range: 50Hz-1000Hz Measuring range of the whole: 0.1pC-10000nC Measuring channel: independent 4 channel Detection sensitivity: 0.1pC Sampling accuracy: 12Bit Sampling rate: 20MHz Non-linear error of the span: 5% Range switching: ×1, ×10, ×100, ×1000, ×10000, ×100000 Capacitance range of the testable sample: 6pF-250µF Measuring band: 3dB bandwidth 10kHz-1MHz		

	Test Report	China National Center for C	Quality Supervision and	№: 20M0561-S
	Test Report	Test of Electrical Ap	Total 68 Page 67	
		Instruments used i	n the tests	
No	Test items	Name & type of instrument	Number & validity	Accuracy level
	2 4 4 6 6	Automatic dielectric strength tester NRNY-1004	ER18-005 2020-12-03	±3%
16	Insulating liquid test, measurement of dissolved gasses in dielectric liquid	High precision full-automatic capacitance, inductance and dielectric loss measuring bridge 2840-Combi	ER18-003 2020-07-22	±0.02%rdg±0.01pF;± 0.5%rdg±1×10 ⁻⁵
16	from each separate oil compartment	Gas chromatogram analyzer 7890B	749-1732 2020-12-17	1
	except diverter switch compartment	Moisture analyzer CA-200	CA02-002 2020-05-09	±3μg (water for 10μg 1mg or above) RSD 0.3% or under (water for 1mg or above)
17	Measurement of frequency response	Transformer winding deformation tester FRAX99	ER16-021 2021-01-15	1
		Voltage transformer TEMP-1000HU	EH112-001 2020-11-08	/
		Voltage transformer VEOS525	EH111-001 2020-10-09	1
	Short-circuit withstand test	Voltage transformer VEOS525	EH111-002 2020-10-09	1
		Voltage transformer VEOS525	EH111-003 2020-10-09	1
		LCR automatic tester UC2860XD	ER16-063 2020-08-06	1
18		Data collection 1-GEN16T-2	EI56-019 2021-01-02	1
		Current divider FLT1-30/2.5	EI30-016 2021-10-28	1
		Current divider FLT1-30/2.5	EI30-017 2021-10-28	1
		Current divider FLT1-30/2.5	EI30-018 2021-10-28	1
		Low sensitivity current divider FLP1	EI31-081 2021-02-26	1
		Low sensitivity current divider FLP1	EI31-082 2021-02-26	1
19	Lightning impulse test	Impulse voltage generator CJDY-1050kV/59kJ	750-009 2020-08-02	1
20	Measurement of no-load excitation characteristics			
21	Long-duration no-load test			
22	Measurement of short-circuit impedance on LV	Transformer power loss test system	749-1237 2020-08-25	Voltage range: 100V~200kV, accuracy
23	Measurement of zero-sequence impedances on three-phase transformers	TMS580-200-4000	177-1237 2020-00-23	0.12% current range: 1A~4000A, accuracy; 0.15%
24	Measurement of the harmonics of the no-load current			

SJJJ-YB017 (11)

	Test Report	China National Center for Test of Electrical Ap	№: 20M0561-S Total 68 Page 68	
		Instruments used	in the tests	-
No	Test items	Name & type of instrument	Number & validity	Accuracy level
		Transformer power loss test system TMS580-200-4000	749-1237 2020-08-25	Voltage range: 100V~200kV, accuracy 0.12% current range: 1A~4000A, accuracy; 0.15%
25		Thermocouple Type T	TT33-129/130/131/132/1 33/134 2021-02-16	1
	Temperature-rise	Data acquisition/switch unit 34970A	TT11-065 2021-02-16	V±5.25%, A±1.5%, T±1°C, Ω±0.81%
	test	DC resistance tester JYR(50C)	ER16-055 2020-10-09	0.2%±0.2μΩ
		DC resistance tester JYR(50C)	ER16-056 2020-10-09	0.2%±0.2μΩ
		Electronic stopwatch PC396	HT15-010 2021-03-23	1
		Infrared gas leak detector and temperature imager GF306	TT14-017 2020-11-13	±2%(reading range) or ±2°C
26	Leak testing with pressure for liquid-immersed transformers	Pressure gauge Y-100	FP81-428 2020-10-07	Class 1.6
	Determination of	Transformer power loss test system TMS580-200-4000	749-1237 2020-08-25	Voltage range: 100V~200kV, accuracy; 0.12% current range: 1A~4000A, accuracy; 0.15%
27	sound levels	Sound level meter 2270	SP01-013 2020-08-12	Class 1
		Sound level calibrator 4231	SP01-020 2020-07-22	Class 1
		Steel tapeline	LS05-032 2021-04-15	1
	Mechanical	Pressure gauge Y-100	FP81-428 2020-10-07	Class 1.6
28	strength test of	Steel tapeline	LS05-032 2021-04-15	1
	tank	Vacuum gauge	FP81-514 2020-07-07	Class 2.5

The remainder of this page is intentionally left blank.

SJJJ-YB017 (11)

DECLARATION

- 1. The report is invalid without special seal for testing and page combining seal on the report;
- 2. The report is invalid if altered;
- The report is invalid without signatures of persons for drawing up, proof-reading, reviewing and approval;
- 4. The report is valid only for the inspected and tested samples.

NOTICE

- In case there is any objection to this report, please raise it to the laboratory within fifteen days starting from the date of receiving the report, Thank you for your cooperation.
- 2. In case there is no objection, please take back the samples within one month starting from the date of receiving the report, when the manufacturer is going to take back the samples, certificate for sample taking and along with the written approval for the report should be brought in presence, only then the samples could be taken back. On time due, the samples will be in the laboratory's own disposal.

The test report is in total 68 pages

including 28 figures

and 3 photos

Typewriter Yuan Xiaoyong

Proofreader Liu Yongning

Binder Yuan Xiaoyong

Address: No.5 Qianzhu Rd., Yuexi, Wuzhong District, Suzhou

Tel: (0512)66556600(switchboards) 68252753 68081201

Fax: (0512)68081686

Post code: 215104

http://www.eeti.cn

E-mail: eservice @eeti.c

1

《CEEG中电电气

110KV (60kV) Oil-immersed Power Transformer

LOW CONSUMPTION & ENERGY SAVING



WWW.CEEGPOWER.COM

CCEEG 中电电气
China Electric Equipment (Jiangsu) Transformer Manufacture Co.,Ltd
Address: 188 Ganglong Road, Yangzhong Economic Development Zone, ZhenJiang City, Jiangsu Province, China Tel: 0511-88222224 18014583377
Website: www.ceegpower.com

V 2021.12



All data on this catalogue printed by CEEG are used for illuminating the relative information of this series products. CEEG have any right to do any improving for it whenever the technology should be upgraded or the production craftwork should be renewed possibly, or do some necessary correction because of the literal error and inaccurate information of this manual without any prior notice. When you make your orders, please keep in touch with relative personnel in order to confirm if your information is right.





Founded in 1990, CEEG has been focusing on manufacturing for 30 years and exporting quality power equipment to the world with the core values of "Vision, Innovation and Responsibility". So far, CEEG has three major industries: power transmission and distribution, new energy and system solutions, with industrial bases in Nanjing and Yangzhong. CEEG was successively awarded the honorary titles of National Innovative Enterprise, Top 500 Asian Brands, Most Influential Brand of China Electrical Industry, China Environmental Label, and National Contract-observing and Creditable Enterprise. In 2011, CEEG was ranked 183rd among the top 500 private enterprises in China with sales of 10.9 billion. China Electric Equipment (Jiangsu) Transformer Manufacture Co., Ltd. is a modern enterprise integrating manufacturing, sales and scientific research. It has a complete set of shearing machines, automatic wrapping machine, robotic automatic laminating machine, German Hedrich vacuum casting tank, vacuum impregnation, electric transfer vehicle and other advanced equipments representing a high level in the industry, and is the first in the industry to develop and apply transformer collaborative design platform to effectively combine product data, product development and production process. CEEG's products include VPI transformer, cast resin transformer, semi-envelope transformer, oil-immersed transformers, traction transformers, 220kV power transformers, 110kV power transformer, mining explosion-proof transformer, mining explosion-proof switches, high and low voltage switchgear, frequency conversion transformer, amorphous alloy transformer, anti-harmonic transformer, Scott transformer, substation, wind power transformer, marine transformer, etc. Its sales cover many industries such as electric power, electronics, hydropower, nuclear power, wind power, coal mines, communications, construction, petroleum, chemical industry, aviation, transportation, railroad, etc.

Walking with giants and keeping pace with the world. CEEG has established long-term strategic partnerships with world-class companies such as DuPont, Schneider, DSI. Pursuing innovation, fulfilling responsibilities, and constantly surpassing products, quality, services and actions, it has developed into a domestic giant power transmission and distribution equipment supplier with a solid industrial foundation. Its cast resin dry type transformers have been exported to more than 40 countries and regions in the world. The strategic layout of brand internationalization and service globalization has been formed!

Make CEEG the world's first choice!












110kV (60kV) Oil Immersed Power Transformer



The new high-temperature resistant transformer independently developed by CEEG adopts a mixed insulation structure, and the hot spot temperature part of the body uses DuPont's Nomex insulation material (grade C heat resistance) and mineral oil, which truly meets the operational requirements of "high overload, safety and reliability" in the whole life cycle. This product is the best choice for users with special high requirements for transformers or renewal and transformation (capacity expansion and transformation on the basis of the original transformer).





Low energy consumption and large capacity

The no-load loss of the product is more than 10% lower than that of the current national standard gb6451-2015, and the load loss is more than 5% lower than that of the current national standard gb6451-2015. The performance meets the energy efficiency standard of gb20052-2020. The noise level of self-cooling is lower than the national standard. According to the needs of users, the advanced Nomex insulating material and transformer insulating oil of DuPont can be used to make the product performance meet the requirements of high overload, high service life, high reliability, high safety and high capacity density.





Performance characteristics



Low Loss

The no-load loss is more than 10% lower than the current national standard GB6451-2015, the load loss is more than 5% lower than the current national standard GB6451-2015, and the performance meets the energy efficiency standard of GB20052-2020.



Low Noise

The self cooling noise level will reach below 60dB, nearly 20dB lower than the national standard. If users have special requirements, they can also customize ultra-low noise transformers;



Low Partial Discharge

The company has introduced modern enterprise management mode. The whole process of 110kV products will be dust-free operation, all metal parts and insulating parts inside the body will be rounded, and the local discharge capacity will be controlled below 100pc;



Strong Short Circuit Resistance

110kV transformer has passed national certification. Ensure that no product is damaged due to sudden short circuit, with strong reliability;



Beautiful Appearance

Full polishing and derusting, powder electric spraying paint can achieve the spraying effect of household appliances, wide chip radiator, never leg color.



No Leakage

All seals are made of acrylate material and adopt one-time molding technology. There is no interface. We solemnly promise that there will be no leakage. Fluorescence, positive pressure and negative pressure are used for leakage test.

Service Conditions

It is conducive to peak summer. It is applicable to the main power grid with high load rate under high temperature and places with impact load and continuous overload requirements. Such as iron and steel, metallurgical industry, railway transportation, power plant, hydropower station, etc.

Product Introduction

Main structural features

NOMEX Insulation + Transformer Insulation Oil

1. High Temperature Resistant and Safer

When the ambient temperature is 40 $^{\circ}$ C, it can operate continuously under 100% load for a long time.

At the same temperature, the continuous load rate is 20% higher than that of oil immersed transformer.

Ambient Temperature(°C)	-10	0	10	20	30	40
\$13(K24)	1.25	1.17	1.09	1.00	0.91	0.81
SRN(K24)	1.37	1.3	1.25	1.18	1.10	1.00

2. Low loss and energy saving

20% energy saving compared with ordinary oil immersed transformer

3. Maintenance free and more environmentally friendly

The seal has the same service life as the transformer All materials can be recycled

Technological innovation

- 1 High temperature resistant hybrid insulation system;
- 2 Compact structure design;
- 3 Seven step temperature control technology to ensure operation safety;
- 4 30-year life pan design;
- The iron core adopts a fully inclined 45 degree 7-step joint structure.



Original Core Technology

High temperature resistant hybrid insulation system



The hot spot temperature distribution of the coil is determined by using the temperature field analysis software, and the insulation materials with different temperature resistance grades are reasonably selected, so that the components of the overall insulation system of the transformer can reach the same service life, and the design service life of the product is more than 30 years.

7-step Temperature Control Technology

The mature structure and technology of traditional transformer shall be adopted as far as possible in the structure of high-temperature liquid immersed transformer, which retains the advantages of reliability, good manufacturability and economy of the traditional transformer. The biggest difference between this transformer and the traditional transformer is that the actual situation of the temperature field in the transformer is reasonably considered in the design, and the insulation materials with different temperature resistance grades are reasonably used according to the temperature distribution to form a hybrid insulation system. With the help of transformer temperature field simulation technology, the temperature distribution of the transformer (mainly winding and its vicinity) can be determined more accurately. According to different temperature ranges, different grades of insulating materials can be selected to give full play to the high-temperature resistance characteristics of materials, and at the same time, it has a good economy. The actual maximum oil temperature of this liquid immersed transformer is set at 95 $^{\circ}$ C, which ensures that the transformer has good safety, thermal performance margin and long expected life. For the temperature design of the whole transformer, we propose and implement the concept of "seven-step temperature control technology" as the design principle, that is, gradually extend from the vicinity of the winding hot spot with the highest temperature to the external low-temperature area and divide it into five levels, and consider the short circuit and overload to form a seven-level thermal state for temperature control:

- (1) Insulation material temperature control technology: different insulation materials shall be selected according to the temperature of different parts of the winding and body. The control winding hot spot temperature.
- (2) Temperature control technology of liquid flow circuit: it is a technology to determine and control the liquid flow temperature of each part by comprehensively considering the relationship between liquid velocity field and temperature field. Control the boundary layer liquid temperature and top layer liquid temperature near the hot spot of the winding.
- (3) Overload temperature control technology: temperature rise control of various parts of the transformer under overload state. The temperature distribution under overload conditions is different from that underrated load operation. Attention should be paid to the temperature rise change under overload conditions in design.
- (4) Iron core temperature control technology: temperature control of insulating parts in contact with iron core.

- (5) Sealed temperature control technology: the thermal expansion, deformation, strength, etc. of the fully sealed oil tank, the influence and control with the change of temperature, so as to ensure the normal operation of the transformer within its allowable temperature range.
- (6) Component temperature control technology: components shall be made of insulation materials of the corresponding grade according to the temperature of their location, such as sealing gasket, etc.
- (7) Short circuit temperature control technology: in case of transformer fault short circuit, the value of short-circuit current flowing through the winding is very large, but the time is very short. It is usually calculated according to the adiabatic process. Under the condition of multiple short-circuit reclosing, the heat accumulation and heat dissipation effect shall be considered. Generally speaking, due to Nomex ® The paper has good high-temperature resistance, mechanical strength, and the change of dielectric coefficient and dielectric loss with temperature is very small. Even under the condition of multiple short-circuit reclosing, it will not cause mechanical damage and electrical failure due to temperature rise, and will not lose the service life of insulating materials.

Measures for anti sudden short circuit capacity of 110kV oil immersed power transformer

Improving the ability of 110kV power transformer against sudden short circuit is mainly guaranteed from two aspects: design calculation and manufacturing process.

- 1. In terms of design, there are the following points:
- (1) Reasonable ampere turn balance calculation of transformer coil can effectively control the maximum unbalanced ampere turn and reduce the short-circuit mechanical force to the greatest extent.
- (2) Mechanical stress belongs to the tolerance test. Copper conductor is a plastic material. When the deformation of copper wire is less than 0.2% after the transformer short circuit, the winding can recover deformation. Soft copper wire shall be selected according to the maximum short-circuit mechanical force borne by the transformer (Σ 0.2 = 90Mpa) or semi-rigid copper wire (Σ 0.2 = 120 ~ 260mpa) so that the average critical stress of copper wire Σ 0.2 within the reasonable safety range.
- (3) The strength and stiffness of clamp, pull plate, selected pressing plate and pressing device shall be calculated to meet the safety requirements of maximum short-circuit mechanical force. (4) The winding cushion block shall be densified and made of hard cardboard with large elastic modulus as far as possible.
- 2. In terms of the manufacturing process, there are the following points:
- (1) The transformer body shall be reasonably controlled in three aspects: first, the coil shall be wound tightly, second, the body shall be sleeved tightly, and third, the body shall be compressed.
- (2) The designed ampere turn balance shall be calculated with the ampere turn balance after manufacturing and processing, and the maximum unbalanced ampere turn shall be strictly controlled.
- (3) Prestress shall be added during the manufacturing process to prevent looseness during the operation of the transformer, so as to increase the short-circuit mechanical force of the transformer
- (4) The height tolerance of in-phase winding after drying treatment shall be strictly controlled so that each winding can be pressed evenly.

Guarantee measures for low partial discharge of 110kV oil immersed power transformer

The generation of transformer partial discharge mainly depends on the design process assurance and process control. We change the traditional concept, use the viewpoint of "field strength" instead of "voltage" to determine the insulation parameters and insulation structure, select more appropriate insulation materials and adopt advanced production technology to ensure the low partial discharge of the transformer.

- 1. Design: study the mechanism and external performance of partial discharge, make a targeted adjustment, and invite experts in the industry to demonstrate and discuss, so as to fundamentally solve the causes of partial discharge;
- (1) Accurately calculate the field strength distribution and reasonably adjust it to make it evenly distributed, reduce the electric field distortion, and ensure that the maximum field strength of the component with the most concentrated electric field is lower than the initial discharge field strength; (2) Reasonably design the high-voltage outlet components, fillet treatment of internal structural parts of the body, reasonably design and distribute the lead components for low partial discharge, and reasonably adjust the ground distance parameters;
- 2. Process assurance:
- (1) Purified production environment (main components such as iron core, coil, body and assembly are completed in the fully sealed and painted workshop, and the personnel in and out of the workshop can enter the workshop only after changing shoes or wearing shoes covers).
- (2) The body and lead are made in a fully enclosed plant.
- (3) Round the outside of all iron clamps as a whole
- (4) Rounding of the inner cavity of the transformer oil tank
- (5) When inserting the iron yoke on the iron core of the transformer, wrap the coil on the core column with a clean cloth, and then insert the iron yoke to prevent trace metal particles generated in the cutting process on the upper iron yoke from falling into the coil.
- (6) Special improvements are made to the track crane: a box is installed at a proper position under the wheel of the crane to absorb the metal particles generated by the friction between the wheel and the track during the operation of the crane.





WORKSHOP

Main Equipments



Vertical Winding Machine



Vacuum Drying Equipment



Horizontal Winding Machine



Air Cushion Car

Utility model patent and invention patent

- 1. Hoisting structure of 110kV transformer body: ZL2008 2 0238182.6;
- 2. Outgoing line structure of 110kV plug-in cable terminal transformer body: Z L2008 2 0159647.9;
- 3. On load voltage regulation structure of 110kV power transformer: ZL2010 2 9044115.5;
- 4. Current transformer structure for transformer winding temperature measurement: ZL2010 2 9044111.7;
- 5. Magnetic shielding structure of large capacity transformer: ZL2010 2 0635851.0.

The above utility model patents and invention patents have played a significant role in promoting and promoting the quality control and product performance improvement of CEEG's $110kV \sim 220kV$ products, and laid a solid foundation for the product innovation and development of CEEG.



Technical Advantages

R & D Team

CEEG has established a strong technology R & D team, with technology R & amp; D platforms such as postdoctoral workstation, Jiangsu power transformation equipment engineering technology research center, Jiangsu graduate workstation and Jiangsu technology center, in conjunction with the Institute of electrical engineering, Chinese Academy of Sciences, Southeast University, Nanjing University of Aeronautics and Astronautics, Jiangsu University China University of mining and technology and other well-known scientific research institutions and universities jointly carry out a series of technological R & D and innovation.










R & D Cloud Platform

It integrates the functions of electromagnetic optimization design, parametric drawing, performance analysis, structural optimization and automatic drawing of transformer, so as to realize the sharing of transformer design resources, search, modification and version control of various data information.



Intelligent Operation and Maintenance Platform

Online power quality analysis and fault alarm can be realized by collecting key data such as transformer temperature, current, voltage, vibration and grid harmonic, and can be installed on mobile phone.









Technical Parameter

\$18-6300 -180000/110kV oil-immersed three-phase double winding non-excitation voltage regulating power transformer (Class III energy efficiency)

		J 1		•		27 71		
Rated Capacity	Voltage co	mbination and t	apping range	Vector	P0 kW	PK kW (75°C)	10 %	UK%
kVA	HV kV	HV Tapping	LVkV	Group	1000	1 KKW (75C)	10 70	OK 70
6300					5.90	33	0.62	
8000					7.10	40	0.62	
10000					8.40	48	0.58	
12500					9.90	56	0.58	
16000			6.3		12.00	69	0.54	
20000			6.6		14.10	84	0.54	10.5
25000	110		10.5		16.60	99	0.50	
31500	115	±2×2.5%		YNd11	19.70	117	0.48	
40000	121				23.50	141	0.45	
50000	121				28.20	166	0.42	
63000					33.30	198	0.38	
75000					37.80	224	0.33	
90000			13.8		43.50	258	0.30	
120000			15.75		54.20	320	0.27	12~14
150000			18		64.10	379	0.24	
180000			21		72.00	434	0.20	

S20-6300-180000 / 110kV oil immersed three-phase double winding non excitation voltage regulating power transformer (Class II energy efficiency)

	_	<i>J</i> 1		•		37		
Rated Capacity	Voltage con	nbination and ta	apping range	Vector	P0 kW	PK kW (75°C)	10 %	UK %
kVA	HV kV	HV Tapping	LVkV	Group	I U KVV	1 K K W (7 3 C)	10 70	OK 70
6300					4.80	32	0.62	
8000					5.80	38	0.62	
10000					6.80	45	0.58	
12500			6.3		8.10	53	0.58	
16000					9.80	65.7	0.54	
20000					11.40	79	0.54	10.5
25000	110		10.5	YNd11	13.50	94	0.50	
31500	115	±2×2.5%			16.00	111	0.48	
40000	121				19.10	133	0.45	
50000					22.90	158	0.42	
63000					27.00	187	0.38	
75000			13.8		30.70	212	0.33	
90000]				35.40	245	0.30	
120000			15.75		44.10	303	0.27	12~14
150000	1		18		52.10	359	0.24	
180000			21		58.50	411	0.20	



S22-6300 -180000/110kV oil-immersed three-phase double winding non- excitation voltage regulating power transformer (class I energy efficiency)

Rated Capacity	Voltage con	nbination and ta	pping range	Vector	P0 kW	PK kW (75°C)	10 %	UK %
kVA	HVkV	HV Tapping	LVkV	Group	I U KVV	1 K K W (7 3 C)	10 70	OK 70
6300					4.10	32	0.62	
8000					4.90	38	0.62	
10000					5.80	45	0.58	
12500					6.80	53	0.58	
16000			6.3 6.6		8.30	65.7	0.54	
20000					9.70	79	0.54	10.5
25000	110		10.5		11.40	94	0.50	
31500	110	±2×2.5%		YNd11	13.50	111	0.48	
40000	115	±2^2.J70		marr	16.20	133	0.45	
50000	121				19.40	158	0.42	
63000					22.90	187	0.38	
75000					26.00	212	0.33	
90000			13.8		29.90	245	0.30	
120000			15.75		37.30	303	0.27	12 - 14
150000			18		44.10	359	0.24	
180000			21		49.50	411	0.20	

\$18-6300-63000/110kV/35kV oil-immersed three-phase double winding non-excitation voltage regulating power transformer (Class III energy efficiency)

Rated Capacity	Voltage con	nbination and ta	pping range	Vector	P0 kW	PK kW (75°C)	10 %	UK %
kVA	HV kV	HV Tapping	LV kV	Group	TURW	1 K K W [73 C]	10 70	OK 70
6300					6.40	35	0.62	
8000					7.70	42	0.62	
10000					9.00	49	0.58	
12500			35		10.50	59	0.58	
16000	110		35 36		12.50	72	0.54	
20000	115	±2×2.5%	37	YNd11	14.80	89	0.54	10.5
25000	121		38.5		17.50	105	0.50	
31500			30.3		20.70	126	0.48	
40000					24.60	147	0.45	
50000					29.50	183	0.42	
63000					34.90	220	0.38	

Technical Parameter

S20-6300-63000/110kV/35kV oil-immersed three-phase double winding non-excitation voltage regulating power transformer (Class II energy efficiency)

Rated Capacity	Voltage con	nbination and ta	pping range	Vector	DO IAVA	DV 13 V / /7E°C)	10 %	UK%
kVA	HV kV	HV Tapping	LVkV	Group	P0 kW	PK kW (75°C)	10 90	OK 90
6300					5.20	33	0.62	
8000					6.20	40	0.62	
10000					7.30	47	0.58	
12500			25		8.50	56	0.58	
16000	110		35	YNdll	10.10	68	0.54	
20000	115	±2×2.5%	36		12.00	85	0.54	10.5
25000	121		37		14.20	99	0.50	
31500			38.5		16.80	120	0.48	
40000					20.00	140	0.45	
50000					24.00	174	0.42	
63000					28.30	209	0.38	

S22-6300-63000/110kV/35kV oil-immersed three-phase double winding non-excitation voltage regulating power transformer (Class I energy efficiency)

Rated Capacity	Voltage con	nbination and ta	pping range	Vector	P0 kW	PK kW (75°C)	10 %	UK%
kVA	HV kV	HV Tapping	LV kV	Group	I O KVV	1 K K W (7 3 C)	10 70	OK 70
6300					4.40	33	0.62	
8000					5.30	40	0.62	
10000					6.20	47	0.58	
12500					7.20	56	0.58	
16000	110		35		8.60	68	0.54	
20000	115	±2×2.5%	36	YNd11	10.20	85	0.54	10.5
25000	121		37		12.10	99	0.50	
31500			38.5		14.30	120	0.48	
40000					16.90	140	0.45	
50000					20.30	174	0.42	
63000					24.00	209	0.38	



SS18-6300-63000/110kV oil-immersed three-phase three winding non-excitation voltage regulating power transformer (Class III energy efficiency)

					•	22	<i>J</i> 1			
Rated	Voltage	combinati	on and tap	oping range	Vector	DO LLY/	DI/ INV/ /ZESCI	10.0/	Uk	: %
Capacity kVA	HV kV	Tapping Range	MV kV	LV kV	Group	P0 kW	PK kW (75°C)	IO %	Step-up	Step-down
6300						7.10	42	0.66		
8000						8.50	50	0.62	HV-MV	HV-MV 10.5
10000						10.10	59	0.59	17.5~18.5	HV-LV
12500				6.3		11.80	70	0.56	HV-LV 10.5	17.5~18.5
16000	110		36	6.6		14.30	86	0.53	MV-LV 6.5	MV-LV 6.5
20000	115	±2×2.5%	37	10.5	YNyn0d11	16.90	101	0.54		
25000	121		38.5	21		19.70	120	0.48		
31500				21		23.50	142	0.48	HV-MV	HV-MV 10.5
40000						27.80	170	0.44	17.5~18.5	HV-LV
50000						33.30	202	0.42	HV-LV 10.5	17.5~18.5
63000						39.40	243	0.40	MV-LV 6.5	MV-LV 6.5

SS20-6300-63000/110kV oil-immersed three-phase three winding non-excitation voltage regulating power transformer (Class II energy efficiency)

Rated	Voltage	combinati	on and tap	oping range	Vector				U	< %
Capacity kVA	HV kV	Tapping Range	MV kV	LV kV	Group	P0 kW	PK kW (75°C)	IO %	Step-up	Step-down
6300						5.80	40	0.66		
8000						6.90	48	0.62	HV-MV	HV-MV 10.5
10000						8.20	56	0.59	17.5~18.5	HV-LV
12500				6.3		9.60	67	0.56	HV-LV 10.5	17.5~18.5
16000	110		36	6.6		11.60	81	0.53	MV-LV 6.5	MV-LV 6.5
20000	115	±2×2.5%	37	10.5	YNyn0d11	13.70	95	0.54		
25000	121		38.5	71		16.00	113	0.48		
31500				Ζ1		19.10	134	0.48	HV-MV	HV-MV 10.5
40000						22.60	161	0.44	17.5~18.5	HV-LV
50000						27.00	192	0.42	HV-LV 10.5	17.5~18.5
63000						32.00	230	0.40	MV-LV 6.5	MV-LV 6.5

Technical Parameter

SS22-6300-63000/110kV oil-immersed three-phase three winding non-excitation voltage regulating power transformer (Class I energy efficiency)

	9-1				1		<i>J</i> 1			
Rated	Voltage	e combinati	on and tap	oping range	Vector	50 1177	DICLUY (750C)	10.07	Uk	: %
Capacity kVA	HV kV	Tapping Range	MV kV	LVkV	Group	P0 kW	PK kW (75°C)	10 %	Step-up	Step-down
6300						4.90	40	0.66		
8000						5.80	48	0.62	HV-MV	HV-MV 10.5
10000						6.90	56	0.59	17.5~18.5	HV-LV
12500				6.3		8.10	67	0.56	HV-LV 10.5	17.5~18.5
16000	110		36	6.6		9.80	81	0.53	MV-LV 6.5	MV-LV 6.5
20000	115	±2×2.5%	37	10.5	YNyn0d11	11.60	95	0.54		
25000	121		38.5	21		13.50	113	0.48		
31500				21		16.20	134	0.48	HV-MV	HV-MV 10.5
40000						19.10	161	0.44	17.5~18.5	HV-LV
50000						22.90	192	0.42	HV-LV 10.5	17.5~18.5
63000						27.10	230	0.40	MV-LV 6.5	MV-LV 6.5

SZ18-6300-63000-110kV oil-immersed three-phase double winding on load voltage regulating power transformer (Class III energy efficiency)

Rated Capacity	Voltage con	nbination and ta	pping range	Vector	P0 kW	PK kW (75°C)	10 %	UK %
kVA	HVkV	HV Tapping	LV kV	Group	10 KVV	1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	10 70	OK 70
6300					6.40	33	0.64	
8000					7.70	40	0.64	
10000					9.00	48	0.59	
12500			6.3		10.70	56	0.59	
16000		0 1 250/	6.6		12.90	69	0.55	10.5
20000	110	±8×1.25%	10.5	YNd11	15.40	84	0.55	10.5
25000			21		18.20	99	0.51	
31500					21.60	117	0.51	
40000					25.80	148	0.46	
50000					30.60	184	0.46	
63000					36.30	220	0.42	



SZ20-6300 - 63000 / 110kV oil-immersed three-phase double winding on load voltage regulating power transformer (Class II efficiency)

Rated Capacity	Voltage con		pping range	Vector	P0 kW	PK kW (75°C)	10 %	UK %
kVA	HV kV	HV Tapping	LV kV	Group	1000	1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	10 70	OK 70
6300					5.20	32	0.64	
8000					6.20	38	0.64	
10000					7.30	45	0.59	
12500			6.3		8.70	53	0.59	
16000	110	±8×1.25%	6.6	YNd11	10.50	66	0.55	
20000	110	10^1.2370	10.5	IIIQII	12.50	79	0.55	10.5
25000			21		14.80	94	0.51	
31500					17.60	111	0.51	
40000					21.00	140	0.46	
50000					24.80	175	0.46	
63000					29.50	209	0.42	

SZ22-6300 - 63000 / 110kV oil immersed three-phase double winding on load voltage regulating power transformer (Class I energy efficiency)

Rated Capacity	Voltage con	nbination and ta _l	pping range	Vector	P0 kW	PK kW (75°C)	IO %	UK %	
kVA	HV kV	HV kV Tapping		Group	1000	1 KKW (73C)	10 70	OK 70	
6300					4.40	32	0.64		
8000					5.30	38	0.64		
10000					6.20	45	0.59		
12500			6.3		7.40	53	0.59		
16000	1.10	.0.1350/	6.6	VA 1 11 1	8.90	66	0.55		
20000	110	±8×1.25%	10.5	YNd11	10.60	79	0.55	10.5	
25000			21		12.50	94	0.51		
31500					14.90	111	0.51		
40000					17.80	140	0.46		
50000					21.00	175	0.46		
63000					25.00	209	0.42		

Technical Parameter

SSZ18-6300 - 63000 / 110kV oil-immersed three-phase three winding on load voltage regulating power transformer (Class III energy efficiency)

Rated	Voltage	combinati	on and tap	oping range	Vector				Ul	<%
Capacity kVA	HVkV	Tapping Range	MV kV	LV kV	Group	P0 kW	PK kW (75°C)	10 %	Step-up	Step-down
6300						7.70	42	0.76		
8000						9.20	50	0.76		
10000						10.90	59	0.71		
12500						12.90	70	0.71	HV-N	1 ∨ 10.5
16000	110	±8×	36	6.3		15.40	86	0.67	H	V-LV
20000	115		37	6.6	YNyn0d11	18.20	101	0.67	18~19 MV-LV 6.5	3~19
25000	121	1.25%	38.5	10.5		21.60	120	0.62		LV 6.5
31500				21		25.70	142	0.62		
40000						30.80	170	0.58		
50000						36.40	202	0.58		
63000						43.30	243	0.53		

SSZ20-6300 - 63000 / 110kV oil immersed three-phase three winding on load voltage regulating power transformer (Class II efficiency)

Rated	Voltage	/oltage combination and tapping rang			Vector	DO 111/4	DV 1.7 V (7 E9C)	10.07	Uk	. %
Capacity kVA	HVkV	Tapping Range	MVkV	LV kV	Group	P0 kW	PK kW (75°C)	10 %	Step-up	Step-down
6300						6.20	40	0.76		
8000						7.50	48	0.76		
10000						8.80	56	0.71		
12500				6.3		10.50	67	0.71		
16000	110	±8×	36			12.50	81	0.67	HV-N	1V 10.5
20000	115	1.25%	37	6.6 10.5	YNyn0d11	14.80	95	0.67	H	V-LV
25000	121	1.2370	38.5	21		17.60	113	0.62	1.8	3~19
31500				21		20.90	134	0.62	MV-I	_V 6.5
40000						25.00	161	0.58		
50000						29.60	192	0.58		
63000						35.20	230	0.53		



SSZ22-6300 - 63000 / 110kV oil-immersed three-phase three winding on load voltage regulating power transformer (Class I energy efficiency)

Rated	Voltage	combinatio	on and tap	ping range	Vector	DO LAY!	DK IA V / (7 E°C)	100/	Uk	: %
Capacity kVA	HV kV	Tapping Range	MVkV	LV kV	Group	P0 kW	kW PK kW (75°C) 10%		Step-up	Step-down
6300						5.30	40	0.76		
8000						6.30	48	0.76		
10000						7.50	56	0.71		
12500						8.90	67	0.71	HV-M	V 10.5
16000	110	±8×	36	6.3		10.60	81	0.67	HV	-LV
20000	115	1.25%	37	6.6 10.5	YNyn0d11	12.50	95	0.67	18-	~19
25000	121	1.25%	38.5	21		14.90	113	0.62	MV-L'	V 6.5
31500				Z I		17.70	134	0.62		
40000						21.20	161	0.58		
50000						25.00	192	0.58		
63000						29.80	230	0.53		

SS11-6300 - 90000 / 110kV oil-immersed three winding non-excitation voltage regulating power transformer

POW	Jowel Hallstoffiel											
Rated	Voltage com	nbination and ta	pping range	Vector				Uk	: %			
Capacity kVA	HV kV	MV kV	LV kV	Group	P0 kW	PK kW (75°C)	10%	Step-up	Step-down			
6300					9.0	45	0.75					
8000					10.8	53	0.71					
10000					12.7	62	0.68					
12500					15	73	0.64	HV-MV	HV-MV			
16000	110±2×		6.3		18	90	0.6	17~18	10.5			
20000	2.5%	35	6.6	V/N b == 0 -1 1 1	21.3	106	0.56	HV-LV	HV-LV			
25000	121±2×	38.5	10.5	YNyn0d11	25.2	125	0.53	10.5	17~18			
31500	2.5%		11		30	148	0.49	MV-LV	MV-LV			
40000					35.8	178	0.41	6.5	6.5			
50000					42.3	212	0.38					
63000	Ī				50.2	255	0.38					
90000					65.6	333	0.3					

- 1. The capacity distribution of high, medium and low voltage windings is (100 / 100 / 100)%;
- 2. The connection group label can be YNd11y10 as required;
- 3. According to the needs of users, the voltage value or tap different from that in the table can be selected for medium voltage;
- 4. The maximum current tap is 5% tap position.

Technical Parameter

$\rm SSZ11\text{-}6300$ - $90000\,/\,110kV$ oil-immersed three winding on load voltage regulating power transformer

Rated	Voltage con	nbination and t	apping range	Vector	DO LLV/	DV 1.) V / /7 E9C)	1007	1.11.07
Capacity kVA	HV kV	MVkV	LV kV	Group	P0 kW	PK kW (75°C)	10%	Uk %
6300					9.7	45	0.89	
8000					11.7	53	0.89	
10000					13.8	62	0.84	
12500					15.9	73	0.84	HV-MV
16000			6.3		19.7	90	0.79	10.5
20000	110±8×	35	6.6	YNyn0d11	23.3	106	0.79	HV-LV
25000	1.25%	38.5	10.5	TNYTIOUTT	27.5	125	0.74	17~18
31500			11		32.7	148	0.74	MV-LV
40000					39.2	178	0.68	6.5
50000					46.4	212	0.68	
63000					55.2	255	0.63	
90000					72.1	333	0.48	

- 1. On load voltage regulating transformer, temporarily provide step-down structure products; 2. The capacity distribution of high, medium and low voltage windings is (100 / 100 / 100)%;
- 3. The connection group label can be YNd11y10 as required; 4. The maximum current tapping is 10% tapping position;
- 5. According to the needs of users, the voltage value or tap different from that in the table can be selected for medium voltage.

S11-6300 - 90000 / 110kV oil-immersed double winding non-excitation voltage regulating power transformér

Rated	Voltage comb	oination and ta	pping range	Vector	PO kW	PK kW (75°C)	10 %	Uk%
Rated Capacity KVA	HV kV	HV Tapping	LVkV	Group	10 KVV	1 K K W (7 3 C)	10 70	OK70
6300					7.5	34	0.68	
8000					9	42	0.64	
10000					10.5	50	0.6	
12500					12.3	59	0.56	
16000			6.3		15	73	0.53	
20000	110	±2×2.5%	6.6	YNd11	17.7	88	0.49	10.5
25000	121		10.5	INGII	21	104	0.45	10.5
31500			11		24.9	125	0.41	
40000					29.8	147	0.38	
50000					35.2	183	0.34	
63000					41.8	221	0.3	
90000					54.6	289	0.3	

1. The maximum current tap is - 5%



\$11-6300 - 90000/110kV oil-immersed double winding low voltage 35kV non-excitation voltage regulating power transformer

Rated	Voltage comb	oination and ta	apping range	Vector	PO kW	PK kW (75°C)	10 %	Uk%			
Rated Capacity KVA	HVkV	HV Tapping	LVkV	Group	10.00	1 K K W (7 3 C)	10 70	OK/0			
6300					8.1	37	0.79				
8000					9.7	45	0.79				
10000					11.4	52	0.74				
12500					13.3	62	0.74				
16000					15.9	77	0.68				
20000	110	±2×2.5%	35	YNd11	18.9	93	0.68	10.5			
25000	121	±Z^Z.5%0	38.5	INGII	22.2	109	0.63	10.5			
31500					26.2	132	0.63				
40000					31.2	155	0.58				
50000					36.6	192	0.58				
63000					43.3	232	0.53				
90000					56.6	303	0.41				

Note:

SZ11-6300 - 90000/110kV oil-immersed double winding on load voltage regulating power transformer

powe	power transformer											
Rated	Voltage com	nbination and ta	apping range	Vector	PO kW	PK kW (75°C)	10 %	Uk%				
Rated Capacity KVA	HVkV	HV Tapping	LV kV	Group	TURW	1 K K W (7 3 C)	10 70	ON70				
6300					8.1	34	0.74					
8000					9.7	42	0.74					
10000					11.7	50	0.68					
12500					13.6	59	0.68					
16000			6.3		16.5	73	0.63					
20000	110	±8×21.25%	6.6	YNd11	19.5	88	0.63	10.5				
25000	110	E6^Z1.Z3%	10.5	TINGTT	22.7	104	0.58	10.5				
31500			11		27.4	125	0.58					
40000					32.9	148	0.53					
50000					38.9	183	0.53					
63000	Ī				46.3	221	0.47					
90000					60.5	289	0.36					

- 1. On load voltage regulating transformer, temporarily provide step-down structure products;
- 2. Negotiate with the manufacturer according to the user department; Products that can provide other voltage combinations;
- 3. The maximum current tap is 10% tap position.

SS13-6300 - 90000/110kV oil-immersed three winding non excitation voltage regulating power transformer

Rated	Voltage.com	nbination and ta	apping range	Vector	DO LIVY	DI/ I.V./ /75°C	1007	UI	<%
Capacity kVA	HV kV	MV kV	LVkV	Group	P0 kW	PK kW (75°C)	10%	Step-up	Step-down
6300					7.2	45	0.75		
8000					8.6	53	0.71		
10000					10.2	62	0.68		
12500					12	73	0.64	HV-MV	HV-MV
16000	110±2×		6.3		14.4	90	0.6	17~18	10.5
20000	2.5%	35	6.6	YNyn0d11	17	106	0.56	HV-LV	HV-LV
25000	121±2×	38.5	10.5	TINYTIOGTT	20.2	125	0.53	10.5	17~18
31500	2.5%		11		24	148	0.49	MV-LV	MV-LV
40000					28.6	178	0.41	6.5	6.5
50000				·	33.8	212	0.38		
63000					40.2	255	0.38		
90000					52.5	333	0.3		

Note:

- 1. The capacity distribution of high, medium and low voltage windings is (100 / 100 / 100)%;
- 2. The connection group label can be YNd11y10 as required;
- 3. According to the needs of users, the voltage value or tap different from that in the table can be selected for medium voltage;
- 4. The maximum current tap is 5% tap position.

SSZ13-6300 - 90000/110kV oil-immersed three winding on load voltage regulating power transformer

POVVC	ower dansformer												
Rated	Voltage.com	nbination and ta	apping range	Vector	PO kW	DK 14 V / /7 C°C)	100/	Uk %					
Capacity kVA	HV kV	MV kV	LV kV	Group	PUKW	PK kW (75°C)	10%	UK 90					
6300					7.8	45	0.89						
8000					9.4	53	0.89						
10000					11	62	0.84						
12500					12.7	73	0.84	HV-MV					
16000			6.3		15.8	90	0.79	10.5					
20000	110±8×	35	6.6	YNyn0d11	18.6	106	0.79	HV-LV					
25000	1.25%	38.5	10.5	TINYTIOGTT	22	125	0.74	17~18					
31500			11		26.2	148	0.74	MV-LV					
40000					31.4	178	0.68	6.5					
50000					37.1	212	0.68						
63000					44.2	255	0.63						
90000					57.7	333	0.48						

- 1. On load voltage regulating transformer, temporarily provide step-down structure products;
- 2. The capacity distribution of high, medium and low voltage windings is (100 / 100 / 100)%;
- 3. The connection group label can be YNd11y10 as required;
- 4. The maximum current tapping is 10% tapping position;
 5. According to the needs of users, the voltage value or tap different from that in the table can be selected for medium voltage.

19/20

^{1.} The maximum current tap is - 5% tap position.



\$13-6300 - 90000 / 110kV oil-immersed double winding non excitation voltage regulating power transformer

Rated	Voltage comb	bination and ta	apping range	Vector	PO kW	PK kW (75°C)	10 %	Uk%
Rated Capacity KVA	HV kV	HV Tapping	LVkV	Group	10 KVV	1 K K W (7 5 C)	10 70	ON70
6300					5.92	34	0.68	
8000					7.2	42	0.64	
10000					8.4	50	0.6	
12500					9.8	59	0.56	
16000			6.3		12	73	0.53	
20000	110	±2×2.5%	6.6	YNd11	14.2	88	0.49	10.5
25000	121	±2^2.5%	10.5	TINGTT	16.8	104	0.45	10.5
31500			11		19.9	125	0.41	
40000					23.8	147	0.38	
50000					28.2	183	0.34	
63000					33.4	221	0.3	
90000					43.7	289	0.3	

Note: 1. The maximum current tapping is - 5%.

\$13-6300 - 90000 / 110kV/35kV oil-immersed double winding non excitation voltage regulating power transformer

regulating power transformer								
Voltage comb				PO WX/	PK WX/175°C1	10 %	Uk%	
HV kV	HV Tapping	LV kV	Group	10.00	1 K K W (7 3 C)	10 70	OK/U	
				6.5	37	0.79		
		35		7.8	45	0.79		
				9.1	52	0.74		
			YNd11	10.6	62	0.74		
				12.7	77	0.68		
110	±2×2 E06			15.1	93	0.68	10.5	
121	±2^2.J%0	38.5		17.8	109	0.63		
				21	132	0.63		
				25	155	0.58		
				29.3	192	0.58		
1				34.6	232	0.53		
1				45.3	303	0.41		
	Voltage comb	Voltage combination and ta HV kV Tapping 110 ±2×2.5%	Voltage combination and tapping range HV kV Tapping LV kV 110 ±2×2.5%	Voltage combination and tapping range HV kV Tapping LV kV Group 110 ±2×2.5% YNd11	Voltage combination and tapping range Vector Group P0 kW HV kV Tapping LV kV 6.5 7.8 9.1 10.6 12.7 15.1 15.1 17.8 21 25 29.3 34.6 34.6	Voltage combination and tapping range Vector Group P0 kW PK kW (75°C) HV kV Tapping LV kV 6.5 37 7.8 45 9.1 52 10.6 62 12.7 77 15.1 93 17.8 109 21 132 25 155 29.3 192 34.6 232	Voltage combination and tapping range HV kV Tapping LV kV 6.5 37 0.79 7.8 45 0.79 9.1 52 0.74 10.6 62 0.74 12.7 77 0.68 15.1 93 0.68 17.8 109 0.63 21 132 0.63 25 155 0.58 29.3 192 0.58 34.6 232 0.53	

Note: 1. The maximum current tapping position is - 5%.

Technical Parameter

SZ13-6300 - 90000 / 110kV oil-immersed double winding on load voltage regulating power transformer

Rated	Voltage com	bination and ta	apping range	Vector	PO kW	PK kW (75°C)	10 %	Uk%
Rated Capacity KVA	HVkV	HV Tapping	LV kV	Group	10.00	1 K K V (7 3 C)	10 70	OK/0
6300					6.5	34	0.74	
8000					7.8	42	0.74	
10000					9.4	50	0.68	
12500				YNd11	10.9	59	0.68	
16000			6.3 6.6 10.5		13.2	73	0.63	
20000	110	±8×1.25%			15.6	88	0.63	10.5
25000	1110	10.41.2570			18.2	104	0.58	10.5
31500					21.9	125	0.58	
40000					26.3	148	0.53	
50000					31.1	183	0.53	
63000					37	221	0.47	•
90000					48.4	289	0.36	

Note:

- On load voltage regulating transformer, temporarily provide step-down structure products;
 Negotiate with the manufacturer according to the user department; Products that can provide other voltage combinations;
 3. The maximum current tap is - 10% tap position.

\$18-3150 - 63000 / 66kV oil-immersed three-phase double winding non excitation voltage regulating power transformer (Class III energy efficiency)

Rated	Voltage con	nbination and tap		Vector		33	10.07	
Capacity kVA	HV kV	HV Tapping	LVkV	Group	P0 kW	PK kW (75°C)	10 %	Uk%
3150					3.20	21.9	0.84	
4000					3.80	25.9	0.80	8.0
5000		±5%			4.60	29.2	0.68	
6300					5.80	32.5	0.60	
8000			6.3	YNd11	7.10	38.5	0.60	
10000	(3				8.40	45.4	0.56	
12500	63				9.90	54	0.56	
16000	66	±2×2.5%			12.00	66.3	0.52	
20000	69		10.5		14.10	80.4	0.52	9.0
25000	1				16.60	95	0.48	
31500	1				19.70	114	0.44	
40000				23.50	134	0.44	1	
50000	1				28.20	158.7	0.40	
63000	1				33.30	188.1	0.36	



S20-3150 - 63000 / 66kV oil-immersed three-phase double winding non-excitation voltage regulating power transformer (Class II energy efficiency)

1 2 1 1 2 1 3	- 5	.9 6 6 6 .		11101		9) =		
Rated	Voltage con	nbination and tap	ping range	Vector	P0 kW	PK kW (75°C)	10 %	Uk%
Capacity kVA	HVkV	HV Tapping	LVkV	Group	FUKW	FKKW (75 C)	10 90	OK90
3150					2.60	20.7	0.84	
4000					3.10	24.6	0.80	8.0
5000					3.70	27.6	0.68	
6300					4.70	30.8	0.60	
8000			6.3	YNd11	5.80	36.5	0.60	
10000		±5%			6.80	43	0.56	
12500	63				8.10	51.1	0.56	
16000	66	±2×2.5%			9.80	62.8	0.52	
20000	69		10.5		11.40	76.1	0.52	9.0
25000					13.50	90	0.48	-
31500					16.00	108	0.44	
40000				19.10	126.9	0.44		
50000					22.90	150.3	0.40	
63000					27.00	178.2	0.36	

S22-3150 - 63000 / 66kV oil-immersed three-phase double winding non-excitation voltage regulating power transformer (Class I energy efficiency)

Rated		mbination and tap		Vector				
Capacity kVA	HVkV	HV Tapping	LVkV	Group	P0 kW	PK kW (75°C)	IO %	Uk%
3150					2.20	20.7	0.84	
4000					2.60	24.6	0.80	8.0
5000		±5%			3.10	27.6	0.68	
6300					4.00	30.8	0.60	
8000			6.3 6.6 10.5	YNdII	4.90	36.5	0.60	9.0
10000	(3				5.80	43	0.56	
12500	63				6.80	51.1	0.56	
16000	66	±2×2.5%			8.30	62.8	0.52	
20000	69				9.70	76.1	0.52	
25000					11.40	90	0.48	
31500					13.50	108	0.44	
40000	1			,	16.20	126.9	0.44	
50000					19.40	150.3	0.40	
63000					22.90	178.2	0.36	

Technical Parameter

SZ18-6300 - 63000 / 66kV oil-immersed three-phase double winding on load voltage regulating power transformer (Class III energy efficiency)

Rated	Voltage con	Voltage combination and tapping range			PO kW	PK kW (75°C)	10 %	Uk%
Capacity kVA	HV kV	HV Tapping	LV kV	Group	1000	1 K K V (7 3 C)	10 70	OK70
6300					6.40	32.5	0.60	
8000					7.70	38.5	0.60	
10000					9.00	45.4	0.56	
12500					10.70	54	0.56	
16000	63		6.3		12.90	66.3	0.52	
20000	66	±8×1.25%	6.6	YNd11	15.40	80.4	0.52	9.0
25000	69		10.5		18.20	95	0.48	
31500					21.50	114	0.44	
40000					25.80	134	0.44	
50000					30.40	158.7	0.40	
63000					35.90	188.1	0.36	

SZ20-6300 - 63000 / 66kV oil immersed three-phase double winding on load voltage regulating power transformer (Class II energy efficiency)


Rated Capacity	Voltage con	Voltage combination and tapping range			P0 kW	PK kW (75°C)	10 %	Uk%
kVA	HV kV	HV Tapping	LV kV	Group	1000	1 K K V (7 3 C)	10 70	OK70
6300					5.20	30.8	0.60	
8000					6.20	36.5	0.60	
10000					7.30	43	0.56	
12500					8.70	51.1	0.56	
16000	63		6.3		10.50	62.8	0.52	
20000	66	±8×1.25%	6.6	YNd11	12.50	76.1	0.52	9.0
25000	69		10.5		14.80	90	0.48	
31500					17.50	108	0.44	
40000					20.90	126.9	0.44	
50000					24.70	150.3	0.40	
63000					29.20	178.2	0.36	



SZ22-6300 - 63000 / 66kV oil immersed three-phase double winding on load voltage regulating power transformer (Class I energy efficiency)

		J 1		1		JJ J I		
Rated Capacity	Voltage cor	Voltage combination and tapping range			PO kW	PK kW (75°C)	10 %	Uk%
kVA	HVkV	HV Tapping	LVkV	Group		11000 (750)	10 70	OK70
6300					4.40	30.8	0.60	
8000					5.30	36.5	0.60	
10000					6.20	43	0.56	
12500					7.40	51.1	0.56	
16000	63		6.3		8.90	62.8	0.52	
20000	66	±8×1.25%	6.6	YNd11	10.60	76.1	0.52	9.0
25000	69		10.5		12.50	90	0.48	
31500					14.80	108	0.44	
40000					17.70	126.9	0.44	
50000					20.90	150.3	0.40	
63000					24.70	178.2	0.36	

Qualification Certificate



TYPE TEST REPORT of 63000/110 TRANSFORMER

Qualification Certificate





ISO 19001

ISO 45001



ISO 14001

Product Family Product Family



































5. Marine Transformer



01	03

- 1. Amorphous Metal Transformer
- 4. 220kV Power Transformer
- 7. 110kV Power Transformer
- 2. VPI Transformer
- 5. 220kV Traction Transformer
- 8. 35kV Power Transformer
- 3. Cast Resin Transformer
- 6. 110kV Traction Transformer
- 9. 110kV Mobile Transformer

- 01 02 03 04 05 06
- 1. Mining Flame-proof Substation
- 4. Ocean Platform Transformer
- 7. Integrated PV Step-up Transformer 8. Substation
- 2. Rectifier Transformer 3. Harmonic Mitigating Transformer
 - 6. AFWF Transformer
 - 9. Substation

www.reinhausen.com	On-load tap-changer Coperating Instructions	OILTAP [®] R tap selector size	Ε
	I Us		
			MR

© All rights reserved, Maschinenfabrik Reinhausen

Unauthorized copying and distribution of this document and the utilization and communication of its con-tents are strictly prohibited unless expressly authorized.

Offenders will be held liable for the payment of damages. All rights reserved in the case of registration of a patent, utility model or registered design.

The product may have been modified after this document went to press.

We expressly reserve the right to make changes to the technical data, the design or the scope of delivery.

The information provided and the arrangements agreed during processing of the relevant quotations and orders are strictly binding.

The original operating instructions were drawn up in German.



1	General	5
1.1	Safety instructions	5
1.2	Appropriate use	6
2	Design/Types	7
3	Shipment	9
4	Installation of the on-load tap-changer for cover mounting	13
4.1	Mounting flange	13
4.2	Attaching the on-load tap-changer to the transformer cover	14
4.3	Assembly of the diverter switch oil compartment and tap selector	15
5	Installation of the on-load tap-changer into the bell-type tank	21
5.1	Assembly of the diverter switch oil compartment and tap selector, connecting tap selector connecting leads	21
5.2	Installation of the on-load tap-changer on the supporting structure	21
5.3	Preparation	22
5.4	Attaching the bell-type tank	26
6	Connection of the tap winding and on-load tap-changer take-off lead	31
6.1	Connection of the tap selector take-off leads	32
6.2	Parallel jumpers for R I 2002-E and R I 3003-E	34
6.3	Connection of on-load tap-changer take-off lead	34
7	Transformer ratio test	37
8	Drying process and oil filling	39
8.1	Drying process	39



8.1.1 8.1.2	Vacuum-drying Vapor-phase drying	
8.2	Filling with oil	. 42
9	Pipe connections	43
9.1	Pipe connection R for protective relay RS 2001	. 43
9.2	Pipe connection S for suction pipe	. 44
9.3	Pipe connection Q (special version, only needed with oil filter unit)	. 44
9.4	E2 connection	. 44
10	Mounting the motor-drive unit, bevel gear and drive shaft	45
10.1	Mounting the motor-drive unit (see appendix, dimension drawing 895660, 893381)	. 45
10.2	Mounting the bevel gear	. 45
10.3	Mounting the drive shaft (square tube)	. 46
11	Commissioning the on-load tap-changer at the transformer manufacturer's site	. 49
11.1	Tap change operation tests	. 49
11.2	Complete oil filling	. 49
11.3	Ground connections	. 51
11.4	Electrical tests on the transformer	. 51
12	Transportation to the operating site	53
13	Commissioning at the operating site	55
14	Supervision during service, failures	. 57
15	Inspections	. 59
16	Appendix	. 63



1 General

1.1 Safety instructions

All personnel involved in installation, commissioning, operation, maintenance or repair of the equipment must:

- be suitably professionally qualified and
- strictly observe these Operating Instructions.

Improper operation or misuse can lead to

- serious or fatal injury
- damage to the equipment and other property of the user
- a reduction in the efficiency of the equipment.

Three kinds of safety notices are used in these operating instructions to highlight important information.

MARNING



indicates potential death or injury. Failure to observe this notice may result in serious injury or death.



ATTENTION



indicates potential damage to the equipment and other property of the user. Potential death or injury can also not be ruled out.

NOTE

indicates important information on a particular topic.



1.2 Appropriate use

A ATTENTION



Use the on-load tap-changer only with the transformer specified in the order.

Installation, electrical connection and commissioning of the on-load tapchanger must be carried out exclusively by trained, suitably qualified personnel and under strict observation of these operating instructions.

The operator must ensure that the on-load tap-changer is used as intended.

For safety reasons, any unauthorized work such as installation, alteration, electrical connection, commissioning or modification to the on-load tap-changer equipment is forbidden without first consulting MR!

The trouble-free operation of the drive, the on-load tap-changer and the transformer may be endangered.

A ATTENTION



All relevant fire protection regulations must be strictly observed.



2 Design/Types

The on-load tap-changer consists of the diverter switch with the tap selector attached underneath **Figure 1**.




Figure 1 Three-phase on-load tap-changer

The diverter switch is installed in its own oil compartment.

The on-load tap-changer is secured to the transformer cover by the on-load tap-changer head.

The change-over selector of all type R OLTCs is laterally attached to the tap selector.

The E series tap selector is very different from those of the C and D series (see operating instructions no. 119).

On-load tap-changer models with change-over selector are available with up to a maximum of 27 operating positions.

The design of the on-load tap-changer and the designation of its main parts are shown in the installation drawing 897873 in the appendix.

These Operating Instructions apply to all standard models of the on-load tapchanger variants specified below.



Three-phase on-load tap-changer:

R III 1200-E (**Figure 1**)

Single-phase on-load tap-changer:

R I 1201-E, R I 2002/2402-E, R I 3003-E

Single-phase on-load tap-changers are also available as sets of on-load tap-changers 3 x R I 1201-E, 3 x R I 2002/2402-E or 3 x R I 3003-E

with a shared motor-drive unit.



3 Shipment

On-load tap-changer and motor-drive unit are shipped in the adjustment position. The on-load tap-changer is packed in two parts – diverter switch and tap selector – and is well protected against moisture. Both parts are locked in the adjustment position.

The on-load tap-changer equipment is shipped as follows:

Diverter switch oil compartment with on-load tap-changer head and fitted diverter switch insert (max. approx. 210 kg), **Figure 2**.




Figure 2 Diverter switch oil compartment



Tap selector (max. weight approx. 500 kg), Figure 3.




Figure 3 Tap selector



ED-S (approx. 80 kg), Figure 4.




Figure 4 ED-S

Drive shaft with coupling parts and bevel gear (max. weight approx. 20 kg), **Figure 5**.




Figure 5 Drive shaft



Protective relay RS 2001 (3.5 kg), Figure 6.




Figure 6 Protective relay RS 2001

The shipment is to be fully checked for completeness on the basis of the shipping documents. The parts must be stored in a dry place until installation.

All on-load tap-changer parts must remain in their airtight, protective wrapping and may only be removed shortly before installation.



In general, drive shafts, bevel gear and protective relay are packed with the onload tap-changer.



4.1 Mounting flange

A mounting flange is required for fitting the on-load tap-changer head on the transformer cover. This mounting flange is to be designed according to the sealing surface of the on-load tap-changer head (see **Figure 7** and appendix, drawing 896705).




Figure 7 Mounting flange





We recommend using a tracing template to position the stud bolts (M12, max. length 45 mm). If requested, the tracing template will be supplied with the first installation of a type R on-load tap-changer free of charge (see **Figure 8** and appendix, drawing 890183).




Figure 8 Tracing template

4.2 Attaching the on-load tap-changer to the transformer cover

The diverter switch oil compartment is lowered through the cover aperture (=mounting flange) of the transformer and bolted by the on-load tap-changer head to the mounting flange. The tap selector is then secured to the diverter switch oil compartment, **Chapter 4.3**.



Proceed as follows:

- 1. Place the diverter switch oil compartment on a level surface.
- 2. Clean sealing faces on mounting flange and on-load tap-changer head.
- 3. Place an oil-resistant gasket on the mounting flange.
- 4. Lift the diverter switch oil compartment by hooking up the on-load tapchanger head and carefully lower the oil compartment into the opening of the mounting flange.
 - Pay attention to the screening rings (with $U_m \ge 170$ kV only).
- 5. Check the mounting position of the on-load tap-changer head.
- 6. Fasten the on-load tap-changer head to the mounting flange.

A ATTENTION



Now remove the blocking plate with stud bolt from the coupling of the diverter switch oil compartment bottom, **Figure 9**.




Figure 9 Blocking plate

4.3 Assembly of the diverter switch oil compartment and tap selector

The tap selector is raised from below to the diverter switch oil compartment and connected to it. Thus the mechanical coupling for the tap selector drive is established. Finally, connect the tap selector connecting leads to the diverter switch oil compartment.



Proceed as follows:

1. Put the tap selector down on a level surface. Get ready 4 lock nuts M12 with washers.

A ATTENTION



Now remove the blocking strip from the tap selector coupling, **Figure 10**.

The coupling part must not be turned again afterwards.




Figure 10 Tap selector coupling blocking strip

- 2. Place the tap selector on the lifting device.
- 3. Lift tap selector under diverter switch oil compartment. Take care that the tap selector connecting leads clear the diverter switch oil compartment and remain undamaged.
- 4. Match the position of the two coupling parts and the attachment points of tap selector suspension and oil compartment base.
- 5. Raise the tap selector to its final height.
- 6. Bolt the tap selector suspension to the oil compartment base:



4 lock nuts M12/wrench 19, washers, max. tightening torque 65 Nm **Figure 12**.




Figure 11 Bolting tap selector suspension

Connect tap selector connecting leads to the diverter switch oil compartment:

A ATTENTION



All connections must be carried out carefully. The tightening torques indicated must be applied. Be sure of totally secure bolt connections and screening of the terminal locations using the screening caps supplied with the equipment, **Figure 12**.




Figure 12 Bolt connections and screening of the terminal locations

On-load tap-changers R III 1200-E and R I 3003-E

Secure 6 lines to oil compartment connection terminals:

Each one attached by 1 bolt M12 (wrench 19) locknut and screening cap, tightening torque 80 Nm, **Figure 13**.






Figure 13 Connection terminals for oil compartment, on-load tap-changers R III 1200-E and R I 3003-E



On-load tap-changer R I 2002/2402-E

Secure 4 lines to oil compartment connection terminals:

Each one attached by 1 bolt M12 (wrench 19) locknut and screening cap, tightening torque 80 Nm, **Figure 14**.




Figure 14 Connection terminals for on-load tap-changer oil compartment, on-load tap-changer R I 2002/2402-E



5 Installation of the on-load tap-changer into the bell-type tank

To install the on-load tap-changer into a transformer with a bell-type tank the on-load tap-changer has to be mounted onto a supporting structure. For this purpose, the on-load tap-changer is equipped with a supporting flange at the diverter switch oil compartment (special design, see appendix, drawing 896762).

First lift the on-load tap-changer into the supporting structure and connect it to the tap winding. The on-load tap-changer must be attached to the supporting structure in such a way that it cannot be displaced. The supporting flange has drilled holes so that it can easily be affixed to the supporting structure. We recommend placing temporary spacers between the supporting structure and supporting flange and removing them before the bell-type tank is mounted.

After mounting the bell-type tank raise the on-load tap-changer (diverter switch insert removed) by means of the lifting traverse (see appendix, drawing 890 180) and attach both the on-load tap-changer and the on-load tap-changer head to the bell-type tank. To attach the on-load tap-changer head to the bell-type tank we recommend the use of a mounting flange as described in **Chapter 4.1**.

5.1 Assembly of the diverter switch oil compartment and tap selector, connecting tap selector connecting leads

The diverter switch oil compartment and tap selector should be assembled and the connecting tap selector connecting leads connected in accordance with **Chapter 4.3**.

5.2 Installation of the on-load tap-changer on the supporting structure

Lift the assembled on-load tap-changer (according to **Chapter 4.1**) into the supporting structure. Check the mounting position of the on-load tap-changer and fix it securely.

NOTE

The on-load tap-changer must be suspended fully vertically in the supporting structure. The on-load tap-changer must be mounted so that it need not be lifted by more than 5 to 20 mm to reach its final position after the bell-type tank is set up.



It is of advantage to install spacer blocks between supporting structure and supporting flange of the on-load tap-changer in such a way that the on-load tap-changer is in its envisaged final position after the bell-type tank is set up. By this measure the leads to be connected to the on-load tap-changer can be correctly dimensioned in length. Remove the spacer blocks after the connection of the leads.

Connect the tap winding and the on-load tap-changer take-off leads according to **Chapter 6**.

A ATTENTION



Make sure that the connected leads do not exert any force on the on-load tapchanger. In addition, there must be sufficient clearance so that the on-load tapchanger can be raised to its final mounting position after the bell-type tank is attached.

The drying process and transformer ratio test are to be performed in accordance with **Chapter 7** and **8**.

5.3 Preparation

Before positioning the bell-type tank, the on-load tap-changer head must be separated from the on-load tap-changer.

- 1. For this purpose, open the on-load tap-changer head cover (24 screws M10, wrench 17, with spring washers).
- 2. Pay attention to the cover gasket (round rubber gasket, **Figure 15**).




Figure 15 On-load tap-changer head cover gasket



3. Remove the tap position indicator disc (pull off the spring clip from the shaft end, **Figure 16**).




Figure 16 Tap position indicator disc

4. Take note of the red-marked area which is in the region of the on-load tapchanger head and not covered by the base plate of the diverter switch insert, **Figure 17**.




Figure 17 Marked area



5. Remove the fixing nuts of the base plate (4 nuts M8, wrench 13, spring washers, **Figure 18**).




Figure 18 Base plate fixing nuts

6. Lift the diverter switch insert carefully and vertically out of the diverter switch oil compartment, **Figure 20**.




Figure 19 Lifting diverter switch insert



7. Remove the suction pipe. The connecting piece in the on-load tap-changer head must be withdrawn by pulling in and off, **Figure 20**. Note the connecting piece's o-rings.




Figure 20 Removing suction pipe

8. Unscrew the remaining screw connections in the on-load tap-changer head (17 nuts M8/wrench 13, spring washers), **Figure 21**.




Figure 21 Loosening screw connections

9. Lift off the on-load tap-changer head from the supporting flange. Pay attention to the sealing.



5.4 Attaching the bell-type tank

- 1. Before positioning the bell-type tank clean the sealing surface of the supporting flange. Put the gasket on the supporting flange. Remove the spacer blocks, **Chapter 5.2**.
- 2. Lift the bell-type tank over the active part of the transformer and set up the bell-type tank.
- 3. Before mounting the on-load tap-changer head clean the sealing surfaces (bottom surface of the head, mounting flange). Place an oil-resistant gasket on the mounting flange.
- 4. Position the on-load tap-changer head onto the mounting flange. Pay attention to the two adjusting bolts (Figure 22) and the marks on the supporting flange and on-load tap-changer head (Figure 23), which ensure assembly in the correct position. Depending on the specified height, a distance of 5-20 mm must be left between on-load tap-changer head and supporting flange.




Figure 22 Adjusting bolts






Figure 23 Markings

5. Lift the on-load tap-changer slightly by means of the lifting traverse (**Figure 24** and appendix, drawing 890180). Make sure that all supporting flange stud bolts go easily through the fixing holes of the on-load tap-changer head.

ATTENTION



Under all circumstances, avoid dropping parts into the diverter switch oil compartment. Otherwise there is a risk of the diverter switch blocking, thereby causing severe damage to the on-load tap-changer and the transformer.

Therefore check the quantities of small parts when disassembling and reassembling to ensure they are identical.




Figure 24 Raising on-load tap-changer



6. Fasten the on-load tap-changer head by screwing the nuts to all studs in the red marked region not covered by the diverter switch insert base plate (Figure 25, Chapter 5.3).




Figure 25 Securing on-load tap-changer head

Use 17 nuts M8 (wrench 13, max. tightening torque 14 Nm, securing by locking washers). Fasten the on-load tap-changer head to the mounting flange.

- 7. Remount the suction pipe. Make sure that the O-rings are correctly seated. The O-rings should be slightly greased before being mounted.
- 8. Put the diverter switch insert back in. Make sure that the base plate is in its proper position within the on-load tap-changer head (the red marked areas must be left free).

Attach the base plate:

- 5 M8 nuts (wrench 13, max. tightening torque 14 Nm, secure by locking washers).
- 9. Attach the tap position indicator disc:

Push the spring clip onto the shaft end.



The mounting of the position indicator dial is possible only in the correct position by means of its coupling pin, **Figure 26**.




Figure 26 Tap position indicator disc

10. Close the on-load tap-changer head with the cover. Pay attention to the round rubber gasket in the cover. Evenly screw down the on-load tap-changer cover with 24 screws M10/wrench 17, max. tightening torque 34 Nm, **Figure 27**.




Figure 27 Closing on-load tap-changer head



6 Connection of the tap winding and on-load tap-changer take-off lead

The connection of the tap winding and the on-load tap-changer take-off leads has to be carried out according to the detailed connection diagram included in the delivery.

A ATTENTION



All connections must be made carefully and locked safely. The tap selector take-off leads must be assembled in such a way as to allow all leads to be connected to the tap selector without tension. If necessary, the connection ends of the tap selector take-off leads must be shaped in the form of expansion loops.

In order to avoid overvoltage on terminals connected in parallel, tap selector connection terminals with the same designation must be linked together when using R I 2002-E and R I 3003-E single-phase on-load tap-changers with several tap selector planes connected in parallel.

If requested, bridges for the parallel connection of tap selector planes according to drawing 898713 can be supplied (see appendix).

In the case of on-load tap-changer R I 2402, the parallel connection of tap selector planes by means of parallel bridges is not applicable as an enforced current splitting is provided by two isolated winding branches on each tap selector connection terminals.





6.1 Connection of the tap selector take-off leads

The tap selector's connection terminals are marked on the tap selector bars, **Figure 28**. The connection is made on the thread stud of the tap selector connection terminal using a cable shoe and M20/wrench 30 lock nut, tightening torque 80 Nm.




Figure 28 Tap selector connection terminals

6 Connection of the tap winding and on-load tap-changer take-off lead



Every connection point must be covered by a cover cap. For lateral connection (**Figure 29**), the screening caps are fitted with a straight cable shoe or for face-end connection (**Figure 30**) with an angled cable shoe (see drawing 897 868 in appendix).




Figure 29 Screening caps for lateral connection




Figure 30 Screening caps for face-end connection

The screening caps are each fitted using a steel bracket and 2 screws M5x12, max tightening torque 5.5 Nm and secured by a center mark on the circumference of the screw head.

Note: The distance between the screening caps and adjacent tap selector takeoff leads must be at least 25 mm.



6 Connection of the tap winding and on-load tap-changer take-off lead

6.2 Parallel jumpers for R I 2002-E and R I 3003-E

Bridges for connecting the connection terminals of the tap selector and changeover selector in parallel can be supplied on request.

6.3 Connection of on-load tap-changer take-off lead

The on-load tap-changer take-off lead should be connected with the connecting ring of the diverter switch oil compartment, **Figure 31**.

The screw connection has to be secured.




Figure 31 Diverter switch oil compartment connecting ring



On-load tap-changer R III 1200-E (star point connection)

One through-hole each for M12 bolts is provided on different points of the connection ring displaced by 120° **Figure 32**.




Figure 32 Connecting ring through-hole 1200-E

On-load tap-changers R I 2002-E/2402-E and R I 3003-E

Three or four through-holes each for M12 bolts are provided on different points of the connection ring displaced by 120° **Figure 33**.




Figure 33 Connecting ring through-hole 2002-E and 3003-E



7 Transformer ratio test

We recommend performing a transformer ratio test with low alternating voltage before drying the transformer.

To operate the drive shaft of the on-load tap-changer head a short tube of 25 mm nominal width with a screwed-in coupling bolt of 12 mm diameter together with a hand wheel or a hand crank may be used.

If using the 3 x R I 2002-E...3003-E on-load tap-changer set, all 3 on-load tap-changer heads must be connected to one another using the horizontal drive shaft part, **Chapter 10**.

If using the ED motor-drive unit, 16.5 revolutions are needed per step on the onload tap-changer drive shaft. Operation of the diverter switch is clearly audible.

When operating the change-over selector a higher torque is required.

The end positions, which are indicated in the connection diagram supplied with the delivery, must never be overrun. Therefore always check the attained operating position through the inspection window in the on-load tap-changer cover, **Figure 34**.




Figure 34 On-load tap-changer cover inspection window

Keep the number of tap-change operations without oil to a minimum. After the transformer ratio test, the on-load tap-changer has to be moved back to the adjustment position (see the detailed connection diagram delivered with the equipment).

NOTE

When vapor-phase drying the transformer in its own tank, open the kerosene drain screw, **Chapter 8.1.2**.



8 Drying process and oil filling

8.1 Drying process

As a precondition of MR's guarantee of the dielectric properties of the on-load tap-changer, a minimum drying treatment must be carried out according to the following instructions (alternatively **Chapter 8.1.1** or **8.1.2**).

8.1.1 Vacuum-drying

8.1.1.1 Vacuum-drying in the autoclave

NOTE

Before drying the transformer in the autoclave, the on-load tap-changer cover must be removed and stored outside the autoclave.

· Heating up:

Heat the on-load tap-changer in air at atmospheric pressure, increasing the temperature by approx. 10 $^{\circ}$ C/h up to a final temperature of not more than 110 $^{\circ}$ C.

· Pre-drying:

Pre-dry the on-load tap-changer in circulating air at a max. temperature of 110 °C applied to the on-load tap-changer for a duration of 20 hours.

• Drying:

Vacuum drying at a temperature of 110 °C max. applied to the on-load tapchanger and a residual pressure of at most 10⁻³ bar for a duration of at least 50 hours.

8.1.1.2 Drying in the transformer tank

NOTE

If the transformer is to be dried in its own tank, the interior of the on-load tapchanger must be connected to vacuum by a connecting pipe, as the on-load tap-changer cover remains closed during the entire drying process.

The on-load tap-changer cover is vacuum-proof.

To ensure sufficient drying of the interior of the oil compartment and the incorporated diverter switch insert, a short by-pass tube of 25 mm nominal width must be connected between the transformer tank and a pipe connection at the on-load tap-changer head that leads directly into the interior.

8 Drying process and oil filling



The connection line must be installed on the on-load tap-changer head between the connections E2 and Q or E2 and R (for location of the connections on on-load tap-changer head, see **Chapter 9** and appendix, drawing 893 899).

Procedure, temperature, duration and pressure of the drying process are described in **Chapter 8.1.1.1**.

8.1.2 Vapor-phase drying

NOTE

In order to drain off the kerosene condensate in the oil compartment, the kerosene drain screw in the oil compartment base must be opened before the drying process commences, **Figure 35**.




Figure 35 Kerosene drain screw

The kerosene drain screw has a hexagonal recess and is easily accessible between oil compartment base and tap selector gear and can be unscrewed from outside.

The thread of the kerosene drain screw features a plastic coating and requires a higher turning torque.

NOTE

Turn the kerosene drain screw only to the point of increased force.

8 Drying process and oil filling



When vapor-phase drying the transformer in its own tank (see Chapter 8.1.2.2) the kerosene drain screw, in general, is not accessible from outside and can only be opened from the inside. In this case, the diverter switch insert must be removed, the kerosene drain screw screwed on with an extended socket wrench (see appendix, drawing 890 182) and the diverter switch insert refitted.

A ATTENTION



The kerosene drain screw must be closed again after the drying process to ensure that no oil from the diverter switch oil compartment can flow into the transformer oil tank!

8.1.2.1 Vapor-phase drying in the vacuum autoclave

NOTE

Before drying the transformer in the autoclave, the on-load tap-changer cover must be removed and stored outside the autoclave.

· Heating up:

Supply kerosene vapor at a temperature of approx. 90°C. Keep this temperature constant for approx. 3-4 hours.

Drying:

Increase the kerosene vapor temperature applied to the on- load tap-changer by approx.10 °C/h to the desired final temperature which should not exceed 125 °C. The duration of the drying process depends on the transformer.

8.1.2.2 Vapor-phase drying in the transformer tank

If the transformer is to be dried in its own tank, the on-load tap-changer cover remains closed during the entire drying process.

The on-load tap-changer cover is vacuum-proof. To ensure sufficient drying of the interior of the diverter switch oil compartment and of the diverter switch insert, it is necessary to connect a common tube of at least 50 mm nominal width between the kerosene vapor lead and at least two pipe connections of the on-load tap-changer head leading into the diverter switch compartment.

For this purpose use pipe connections R and Q for on-load tap-changer type R (for position of pipe connections at the on-load tap-changer head see Chapter 9 and appendix, drawing 893 899).

Procedure, temperature and duration of the drying process are described in Chapter 8.1.2.1.



8.1.2.3 Operating the on-load tap-changer

A ATTENTION



Do not operate the on-load tap-changer after drying without oil wetting, otherwise bearings and gaskets will be damaged.

The on-load tap-changer must not be operated before the diverter switch oil compartment has been filled with oil and the tap selector has been completely immersed in transformer oil.

8.2 Filling with oil

ATTENTION



The oil compartment and the associated oil conservator must be filled only with new mineral insulating oil for transformers according to IEC 296. The use of other oil puts at risk the trouble-free operation of on-load tap-changer and transformer.

Close the on-load tap-changer head with the cover. Tighten all 24 cover bolts M10, wrench 17 equally (max. tightening torque 34 Nm).

On-load tap-changer and transformer are simultaneously filled with new transformer oil under vacuum.

When filling with oil, pipe connection S or R on the on-load tap-changer head is to be used. For evacuating purposes, a by-pass tube between connections E2 and Q is to be installed in order to simultaneously apply vacuum to the transformer and the oil compartment.



9 Pipe connections

The on-load tap-changer head is provided with 3 pipe connections for different purposes. After loosening the pressure ring (4 M10/wrench 17 screws), all pipe connections can be freely swiveled (**Figure 36** and appendix, 893 899).




Figure 36 Pipe connections

9.1 Pipe connection R for protective relay RS 2001

Install the protective relay RS 2001 (see appendix, dimension drawing 892608) according to our Operating Instructions No. 59.

NOTE

The stamped serial number must match the serial number of the on-load tapchanger.

The protective relay must be installed as close as possible to the on-load tapchanger head in a horizontal position.

The directional arrow on the protective relay must point towards the oil conservator in the mounted state.

The pipe leading to the oil conservator must have an inclination of at least 2 %.



9.2 Pipe connection S for suction pipe

If no feed pipe of a stationary oil filter unit is connected here, a pipe must be connected which ends with a drain valve at the side of the transformer tank at operating height.

9.3 Pipe connection Q (special version, only needed with oil filter unit)

This pipe connection is used to connect the oil return for a stationary oil filter unit. If no oil filter unit is connected, a blank cover is mounted instead of the pipe connection.

9.4 E2 connection

This connection is sealed using a blank cover. It runs into the transformer's oil tank directly under the on-load tap-changer head and can if necessary be connected to a collecting pipe for the Buchholz relay.



10 Mounting the motor-drive unit, bevel gear and drive shaft

10.1 Mounting the motor-drive unit (see appendix, dimension drawing 895660, 893381)

Detailed installation instructions can be found in our Operating Instructions no. 138 for the ED motor-drive unit.

NOTE

The serial number of the motor-drive unit must match the serial number of the on-load tap-changer (nameplate).

Motor-drive unit and on-load tap-changer must be in the same operating position.

The adjustment position is indicated in the connection of the on-load tapchanger included in delivery.

The motor-drive unit must be mounted at the intended position on the transformer tank in a vertical position and protected against transformer vibrations.

10.2 Mounting the bevel gear

The bevel gear is to be attached to a support on the transformer cover by 2 bolts (through-holes 18 mm diameter, see appendix, drawing 892916).

NOTE

The stamped serial number must match the serial number of the on-load tapchanger.

The horizontal drive shaft must align with the shaft end of the on-load tapchanger head.

After loosening the pressure ring (6 bolts M8, wrench 13) the upper gear unit can be freely swiveled, **Figure 37**. When having adjusted the upper gear unit, tighten the pressure ring (max. tightening torque 15 Nm). **The bolts should be secured.**

The above notes also apply analogously to the special models of bevel gears and to the intermediate bearings of the vertical or horizontal drive shaft.






Figure 37 Upper gear unit

10.3 Mounting the drive shaft (square tube)

The drive shaft must be mounted according to our Operating Instructions No. 42.

The drive shaft is the mechanical connection between the motor-drive unit and the on-load tap-changer head.

The bevel gear changes the direction from vertical to horizontal. Accordingly, the vertical drive shaft has to be mounted between motor-drive unit and bevel gear and the horizontal drive shaft has to be mounted between bevel gear and on-load tap-changer head.

The drive shaft itself consists of a square tube and is to be coupled by two coupling brackets and one coupling bolt at both ends to the drive or driven shaft end of the device to be connected.

NOTE

When mounting the drive shaft make sure that the shaft ends to be connected are aligned exactly.

Square tubes, coupling brackets, coupling bolts, screws, nuts and lock tabs are made of corrosion-resistant steel. We recommend, however, to apply the same outside coating to these parts as to the transformer tank.

The square tubes and the guard plate, which serves as a foot step protection for the horizontal drive shaft over the transformer cover, are delivered longer than necessary (various standard lengths). They must be cut to the right lengths when they are mounted on the transformer.

The lag of the motor-drive unit must then be balanced with the diverter switch operation of the on-load tap-changer (as described in our operating instructions no. 138 for ED).



On-load tap-changer 3 x R I 2002-E...3003-E

The following procedure is recommended for the R III1200 on-load tap-changer.

Due to the special arrangement of three column constructions, the on-load tapchanger heads must be coupled together above the transformer cover.

Turning the upper gear unit will initiate a tap-change operation, so ensure that the diverter switches are returned exactly to the adjustment position once the gear units have been adjusted.

For this purpose proceed as follows:

- 1. Check that the operating positions of all on-load tap-changers are identical (inspection window in the on-load tap-changer head). Each of the singlephase on-load tap-changers must be in the adjustment position.
- 2. Turn the upper gear unit of the on-load tap-changer heads into the desired mounting position and fix them there (screw-tighten and secure pressure rings).

Take note of the arrow on the drive shaft flange below the punched serial number. The direction of the arrow indicates the direction of rotation when turning the hand crank of the motor-drive unit clockwise and must be the same on all gear units.

- 3. Operate the on-load tap-changer poles separately by one step by rotating the shaft ends **counter-clockwise** until the diverter switch operates once.
 - Check coincidence of the operating positions of all on-load tap-changer heads.
- 4. Mount the horizontal drive shaft between the on-load tap-changer heads.
- 5. Return the whole on-load tap-changer set, that is all on-load tap-changer poles together, into the adjustment position. The adjustment position must be reached by turning the drive shaft in clockwise direction.

Check simultaneous operation of all diverter switches. Check coincidence of the operating positions of all on-load tap-changer heads.

6. Mount the vertical drive shaft.



ATTENTION



The supervisory circuit must be installed according to the connection diagram of the relevant motor-drive unit. Incorrect installation will cause damage of both on-load tap-changer and transformer in case of malfunction.



11 Commissioning the on-load tap-changer at the transformer manufacturer's site

11.1 Tap change operation tests

Before applying voltage to the transformer, test tap-change operations must be carried out to check the mechanical functions of on-load tap-changer and motor-drive unit.

These tap-change operations are to be performed over the entire operating

Make sure that in each operating position the tap position indicators of motordrive unit and on-load tap-changer (inspection window in the on-load tapchanger head) read the same position.

A ATTENTION



Non-conformance of the tap position indicator of the on-load tap-changer and motor-drive unit indicates a coupling error. Misalignment of coupling between on-load tap-changer and motor-drive unit leads to severe damage of on-load tap-changer and transformer, if operation is continued. Do not put the transformer into operation.

Check, in both end positions, the automatic switching off and the function of the electrical and mechanical end position limitation (see Operating Instructions no. 138 for the motor-drive unit ED).

11.2 Complete oil filling

Bleed and completely fill the on-load tap-changer with transformer oil via the oil conservator.

Bleed:

the oil tank of the on-load tap-changer head via the air-vent valve in the onload tap-changer cover (E1):



11 Commissioning the on-load tap-changer at the transformer

Open the screw cap M30/wrench 36, lift the valve tappet by means of a screwdriver, **Figure 38**.




Figure 38 Opening screw cap

 Push suction pipe (S) through bleeder screw on connecting elbow: screw cap M16/wrench 22, max. tightening torque 9 Nm, bleeder screw M6 with slotted head, max. tightening torque 2 Nm, Figure 39.

ATTENTION



Make sure that the suction pipe has been bled correctly. The insulation capability of the on-load tap-changer to ground is otherwise significantly impaired.




Figure 39 Connecting elbow vent screw



11.3 Ground connections

Connect the ground screws of the on-load tap-changer head (2 screws M12 with nuts, wrench 19, max. tightening torque 60 Nm, **Figure 40**) to the transformer cover.




Figure 40 On-load tap-changer head grounding screws

Connect grounding screw M12/wrench 19 (max. tightening torque 60 Nm) of motor-drive unit protective housing with transformer tank.

11.4 Electrical tests on the transformer

Following the work described above, the electrical tests required for the commissioning of the transformer can now be performed.



12 Transportation to the operating site

If the motor-drive unit has to be dismounted for the transport of the transformer to the operating site, operate the motor-drive unit into the adjustment position and then uncouple it.

A

ATTENTION



Do not operate the motor-drive unit while the on-load tap-changer is not coupled.

It is reassembled as described under Chapter 10.1 and 10.3.

NOTE

If the transformer is filled with oil but stored or transported without oil conservator, a connecting lead must be installed between the interior of the diverter switch oil compartment and the transformer oil tank to equalize the pressure caused by the expansion of the oil.

The connecting lead must run between connections E2 and Q on the on-load tap-changer head. For a short operating period of 2-4 weeks without an oil conservator, lowering the oil level in the on-load tap-changer head by around 5 liters is sufficient.

If the transformer is to be completely emptied, drain also the switching oil of the on-load tap-changer completely.

The interior of the diverter switch oil compartment is to be conserved in the same way as the transformer (e.g. by filling with N_2).

For longer immobilization periods, the motor-drive unit heating must be connected and operated.



13 Commissioning at the operating site

Before putting the transformer into service operational tests of on-load tapchanger and motor-drive unit have to be performed according to **Chapter 11.1**. The function of the protective relay must also be checked at this point.

NOTE

The protective relay must be inserted into the tripping circuit of the circuitbreakers so that the transformer is immediately shut down by the circuitbreakers when the protective relay is tripped (see operating instructions no. 59 for RS 2001 the protective relay).

A test trip of the connected circuit breakers should be made by pressing the test button ""OFF"" of the protective relay.

Make sure that closing of the circuit breakers is only possible again after the protective relay has been brought to the "IN SERVICE" position by pressing the other test button.

A ATTENTION



Check that all stop valves between oil conservator and on-load tap-changer are open.

After energizing the transformer, tap-change operations under load can be performed. The switching gas accumulating under the on-load tap-changer cover will cause small amounts of oil to be displaced or will escape through the oil conservator.



14 Supervision during service, failures

Monitoring the on-load tap-changer and motor-drive unit is limited to occasional visual checks of on-load tap-changer head, protective relay and motor-drive unit.

Pay particular attention to the following:

- sealing points of the on-load tap-changer head, protective relay and connected pipes are to be oil-proof,
- · gaskets of the protective housing of the motor-drive unit,
- correct functioning of the installed electrical heater in the protective housing of the motor-drive unit
- the condition of the control devices in the motor-drive unit.

MARNING



If the protective relay is triggered, the on-load tap-changer and transformer must be thoroughly checked. To do this, remove the diverter switch insert and check as described in the inspection instructions. Proceed in detail according to Operating Instructions No. 59 for the protective relay RS 2001.

Do not use the equipment again until you are sure there is no damage to the on-load tap-changer or transformer.

Energizing the transformer without prior checking is not permitted as serious damage to the on-load tap-changer and the transformer can occur.

For more serious problems with the on-load tap-changer and motor-drive unit, which cannot be easily corrected on site, or if the protective relay has been tripped, please inform your authorized MR representative, the transformer manufacturer or contact us directly at:

Maschinenfabrik Reinhausen GmbH Technischer Service Postfach 12 03 60 D-93025 Regensburg

Tel.: (+49) 9 41 / 40 90-0 Fax: (+49) 9 41 / 40 90-501

Telex: 65881



15 Inspections

NOTE

The tap-changing equipment must be inspected at regular intervals to maintain a high level of operational safety.

The inspection can be carried out by qualified and MR-trained personnel usually within one day, provided it is well prepared and organized.

We generally recommend to have inspection carried out by our Technical Service.

This guarantees a professional performance of the inspection and ensures the updating of specific components to the latest operational state.

If the inspection is not to be carried out by MR personnel, we recommend that you ask for a quotation of the spare parts required for the inspection (please quote the on-load tap-changer serial number and the number of switching operations).

The numbers of tap-change operations determining the inspection intervals indicated in Table II and Table III are figures based on experience with use of usual oil qualities.

The tap selector in the on-load tap-changer does not require any maintenance. In special cases, however, for example in industrial transformers where high numbers of tap-change operations are to be expected, our technical service department must be contacted after about 1,000,000 tap-change operations.

The diverter switch insert in the on-load tap-changer must be replaced after 800,000 tap-change operations at the latest. The protective relay must be connected The protective relay must be connected

If the number of tap-change operations per year is 15,000 or higher, we recommend the use of our stationary oil filter unit type OF100 with a paper filter insert (see Operating Instructions BA018). Use of the oil filter unit OF 100 with combined filter is prescribed for all type R on-load tap-changers where Um = 300 kV (insulated to ground) and there is a linked operating voltage on the on-load tap-changer of 245...260 kV. Use of the oil filter unit OF 100 with combined filter is generally prescribed for all type R on-load tap-changers where $U_m = 362 \text{ kV}$ (insulated to ground).

Filtering of the switching oil allows the inspection intervals to be extended.

The insulating oils in the transformer are to be monitored by the operator according to the appropriate rules and regulations.

If inspections are not carried out by MR personnel, we request a report to supplement our inspection files.



A ATTENTION



Disregard of the inspection intervals puts at a risk the trouble-free operation of on-load tap-changer and transformer.

Standard values for oil testing according to CIGRE report 12-13 (1982) apply to transformer oil at service temperature:

On-load tap-changer	Water content ¹	Dielectric strength ²
Star-point on-load tap-changer	< 40 ppm	> 30 kV/2.5 mm
Single-phase on-load tap-changer	< 30 ppm	> 40 kV/2.5 mm

Table 1

Approximate values for monitoring the on-load tap-changer oil measured according to Karl-Fischer method based on IEC Publication 814

² measured according to DIN VDE 0370 Part 1

On-load tap-changer	Transformer	Number of tap-change operations	
	Rated current	without MR oil filter unit	with MR oil filter unit
R III 1200-E	up to 600 A up to 1200 A	80000 60000	100000 100000
R I 2002-E	up to 2000 A	40000	80000
R I 2402-E	up to 2400	40000	80000
R I 3003-E	up to 3000	40000	80000

Table 2 Inspection intervals for type R on-load tap-changers in star point application, single-phase on-load tap-changers where Um < 245 kV and in autotransformers or for regulation at line end of winding of the transformer.

Initial inspection and further inspections: After every 7 years or the number of tap-changer operations given in table II, depending on what is reached first.

On-load tap-changer	Transformer	Number of tap-change operations		
	Rated current	without MR oil filter unit	with MR oil filter unit	
RII 1201-E	up to 600 A up to 1200 A	40000 30000	50000 50000	
R I 2002-E	up to 2000 A	20000	40000	
R I 2402-E	up to 2400	20000	40000	

Table 3 Inspection intervals for type R on-load tap-changers in star point application, single-phase on-load tap-changers where Um < 245 kV and in autotransformers or for regulation at line end of winding of the transformer.

15 Inspections



On-load tap-changer	Transformer	Number of tap-change operations	
	Rated current	without MR oil filter unit	with MR oil filter unit
R I 3003-E	up to 3000	20000	40000

Table 3 Inspection intervals for type R on-load tap-changers in star point application, single-phase on-load tap-changers where Um < 245 kV and in autotransformers or for regulation at line end of winding of the transformer.

First inspection: after 2 years or 20,000 tap-change operations, depending on what is reached first.

Further inspections: Without MR filter unit after every 4 years, with MR filter unit (combined filter) after every 6 years or the number of operations indicated in table III – whatever is reached first.


16 Appendix



16 Appendix


Installation drawing	8978730
Tap and change-over selector connection terminals	8978680
On-load tap-changer head	8938998
Template for on-load tap-changer head	8901836
Supporting flange for bell-type tank installation	8967623
Lifting traverse	8901803
Socket wrench for kerosene drain plug	8901827
Protective relay RS 2001, dimensional drawing	8926085
Motor-drive unit MA 7, dimensional drawing	895660A
CD 6500 bevel gear, dimension drawing	8929166







Variant 1
Tap and change-over selector connection terminal with <u>straight</u> cable shoe (customer request)



Variant 2
Tap and change-over selector connection terminal with <u>angled</u> cable shoe 90° (customer request)




Table 1: Distance to center point for tap selector/change-over selector (connection points)

Contact designation	
Fine tap selector contact	352
"0" contact change-over selector	176
"+" and "-" contact change-over selector	383




x min. between screening cap and neighboring feed =25 mm (rated lightning impulse withstand voltage 300 kV 2.3/50 and line Ø18/Ø28)

<u>Table 1:</u> Connection variants which can be produced with part numbers of the screening caps needed.


				CONTACT DESIGNATION				
		1 to n - 2	n - 1	n and/or K	0	+	-	
OAD ER	with coarse change- over selector	Var. 1 055 640: Var. 2 082 751:	Var. 1 055 640:	no customer connection	Var. 1 055 040: Var. 2 082 751:	Var. 1 055 743: Var. 2 084 414:	Var. 1 055 640: Var. 2 082 751:	
OF ON-LOAD >-CHANGER	with reversing change-over selector	Var. 1 055 640: Var. 2 082 751:	Var. 1 055 640:	no customer connection	Var. 1 055 743: Var. 2 084 414:	Var. 1 055 640: Var. 2 022 751:	Var. 1 055 640: Var. 2 082 751:	
TYPE (TAP-	without change-over selector	Var. 1 055 640: Var. 2 032 751:	Var. 1 055 640: Var. 2 082 731:	Var. 1 035 640: Var. 2 282 751:				

The above variants apply for one tap selector connecting lead per contact. Two tap selector connecting leads per contact on request.


























70 OILTAP® R BR E














www.reinhausen.com

©Maschinenfabrik Reinhausen GmbH Falkensteinstrasse 8

D - 93059 Regensburg

Tel.: +49 (0)941 4090 0 Fax: +49 (0)941 4090 7001 E-mail: sales@reinhausen.com

