

VALURA Oy	EN 124 PRODUCT CONTROL TYPE TESTING	
------------------	--	--

TESTING: WRITE THE RESULTS OF MOD PP01.04

18	7.2	TEST LOAD				
		if CO \geq 250 mm	Declared class in kN	400	400	400
		If CO < 250 mm	Declared class in kN x CO/250			
19	7.3	Permanent set of cover with the application of 2/3 of the test load	\leq 1/100 clear opening for A15 and B125			
			\leq 1/300 clear opening Co from C250 to F900 if cover			
			Is secured with locking device	0.9	0.9	0.9
			1 mm max if clear opening CO < 300 mm			
			\leq 1/500 clear opening Co from C250 to F900 if cover			
			Is secured with mass			
20	8.3	Test load	Maintained for 30s with no cracks	OK	OK	OK
		Breaking	Increase till crack	> 450	>450	>450

MARKING

21	9a	EN 124-2		OK	OK	OK
	9b	Class		OK	OK	OK
	9c	VLR		OK	OK	OK
	9d	Factory of manufacture in code		OK	OK	OK
	9e	Date of manufacture		OK	OK	OK
	9h	Identification of product (voluntary)		OK	OK	OK

ADDITIONAL REQUIREMENT (TECHNICAL SHEET, SPECIFICATION)

Referement:

--	--	--

DATE: 02/02/2023	SIGNATURE: 
-------------------------	---