

|                                                                                   |                                                                    |                                                                                                                              |
|-----------------------------------------------------------------------------------|--------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------|
|  | <b>CERTIFICAT DE<br/>ANALIZĂ</b><br><b>CERTIFICATE of ANALYSIS</b> | Numarul<br>documentului : KK.FR.014<br>Numarul de : 02<br>Revizie<br>Data revizuirii : 06.05.2014<br>Numarul paginii : 1 / 1 |
|-----------------------------------------------------------------------------------|--------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------|

|                                                            |                                                                            |
|------------------------------------------------------------|----------------------------------------------------------------------------|
| <b>NUMELE PRODUSULUI</b><br><i>PRODUCT NAME</i>            | <b>Eurofix Acrylic Sealant 280ML (Gw.500) White (24)</b><br><b>**New**</b> |
| <b>NR. ÎNCĂRCARE PRODUS</b><br><i>PRODUCT BATCH NUMBER</i> | <b>24SD2569/305 – 24SD2570/305 – 24SD2578/305</b>                          |
| <b>DATA FABRICATIEI</b><br><i>PRODUCTION DATE</i>          | <b>26.04.2024 – 26.04.2024 – 27.04.2024</b>                                |
| <b>DATA EXPIRĂRII</b><br><i>EXPIRATION DATE</i>            | <b>26.10.2025 – 26.10.2025 – 27.10.2025</b>                                |
| <b>DATA RAPPORTULUI</b><br><i>REPORT DATE</i>              | <b>30.05.2024</b>                                                          |
| <b>RAPORT NR</b><br><i>REPORT NUMBER</i>                   | <b>02</b>                                                                  |

| SPECIFICAȚII TEHNICE<br>TECHNICAL PROPERTIES |                                  |                   |                              |                         |                  |                  |
|----------------------------------------------|----------------------------------|-------------------|------------------------------|-------------------------|------------------|------------------|
| ANALIZA<br>ANALYSIS                          | METODA DE<br>TEST<br>TEST METHOD | BİRİM<br>UNIT     | KABUL DEĞERLER<br>REF. VALUE | 24SD2569/<br>305        | 24SD2570/<br>305 | 24SD2578/<br>305 |
| CULOARE<br>(COLOR)                           | VISUAL<br>(VISUAL)               | ---               | ALB (WHITE)                  | ALB (WHITE)             |                  |                  |
| ASPECT<br>(APPEARANCE)                       | VIZUAL<br>(VISUAL)               | ---               | OMOGEN<br>(HOMOGENEOUS)      | OMOGEN<br>(HOMOGENEOUS) |                  |                  |
| DENSITATE<br>(DENSITY)                       | TS EN ISO 2811-1                 | g/cm <sup>3</sup> | 1,70±0,03                    | 1,700                   | 1,700            | 1,700            |
| USCAREA<br>SUPRAFAȚEI<br>(TACK FREE TIME)    | ASTM C 679-03                    | dk                | 5-20                         | 5                       | 5                | 5                |

\* Condiții de testare: Temperatura; 23°C, umiditate: Rh- 50%

**CONTROLOR : AHMET TURAN OK**  
**CONTROLLER**




AKKİM YAPI KİMYASALLARI SAN. TİC. A.Ş.  
 Yeşilbayır Mah. Şimşir Sk. No:22 34555 Hadımköy/İSTANBUL  
 TEL:0212 771 13 71 FAX:0212 771 38 88  
 E-Mail:kalitekontrol@akkim.net