

Inspection certificate to EN 10204**3.1** 

Customer: **SWS ENGINEERING& CONSULTING SRL**
42 A Daniel Danielopolu str.
014143 SECTOR 1, BUCURESTI B

Machine : Screw compressor
Package model : SX 6/ 11 bar
Serial number : 9868
Year of manufacture : 2018
KAESER part no. : SX.2
KAESER contract no. : 10679728
Date of test : 09.11.2018

Type of test: **Inspection certificate**

The total unit has been submitted to an inspection test.

Nominal value

Outlet pressure : 10 bar (g)
Free air delivery : 0,48 m³/min
Spec. Electrical power consumption : 8,75 kW / (m³/min)

The machine values are within tolerance according to ISO 1217:2009 Annex C.

The function of the shutdown system/safety relief valves was found to be in order.
No faults occurred during the test run.

Remarks:

We hereby certify that the above named equipment/part complies with regulations.

Coburg, 15.11.2018


KAESER KOMPRESSOREN SE
96410 Coburg, Postfach 21 43

Competent Examiner