



No: RMD 1017 Rev. AF

We,

6021 Innovation Blvd. Shakopee, MN 55379

declare under our sole responsibility that the product,

Rosemount 3051 Pressure Transmitters

manufactured by,

6021 Innovation Blvd. Shakopee, MN 55379 USA

to which this declaration relates, is in conformity with the provisions of the European Union Directives, including the latest amendments, as shown in the attached schedule.

Assumption of conformity is based on the application of the harmonized standards and, when applicable or required, a European Union notified body certification, as shown in the attached schedule.

(signature) Vice President of Global Quality (function)

Mark Lee September 8, 2021 (date of issue & place)





No: RMD 1017 Rev. AF

EMC Directive (2014/30/EU)

Harmonized Standards: EN 61326-1:2013, EN 61326-2-3:2013

PED Directive (2014/68/EU)

Rosemount 3051CA4; 3051CD2, 3, 4, 5; 3051HD2, 3, 4, 5; (also with P9 option)

QS Certificate of Assessment - Certificate No. 12698-2018-CE-USA-ACCREDIA Module H Conformity Assessment
Other Standards Used: ANSI/ISA61010-1:2004
Note - previous PED Certificate No. 59552-2009-CE-HOU-DNV

All other Rosemount 3051 Pressure Transmitters

Sound Engineering Practice

Transmitter Attachments: Diaphragm Seal, Process Flange, or Manifold

Sound Engineering Practice

Rosemount 3051CFx DP Flowmeters

See DSI 1000 Declaration of Conformity

RoHS Directive (2011/65/EU)

Models 3051 Pressure Transmitters

Harmonized standard: EN 50581:2012

Does not apply to the following options:

- Wireless output code X
- Low power output code M





No: RMD 1017 Rev. AF

ATEX Directive (2014/34/EU)

BAS97ATEX1089X - Intrinsic Safety

Equipment Group II Category 1 G
Ex ia IIC T5/T4 Ga
Harmonized Standards Used:
EN IEC 60079-0:2018, EN60079-11:2012

BAS00ATEX3105X - Type n

Equipment Group II Category 3 G

Ex nA IIC T5 Gc

Harmonized Standards Used:

EN60079-0:2012 + A11:2013*, EN60079-15:2010

*(A review against EN IEC 60079-0:2018 which is harmonized, shows no significant changes relevant to this equipment so EN60079-0:2012 + A11:2013 continues to represent "State of the Art".)

BaseefallATEX0275X - Dust

Equipment Group II Category 1 D

Ex ta IIIC T95°C T500105°C Da

Harmonized Standards Used:

EN60079-0:2012 + A11:2013*, EN60079-31:2014

*(A review against EN IEC 60079-0:2018 which is harmonized, shows no significant changes relevant to this equipment so EN60079-0:2012 + A11:2013 continues to represent "State of the Art".)

KEMA00ATEX2013X - Flameproof

Equipment Group II Category 1/2 G

Ex db IIC T6...T4 Ga/Gb

Harmonized Standards Used:

EN IEC 60079-0:2018, EN60079-1:2014, EN60079-26:2015





No: RMD 1017 Rev. AF

PED Notified Body

DNV GL Business Assurance Italia S.r.l. [Notified Body Number: 0496]

Via Energy Park, 14, N-20871

Vimercate (MB), Italy

Note – equipment manufactured prior to 20 October 2018 may be marked with the previous PED Notified Body number; previous PED Notified Body information was as follows:

Det Norske Veritas (DNV) [Notified Body Number: 0575]

Veritasveien 1, N-1322

Hovik, Norway

ATEX Notified Bodies

DEKRA [Notified Body Number: 0344] Utrechtseweg 310, 6812 AR Arnhem P.O. Box 5185, 6802 ED Arnhem The Netherlands Postbank 6794687

SGS FIMKO OY [Notified Body Number: 0598]

Takomotie 8 FI-00380 Helsinki,

Finland

ATEX Notified Body for Quality Assurance

SGS FIMKO OY [Notified Body Number: 0598]

Takomotie 8 FI-00380 Helsinki, Finland