

Specificații tehnice (F4.1)

[Acest tabel va fi completat de către ofertant în coloanele 3, 4, 5, 7, iar de către autoritatea contractantă – în coloanele 1, 2, 6, 8]

Numărul procedurii de achiziție: ocds-b3wdp1-MD-1624529732372							
Denumirea procedurii de achiziție: Utilaje pentru sistemele de încălzire, pompe de rețea, cazane pe combustibil solid							
Cod CPV	Denumirea bunurilor	Modelul articolului	Țara de origine	Producător	Specificarea tehnică deplină solicitată de către autoritatea contractantă	Specificarea tehnică deplină propusă de către ofertant	Standard de referință
1	2	3	4	5	6	7	8
42122000-0	Pompă de circulație	GHNbasic II 65-190 F	Slovenia	IMP Pumps	Motor cu rotor umed; U – 380 V, 50 Hz; Q min. – 30 m ³ /h la înălțimea minim 14 m; Ø – 65 mm (2½’’), conectarea prin flanșe; Gradul de protecție minim IP 44.	GHNbasic II 65-190F poz. 8113 cu 250V/50Hz Diagram Head (H) in meters (m) on the y-axis (0 to 25). Flow rate (Q) in m³/h on the x-axis (0 to 60). Three speed curves are shown: 1 (solid blue), 2 (dashed blue), and 3 (dotted blue). Efficiency curves (η) are shown as shaded areas. Power curve (P) is shown as a solid blue line.	

Semnat: _____ Numele, Prenumele: Ciomasu Trifan În calitate de: administrator

Ofertantul: SC Lerai Grup SRL Adresa: or. Chisinau, str. Bulgara 18