

Nanjing Jingning Quality Inspection Company

Quality Certificate

Drywall Screw, Coarse/Fine Thread, GRAY phosphate



Specification	Items	torsion standard	Attack speed	result
Drywall Screw, Fine Thread	3,5x16	2.80	1S	Acc.
	3,5x19	2.80	1S	Acc.
	3,5x25	2.80	1S	Acc.
	3,5x35	2.80	1S	Acc.
	3,5x45	2.80	1S	Acc.
	3,5x55	2.80	1S	Acc.
	4,2x70	4.90	1S	Acc.
	4,8x89	4.90	1S	Acc.
	4,8x102	6.80	1S	Acc.
Drywall Screw, Coarse Thread	3,5x16	2.80	--	Acc.
	3,5x19	2.80	--	Acc.
	3,5x25	2.80	--	Acc.
	3,5x32	2.80	--	Acc.
	3,5x35	2.80	--	Acc.
	3,5x41	2.80	--	Acc.
	3,5x45	2.80	--	Acc.
	3,5x51	2.80	--	Acc.
	3,5x55	2.80	--	Acc.
	3,8x64	3.40	--	Acc.
	4,2x70	4.90	--	Acc.
	4,2x76	4.90	--	Acc.
	4,8x89	6.80	--	Acc.
	4,8x95	6.80	--	Acc.
	4,8x102	6.80	--	Acc.
	4,8x120	6.80	--	Acc.
	4,8x152	6.80	--	Acc.

Remark: Acc. Stands for acceptable

Steel grade: SWRCH22A						
Specification: Q/ASB 234-2015						
Chemical composition & Technical specification						
Element	C%	Si%	Mn%	P%	S%	Cr%
Ratio	21	8	78	1.7	0.7	2
	Elongation			Contraction Percentage		Tensile Strength (Mpa)
Ratio	28%			64%		498

Inspection date: 2016.1.20

Inspector:Li Jun

